



Sep 10, 2024

STONE

6239 N LEAVITT ST, Chicago IL 60659.

Dear **STONE** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

STONE

6239 N LEAVITT ST, Chicago IL 60659.

Estimadas familias de **STONE**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-SEP-16	3.970	ppb
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-SEP-16	3.710	ppb
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-SEP-16	1.800	ppb
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-SEP-16	2.060	ppb
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Initial	20-SEP-16	5.010	ppb
51074	51074-1-E-HAL-WC04	Across from Room 101, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-SEP-16	1.780	ppb
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-SEP-16	4.060	ppb
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-SEP-16	2.320	ppb
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-SEP-16	2.460	ppb
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Flush180	21-AUG-20	1.280	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Initial	20-SEP-16	9.140	ppb
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-1-E-HAL-WC05	Across from Room 101, Right Fountain	Initial	21-AUG-20	1.000	ug/L
51074	51074-1-HAL-WC03	Across from Room 104, Left Fountain	Flush180	20-SEP-16	0.172	ppb
51074	51074-1-HAL-WC03	Across from Room 104, Left Fountain	Flush180	20-SEP-16	0.197	ppb
51074	51074-1-HAL-WC03	Across from Room 104, Left Fountain	Flush180	20-SEP-16	0.259	ppb
51074	51074-1-HAL-WC03	Across from Room 104, Left Fountain	Flush180	20-SEP-16	0.124	ppb
51074	51074-1-HAL-WC03	Across from Room 104, Left Fountain	Initial	20-SEP-16	1.000	ppb
51074	51074-1-HAL-WC02	Across from Room 104, Right Fountain	Flush180	20-SEP-16	0.192	ppb
51074	51074-1-HAL-WC02	Across from Room 104, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51074	51074-1-HAL-WC02	Across from Room 104, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51074	51074-1-HAL-WC02	Across from Room 104, Right Fountain	Flush180	20-SEP-16	0.125	ppb
51074	51074-1-HAL-WC02	Across from Room 104, Right Fountain	Initial	20-SEP-16	0.144	ppb
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-SEP-16	0.753	ppb
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-SEP-16	0.618	ppb
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-SEP-16	3.720	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-SEP-16	1.230	ppb
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Initial	20-SEP-16	2.680	ppb
51074	51074-1-N-HAL-F06	Across from Room 107, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-SEP-16	0.254	ppb
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-SEP-16	0.137	ppb
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-SEP-16	0.175	ppb
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-SEP-16	1.000	ppb
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Initial	20-SEP-16	0.195	ppb
51074	51074-1-N-HAL-F07	Across from Room 107, Right Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-SEP-16	0.311	ppb
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-SEP-16	0.282	ppb
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-SEP-16	0.367	ppb
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-SEP-16	0.300	ppb
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Initial	20-SEP-16	0.690	ppb
51074	51074-2-N-HAL-F05	Across from Room 209, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-SEP-16	0.252	ppb
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-SEP-16	0.260	ppb
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-SEP-16	0.243	ppb
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-SEP-16	0.472	ppb
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Initial	20-SEP-16	0.512	ppb
51074	51074-2-N-HAL-F06	Across from Room 209, Right Fountain	Initial	20-NOV-19	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-SEP-16	1.000	ppb
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-SEP-16	1.000	ppb
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-SEP-16	0.199	ppb
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-SEP-16	1.000	ppb
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-W-KIT-KS01	Kitchen Sink	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-W-KIT-KS01	Kitchen Sink	Initial	20-SEP-16	0.177	ppb
51074	51074-1-W-KIT-KS01	Kitchen Sink	Initial	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-SEP-16	0.648	ppb
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-SEP-16	0.550	ppb
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-SEP-16	0.582	ppb
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-SEP-16	0.544	ppb
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Initial	20-SEP-16	0.660	ppb
51074	51074-1-S-HAL-WC09	Outside Room 109, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-SEP-16	0.948	ppb
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-SEP-16	0.659	ppb
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-SEP-16	0.567	ppb
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-SEP-16	0.643	ppb
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-NOV-19	1.060	ug/L
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-NOV-19	1.120	ug/L
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Flush180	20-NOV-19	1.130	ug/L
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Initial	20-SEP-16	0.506	ppb
51074	51074-1-S-HAL-WC08	Outside Room 109, Right Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-SEP-16	2.270	ppb
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-SEP-16	2.190	ppb
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-SEP-16	1.460	ppb
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-SEP-16	1.900	ppb
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-NOV-19	1.400	ug/L
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-NOV-19	2.710	ug/L
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Flush180	20-NOV-19	2.120	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-WC02					
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Initial	20-SEP-16	1.660	ppb
51074	51074-2-W-HAL-WC02	Outside Room 201, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-SEP-16	1.030	ppb
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-SEP-16	0.963	ppb
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-SEP-16	1.890	ppb
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-SEP-16	2.920	ppb
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-NOV-19	2.050	ug/L
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Flush180	20-NOV-19	3.480	ug/L
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Initial	20-SEP-16	1.120	ppb
51074	51074-2-W-HAL-WC01	Outside Room 201, Right Fountain	Initial	20-NOV-19	2.060	ug/L
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-SEP-16	1.640	ppb
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-SEP-16	3.810	ppb
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-SEP-16	1.030	ppb
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-SEP-16	1.620	ppb
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Initial	20-SEP-16	7.500	ppb
51074	51074-2-E-HAL-F03	Outside Room 206, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-SEP-16	3.710	ppb
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-SEP-16	2.610	ppb
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-SEP-16	3.720	ppb
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-SEP-16	3.500	ppb
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-NOV-19	1.470	ug/L
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-NOV-19	1.180	ug/L
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Initial	20-SEP-16	12.900	ppb
51074	51074-2-E-HAL-F04	Outside Room 206, Right Fountain	Initial	20-NOV-19	1.140	ug/L
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-SEP-16	0.969	ppb
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-SEP-16	0.802	ppb
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-SEP-16	1.260	ppb
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-SEP-16	1.150	ppb
51074	51074-2-S-	Outside Room 209, Left Fountain	Flush180	20-NOV-19	2.500	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F08					
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-NOV-19	2.450	ug/L
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-NOV-19	2.360	ug/L
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Flush180	20-NOV-19	2.050	ug/L
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Initial	20-SEP-16	1.250	ppb
51074	51074-2-S-HAL-F08	Outside Room 209, Left Fountain	Initial	20-NOV-19	2.080	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-SEP-16	1.220	ppb
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-SEP-16	1.110	ppb
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-SEP-16	1.230	ppb
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-SEP-16	1.250	ppb
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-NOV-19	2.270	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-NOV-19	2.680	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-NOV-19	2.510	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	20-NOV-19	2.390	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	30-DEC-20	12.400	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	30-DEC-20	6.280	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	30-DEC-20	7.410	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	30-DEC-20	4.990	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	05-MAR-21	1.650	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	05-MAR-21	1.010	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	05-MAR-21	1.120	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	05-MAR-21	1.170	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	17-FEB-21	7.430	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	17-FEB-21	5.510	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	17-FEB-21	3.690	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	17-FEB-21	4.030	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	11-DEC-20	11.400	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	11-DEC-20	21.700	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	11-DEC-20	27.900	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	11-DEC-20	18.600	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	21-AUG-20	87.300	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	09-OCT-20	4.290	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	09-OCT-20	5.120	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	09-OCT-20	9.760	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Flush180	09-OCT-20	9.460	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	20-SEP-16	1.250	ppb
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	20-NOV-19	2.150	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	30-DEC-20	26.500	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	05-MAR-21	3.040	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	17-FEB-21	15.600	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	11-DEC-20	24.600	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	21-AUG-20	29.300	ug/L
51074	51074-2-S-HAL-F07	Outside Room 209, Right Fountain	Initial	09-OCT-20	6.050	ug/L
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-SEP-16	8.640	ppb
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-SEP-16	7.610	ppb
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-SEP-16	10.300	ppb
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-SEP-16	10.300	ppb
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-NOV-19	1.110	ug/L
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-NOV-19	1.280	ug/L
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Flush180	20-NOV-19	1.370	ug/L
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Initial	20-SEP-16	13.200	ppb
51074	51074-3-W-HAL-WC02	Outside Room 301, Left Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-SEP-16	4.640	ppb
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-SEP-16	3.850	ppb
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-SEP-16	7.100	ppb
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-SEP-16	5.470	ppb
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-NOV-19	1.420	ug/L
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-NOV-19	2.880	ug/L
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Initial	20-SEP-16	13.100	ppb
51074	51074-3-W-HAL-WC01	Outside Room 301, Right Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-SEP-16	1.150	ppb
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-SEP-16	2.080	ppb
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-SEP-16	1.450	ppb
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-SEP-16	2.010	ppb
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Initial	20-SEP-16	2.530	ppb
51074	51074-3-E-HAL-F03	Outside Room 306, Left Fountain	Initial	20-NOV-19	1.260	ug/L
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-SEP-16	1.650	ppb
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-SEP-16	1.910	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-SEP-16	1.150	ppb
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-SEP-16	2.040	ppb
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Flush180	20-NOV-19	1.000	ug/L
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Initial	20-SEP-16	2.590	ppb
51074	51074-3-E-HAL-F04	Outside Room 306, Right Fountain	Initial	20-NOV-19	1.000	ug/L
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	20-SEP-16	63.000	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	21-OCT-16	1.000	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	21-OCT-16	1.000	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	21-OCT-16	1.000	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	21-OCT-16	1.000	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	20-SEP-16	7.270	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	20-SEP-16	13.500	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Flush180	20-SEP-16	10.200	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Initial	21-OCT-16	1.000	ppb
51074	51074-3-HAL-F06	Outside Room 309, Fountain	Initial	20-SEP-16	64.600	ppb
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	13-JUN-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	13-JUN-23	6.110	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	13-JUN-23	2.050	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	13-JUN-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	16-AUG-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	16-AUG-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	16-AUG-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Flush180	16-AUG-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Initial	13-JUN-23	1.000	ug/L
51074	51074-1-PG-F01	Water Fountain on Playground	Initial	16-AUG-23	1.000	ug/L