



Sep 10, 2024

SUMNER

715 S KILDARE AVE, Chicago IL 60624.

Dear **SUMNER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

SUMNER

715 S KILDARE AVE, Chicago IL 60624.

Estimadas familias de **SUMNER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	16-FEB-23	1.850	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	16-FEB-23	2.440	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	16-FEB-23	2.320	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	16-FEB-23	1.210	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	15-SEP-16	1.900	ppb
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	15-SEP-16	1.800	ppb
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	15-SEP-16	2.200	ppb
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	15-SEP-16	1.800	ppb
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Initial	16-FEB-23	1.840	ug/L
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Initial	15-SEP-16	4.300	ppb
51190	51190-1-E-HAL-F10	Across from 024, right fountain	Initial	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	16-FEB-23	1.590	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	12-JUN-19	1.730	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	12-JUN-19	1.130	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Initial	16-FEB-23	1.050	ug/L
51190	51190-1-E-HAL-F08	Across from room 024, left fountain	Initial	12-JUN-19	1.000	ug/L
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	15-SEP-16	3.300	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	15-SEP-16	7.700	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	15-SEP-16	5.500	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	15-SEP-16	4.800	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	12-JUN-19	6.140	ug/L
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	12-JUN-19	7.200	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	12-JUN-19	9.650	ug/L
51190	51190-3-W-HAL-F03	Acrss RM 335	Flush180	12-JUN-19	4.570	ug/L
51190	51190-3-W-HAL-F03	Acrss RM 335	Initial	15-SEP-16	21.000	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Initial	27-OCT-16	1.000	ppb
51190	51190-3-W-HAL-F03	Acrss RM 335	Initial	12-JUN-19	12.000	ug/L
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	15-SEP-16	9.800	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	15-SEP-16	5.700	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	15-SEP-16	6.400	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	15-SEP-16	15.000	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	15-SEP-16	10.000	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	15-SEP-16	7.000	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	15-SEP-16	22.000	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	27-OCT-16	6.510	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	27-OCT-16	5.800	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Flush180	15-SEP-16	7.900	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Initial	15-SEP-16	28.000	ppb
51190	51190-B-HAL-F02	Hall outside Boys Bathroom	Initial	27-OCT-16	6.380	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Initial	15-SEP-16	13.000	ppb
51190	51190-B-HAL-F01	Hall outside Boys Bathroom	Initial	27-OCT-16	6.690	ppb
51190	51190-1-S-HAL-F06	Hallway near 020, second fountain left faucet	Flush180	12-JUN-19	53.900	ug/L
51190	51190-1-S-HAL-F06	Hallway near 020, second fountain left faucet	Flush180	12-JUN-19	41.300	ug/L
51190	51190-1-S-HAL-F06	Hallway near 020, second fountain left faucet	Flush180	12-JUN-19	13.700	ug/L
51190	51190-1-S-HAL-F06	Hallway near 020, second fountain left faucet	Flush180	12-JUN-19	11.700	ug/L
51190	51190-1-S-HAL-F06	Hallway near 020, second fountain left faucet	Initial	12-JUN-19	71.400	ug/L
51190	51190-1-S-HAL-F04	In stairwell by room 020 left	Flush180	12-JUN-19	34.800	ug/L
51190	51190-1-S-HAL-F04	In stairwell by room 020 left	Flush180	12-JUN-19	11.100	ug/L
51190	51190-1-S-HAL-F04	In stairwell by room 020 left	Flush180	12-JUN-19	9.680	ug/L
51190	51190-1-S-HAL-F04	In stairwell by room 020 left	Flush180	12-JUN-19	11.900	ug/L
51190	51190-1-S-HAL-F04	In stairwell by room 020 left	Initial	12-JUN-19	10.900	ug/L
51190	51190-1-S-HAL-F05	In stairwell near 020, first fountain, right faucet	Flush180	12-JUN-19	94.100	ug/L
51190	51190-1-S-HAL-F05	In stairwell near 020, first fountain, right faucet	Flush180	12-JUN-19	36.300	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51190	51190-1-S-HAL-F05	In stairwell near 020, first fountain, right faucet	Flush180	12-JUN-19	55.200	ug/L
51190	51190-1-S-HAL-F05	In stairwell near 020, first fountain, right faucet	Flush180	12-JUN-19	122.000	ug/L
51190	51190-1-S-HAL-F05	In stairwell near 020, first fountain, right faucet	Initial	12-JUN-19	29.000	ug/L
51190	51190-1-020-F01	Inside Room 020, Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-020-F01	Inside Room 020, Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-020-F01	Inside Room 020, Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-020-F01	Inside Room 020, Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-020-F01	Inside Room 020, Fountain	Initial	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	15-SEP-16	0.650	ppb
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	15-SEP-16	0.980	ppb
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	15-SEP-16	0.550	ppb
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	15-SEP-16	0.650	ppb
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	12-JUN-19	1.210	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	12-JUN-19	1.250	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	12-JUN-19	1.020	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	12-JUN-19	1.290	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	30-APR-20	2.170	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	30-APR-20	2.360	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	30-APR-20	2.460	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	30-APR-20	5.550	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Flush180	19-AUG-20	1.000	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Initial	16-FEB-23	2.160	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Initial	15-SEP-16	0.920	ppb
51190	51190-1-S-KIT-KS01	Left sink South Wall	Initial	12-JUN-19	7.990	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Initial	30-APR-20	7.030	ug/L
51190	51190-1-S-KIT-KS01	Left sink South Wall	Initial	19-AUG-20	1.000	ug/L
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	15-SEP-16	1.800	ppb
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	15-SEP-16	1.800	ppb
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	15-SEP-16	1.300	ppb
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	15-SEP-16	0.700	ppb
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Flush180	12-JUN-19	1.000	ug/L
51190	51190-1-E-	Middle Fountain across from 024	Flush180	12-JUN-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F09					
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Initial	15-SEP-16	2.900	ppb
51190	51190-1-E-HAL-F09	Middle Fountain across from 024	Initial	12-JUN-19	1.000	ug/L
51190	51190-1-E-HAL-RBF01	Middle Fountain across from 024	Flush180	16-FEB-23	3.280	ug/L
51190	51190-1-E-HAL-RBF01	Middle Fountain across from 024	Flush180	16-FEB-23	1.970	ug/L
51190	51190-1-E-HAL-RBF01	Middle Fountain across from 024	Flush180	16-FEB-23	2.000	ug/L
51190	51190-1-E-HAL-RBF01	Middle Fountain across from 024	Flush180	16-FEB-23	2.710	ug/L
51190	51190-1-E-HAL-RBF01	Middle Fountain across from 024	Initial	16-FEB-23	1.140	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	15-SEP-16	0.520	ppb
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	15-SEP-16	0.320	ppb
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	15-SEP-16	0.560	ppb
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	15-SEP-16	0.370	ppb
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	12-JUN-19	16.600	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	12-JUN-19	3.860	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	12-JUN-19	1.890	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	12-JUN-19	1.080	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	30-APR-20	3.600	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	30-APR-20	3.040	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	30-APR-20	2.710	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Flush180	30-APR-20	2.430	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Initial	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Initial	15-SEP-16	1.200	ppb
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Initial	12-JUN-19	3.180	ug/L
51190	51190-1-S-KIT-KS02	Middle Sink South Wall	Initial	30-APR-20	3.510	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	16-FEB-23	4.580	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	16-FEB-23	3.980	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	16-FEB-23	3.020	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	16-FEB-23	2.120	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	15-SEP-16	42.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	15-SEP-16	54.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	15-SEP-16	32.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	15-SEP-16	48.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-	Near Girls Bathroom by lunchroom	Flush180	27-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F01	2, left				
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	12-JUN-19	23.900	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	12-JUN-19	42.300	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	12-JUN-19	50.500	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	12-JUN-19	19.300	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	30-APR-20	1.600	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	30-APR-20	6.940	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	30-APR-20	3.940	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Flush180	30-APR-20	1.370	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Initial	16-FEB-23	3.800	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Initial	15-SEP-16	40.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Initial	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Initial	12-JUN-19	63.600	ug/L
51190	51190-1-W-HAL-F01	Near Girls Bathroom by lunchroom 2, left	Initial	30-APR-20	2.390	ug/L
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	15-SEP-16	16.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	15-SEP-16	12.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	15-SEP-16	31.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	15-SEP-16	29.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	12-JUN-19	7.400	ug/L
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	12-JUN-19	2.010	ug/L
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	12-JUN-19	3.200	ug/L
51190	51190-1-W-HAL-F03	Outside RM 132 right	Flush180	12-JUN-19	2.880	ug/L
51190	51190-1-W-HAL-F03	Outside RM 132 right	Initial	15-SEP-16	11.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Initial	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F03	Outside RM 132 right	Initial	12-JUN-19	3.140	ug/L
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	27-OCT-16	5.310	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	15-SEP-16	11.000	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	15-SEP-16	10.000	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	15-SEP-16	13.000	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	15-SEP-16	12.000	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	27-OCT-16	10.800	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	27-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Flush180	27-OCT-16	8.100	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Initial	27-OCT-16	17.300	ppb
51190	51190-3-HAL-F01	Outside RM 225 Left Fountain	Initial	15-SEP-16	31.000	ppb
51190	51190-3-HALL-F02	Outside RM 225 Right Fountain	Flush180	15-SEP-16	7.600	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	15-SEP-16	10.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	15-SEP-16	25.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	15-SEP-16	15.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Initial	15-SEP-16	31.000	ppb
51190	51190-3-HAL-F02	Outside RM 225 Right Fountain	Initial	27-OCT-16	12.300	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	15-SEP-16	11.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	27-OCT-16	1.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	15-SEP-16	19.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	15-SEP-16	14.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Flush180	15-SEP-16	28.000	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Initial	27-OCT-16	6.010	ppb
51190	51190-2-HAL-F05	Outside RM 234 Left Fountain	Initial	15-SEP-16	26.000	ppb
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	15-SEP-16	0.560	ppb
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	15-SEP-16	0.870	ppb
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	15-SEP-16	0.990	ppb
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	15-SEP-16	0.550	ppb
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Initial	16-FEB-23	1.000	ug/L
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Initial	15-SEP-16	0.430	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51190	51190-2-W-HAL-F01	Outside Rm 123 Left Fountain	Initial	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	15-SEP-16	0.460	ppb
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	15-SEP-16	0.380	ppb
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	15-SEP-16	0.330	ppb
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	15-SEP-16	0.350	ppb
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Flush180	19-AUG-20	1.070	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Initial	15-SEP-16	0.850	ppb
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Initial	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F02	Outside Rm 123 Middle Fountain	Initial	19-AUG-20	1.000	ug/L
51190	51190-2-E-HAL-RBF01	Outside Rm 123 Middle Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-RBF01	Outside Rm 123 Middle Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-RBF01	Outside Rm 123 Middle Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-RBF01	Outside Rm 123 Middle Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-RBF01	Outside Rm 123 Middle Fountain	Initial	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	15-SEP-16	0.310	ppb
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	15-SEP-16	0.440	ppb
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	15-SEP-16	0.530	ppb
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	15-SEP-16	0.360	ppb
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Flush180	12-JUN-19	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Initial	16-FEB-23	1.000	ug/L
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Initial	15-SEP-16	1.300	ppb
51190	51190-2-E-HAL-F03	Outside Rm 123 Right Fountain	Initial	12-JUN-19	1.000	ug/L
51190	51190-2-W-HAL-F04	Outside Rm 234 Right Fountain	Flush180	12-JUN-19	2.470	ug/L
51190	51190-2-W-HAL-F04	Outside Rm 234 Right Fountain	Flush180	12-JUN-19	5.430	ug/L
51190	51190-2-W-HAL-F04	Outside Rm 234 Right Fountain	Flush180	12-JUN-19	7.220	ug/L
51190	51190-2-W-HAL-F04	Outside Rm 234 Right Fountain	Flush180	12-JUN-19	2.750	ug/L
51190	51190-2-W-	Outside Rm 234 Right Fountain	Initial	12-JUN-19	9.730	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04					
51190	51190-1-HAL-F03	Right Sink East Wall across 024	Flush180	15-SEP-16	0.330	ppb
51190	51190-1-HAL-F03	Right Sink East Wall across 024	Flush180	15-SEP-16	0.300	ppb
51190	51190-1-HAL-F03	Right Sink East Wall across 024	Flush180	15-SEP-16	0.250	ppb
51190	51190-1-HAL-F03	Right Sink East Wall across 024	Flush180	15-SEP-16	0.200	ppb
51190	51190-1-HAL-F03	Right Sink East Wall across 024	Initial	15-SEP-16	0.560	ppb
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	16-FEB-23	1.000	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	15-SEP-16	1.400	ppb
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	15-SEP-16	0.780	ppb
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	15-SEP-16	0.860	ppb
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	15-SEP-16	0.740	ppb
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	12-JUN-19	3.520	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	12-JUN-19	1.410	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	12-JUN-19	1.370	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	12-JUN-19	1.130	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	30-APR-20	2.720	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	30-APR-20	2.570	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	30-APR-20	2.510	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Flush180	30-APR-20	2.380	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Initial	16-FEB-23	1.420	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Initial	15-SEP-16	1.500	ppb
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Initial	12-JUN-19	13.700	ug/L
51190	51190-1-S-KIT-KS03	Right Sink South Wall	Initial	30-APR-20	4.170	ug/L
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	15-SEP-16	17.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	15-SEP-16	21.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	15-SEP-16	19.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Flush180	15-SEP-16	19.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Initial	27-OCT-16	1.000	ppb
51190	51190-1-HAL-F06	Vestibule Stairway near Girls Bathroom	Initial	15-SEP-16	50.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	16-FEB-23	1.330	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	16-FEB-23	1.480	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	16-FEB-23	1.790	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	16-FEB-23	2.150	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	15-SEP-16	26.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	15-SEP-16	28.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	15-SEP-16	30.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	15-SEP-16	22.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	12-JUN-19	89.300	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	12-JUN-19	5.710	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	12-JUN-19	3.230	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	12-JUN-19	2.610	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	30-APR-20	1.000	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	30-APR-20	1.000	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	30-APR-20	1.000	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Flush180	30-APR-20	1.000	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Initial	16-FEB-23	1.640	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Initial	15-SEP-16	52.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Initial	27-OCT-16	1.000	ppb
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Initial	12-JUN-19	30.500	ug/L
51190	51190-1-W-HAL-F02	Vestibule Stairway near Girls Bathroom by lunch room 2 , RIGHT	Initial	30-APR-20	1.030	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	16-FEB-23	1.410	ug/L
52577	52577-1-S-	Girls Locker Room	Flush180	16-FEB-23	1.380	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	GL-F01					
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	16-FEB-23	1.160	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	15-SEP-16	3.400	ppb
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	15-SEP-16	3.200	ppb
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	15-SEP-16	3.400	ppb
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	15-SEP-16	4.300	ppb
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	12-JUN-19	3.650	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	12-JUN-19	4.980	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	12-JUN-19	3.720	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	12-JUN-19	5.100	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	30-APR-20	3.010	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	30-APR-20	1.340	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	30-APR-20	1.640	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Flush180	30-APR-20	2.150	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Initial	16-FEB-23	1.450	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Initial	15-SEP-16	5.400	ppb
52577	52577-1-S-GL-F01	Girls Locker Room	Initial	12-JUN-19	6.430	ug/L
52577	52577-1-S-GL-F01	Girls Locker Room	Initial	30-APR-20	5.910	ug/L
52577	52577-1-HAL-F01	Hallway Outside Boys Locker room left	Flush180	15-SEP-16	1.500	ppb
52577	52577-1-HAL-F01	Hallway Outside Boys Locker room left	Flush180	15-SEP-16	1.700	ppb
52577	52577-1-HAL-F01	Hallway Outside Boys Locker room left	Flush180	15-SEP-16	1.800	ppb
52577	52577-1-HAL-F01	Hallway Outside Boys Locker room left	Flush180	15-SEP-16	1.900	ppb
52577	52577-1-HAL-F01	Hallway Outside Boys Locker room left	Initial	15-SEP-16	2.600	ppb
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	15-SEP-16	1.800	ppb
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	15-SEP-16	2.100	ppb
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	15-SEP-16	2.200	ppb
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	15-SEP-16	2.100	ppb
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	12-JUN-19	1.260	ug/L
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Initial	15-SEP-16	1.900	ppb
52577	52577-1-N-HAL-F02	Hallway Outside Boys Locker room right	Initial	12-JUN-19	1.000	ug/L
52577	52577-1-HAL-F04	Hallway Outside Girls Locker room left unable to test water low pressure	Flush180	15-SEP-16	2.300	ppb
52577	52577-1-HAL-F04	Hallway Outside Girls Locker room left unable to test water low pressure	Flush180	15-SEP-16	3.300	ppb
52577	52577-1-HAL-	Hallway Outside Girls Locker room	Flush180	15-SEP-16	3.300	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	left unable to test water low pressure				
52577	52577-1-HAL-F04	Hallway Outside Girls Locker room left unable to test water low pressure	Flush180	15-SEP-16	2.200	ppb
52577	52577-1-HAL-F04	Hallway Outside Girls Locker room left unable to test water low pressure	Initial	15-SEP-16	8.800	ppb
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	15-SEP-16	1.300	ppb
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	15-SEP-16	1.300	ppb
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	15-SEP-16	1.300	ppb
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	15-SEP-16	1.700	ppb
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	12-JUN-19	1.730	ug/L
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Initial	15-SEP-16	2.200	ppb
52577	52577-1-N-HAL-F05	Hallway Outside Girls Locker room, across from 111, RIGHT	Initial	12-JUN-19	1.330	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	15-SEP-16	0.250	ppb
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	15-SEP-16	0.300	ppb
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	15-SEP-16	0.310	ppb
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	15-SEP-16	0.150	ppb
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Initial	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Initial	15-SEP-16	0.440	ppb
52577	52577-1-W-KIT-KS02	Kitchen Middle Sink on West Wall	Initial	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	15-SEP-16	0.120	ppb
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	15-SEP-16	0.660	ppb
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	15-SEP-16	0.180	ppb
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	15-SEP-16	0.140	ppb
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	12-JUN-19	2.030	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KIT-KS03					
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	12-JUN-19	1.010	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	12-JUN-19	1.400	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Flush180	12-JUN-19	1.010	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Initial	16-FEB-23	1.130	ug/L
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Initial	15-SEP-16	2.200	ppb
52577	52577-1-W-KIT-KS03	Kitchen North Sink on West Wall	Initial	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	15-SEP-16	0.780	ppb
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	15-SEP-16	0.740	ppb
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	15-SEP-16	0.860	ppb
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	15-SEP-16	0.990	ppb
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	12-JUN-19	2.550	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	12-JUN-19	1.610	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Flush180	19-AUG-20	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Initial	16-FEB-23	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Initial	15-SEP-16	2.200	ppb
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Initial	12-JUN-19	1.000	ug/L
52577	52577-1-W-KIT-KS01	Kitchen South Sink on West Wall	Initial	19-AUG-20	1.860	ug/L
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	15-SEP-16	0.430	ppb
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	15-SEP-16	0.160	ppb
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	15-SEP-16	0.140	ppb
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	15-SEP-16	0.290	ppb
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	12-JUN-19	1.820	ug/L
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Initial	15-SEP-16	0.780	ppb
52577	52577-1-N-HAL-F07	Outside RM 102 left DF	Initial	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	15-SEP-16	0.160	ppb
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	15-SEP-16	0.100	ppb
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	15-SEP-16	0.160	ppb
52577	52577-1-N-	Outside RM 102 right DF	Flush180	15-SEP-16	0.170	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F08					
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Flush180	19-AUG-20	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Initial	15-SEP-16	0.590	ppb
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Initial	12-JUN-19	1.000	ug/L
52577	52577-1-N-HAL-F08	Outside RM 102 right DF	Initial	19-AUG-20	1.000	ug/L
52577	52577-1-N-HAL-RBF01	Outside RM 102, Retrofit Bottle Filler, Right	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-N-HAL-RBF01	Outside RM 102, Retrofit Bottle Filler, Right	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-N-HAL-RBF01	Outside RM 102, Retrofit Bottle Filler, Right	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-N-HAL-RBF01	Outside RM 102, Retrofit Bottle Filler, Right	Flush180	16-FEB-23	1.000	ug/L
52577	52577-1-N-HAL-RBF01	Outside RM 102, Retrofit Bottle Filler, Right	Initial	16-FEB-23	1.000	ug/L
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	15-SEP-16	0.160	ppb
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	15-SEP-16	0.580	ppb
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	15-SEP-16	0.150	ppb
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	15-SEP-16	0.220	ppb
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Initial	15-SEP-16	0.730	ppb
52577	52577-2-N-HAL-F01	Outside RM 202 Left Fountain	Initial	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	15-SEP-16	0.320	ppb
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	15-SEP-16	0.280	ppb
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	15-SEP-16	0.230	ppb
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	15-SEP-16	0.260	ppb
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Flush180	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Initial	15-SEP-16	1.300	ppb
52577	52577-2-N-HAL-F02	Outside RM 202 Right Fountain	Initial	12-JUN-19	1.000	ug/L
52577	52577-2-N-HAL-RBF01	Outside RM 202, Retrofit Bottle Filler, Left	Flush180	16-FEB-23	1.000	ug/L
52577	52577-2-N-HAL-RBF01	Outside RM 202, Retrofit Bottle Filler, Left	Flush180	16-FEB-23	1.000	ug/L
52577	52577-2-N-HAL-RBF01	Outside RM 202, Retrofit Bottle Filler, Left	Flush180	16-FEB-23	1.000	ug/L
52577	52577-2-N-HAL-RBF01	Outside RM 202, Retrofit Bottle Filler, Left	Flush180	16-FEB-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52577	52577-2-N-HAL-RBF01	Outside RM 202, Retrofit Bottle Filler, Left	Initial	16-FEB-23	1.000	ug/L