



Sep 10, 2024

TAFT HS

6530 W BRYN MAWR AVE, Chicago IL 60631.

Dear **TAFT HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

TAFT HS

6530 W BRYN MAWR AVE, Chicago IL 60631.

Estimadas familias de **TAFT HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS01	2 basin Sink, Left	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS01	2 basin Sink, Left	Initial	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS01	2 basin Sink, Left	Initial	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS02	2 basin Sink, Right	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-KIT-KS02	2 basin Sink, Right	Initial	04-OCT-16	1.000	ppb
51540	51540-2-KIT-KS02	2 basin Sink, Right	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS03	Across From Refrigerator 1	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS03	Across From Refrigerator 1	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS03	Across From Refrigerator 1	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS03	Across From Refrigerator 1	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS03	Across From Refrigerator 1	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF01	Across from 264	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF01	Across from 264	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF01	Across from 264	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF01	Across from 264	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF01	Across from 264	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS04	Across from ovens	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS04	Across from ovens	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-KS04	Across from ovens	Flush180	19-APR-23	1.020	ug/L
51540	51540-2-HAL-KS04	Across from ovens	Flush180	19-APR-23	1.040	ug/L
51540	51540-2-HAL-KS04	Across from ovens	Initial	19-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	19-APR-23	1.300	ug/L
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	19-APR-23	1.460	ug/L
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	19-APR-23	1.710	ug/L
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Flush180	19-APR-23	1.440	ug/L
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Initial	04-OCT-16	1.000	ppb
51540	51540-1-AH-F01	Assembly Hall near men's bathroom	Initial	19-APR-23	2.650	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-MAY-23	1.220	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-MAY-23	1.410	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-MAY-23	2.740	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-MAY-23	1.820	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-APR-23	9.110	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-APR-23	4.650	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-APR-23	2.800	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Flush180	19-APR-23	2.560	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Initial	19-MAY-23	4.320	ug/L
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Initial	04-OCT-16	1.000	ppb
51540	51540-1-AH-F02	Assembly Hall near women's bathroom	Initial	19-APR-23	4.940	ug/L
51540	51540-2-KIT-F01	Fountain in Kitchen	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-F01	Fountain in Kitchen	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-F01	Fountain in Kitchen	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-F01	Fountain in Kitchen	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-KIT-F01	Fountain in Kitchen	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	19-APR-23	1.470	ug/L
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	19-APR-23	1.320	ug/L
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	19-APR-23	1.280	ug/L
51540	51540-3-HAL-F09	Hall Outside 310	Flush180	19-APR-23	1.260	ug/L
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F10	Hall Outside 310	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F09	Hall Outside 310	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F10	Hall Outside 310	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F09	Hall Outside 310	Initial	19-APR-23	2.010	ug/L
51540	51540-3-HAL-F10	Hall Outside 310	Initial	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	19-APR-23	1.330	ug/L
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	19-APR-23	1.430	ug/L
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	19-APR-23	1.270	ug/L
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	19-APR-23	1.090	ug/L
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F08	Hall Outside 312	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	19-APR-23	1.110	ug/L
51540	51540-3-HAL-F07	Hall Outside 312	Flush180	19-APR-23	1.150	ug/L
51540	51540-3-HAL-F07	Hall Outside 312	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F08	Hall Outside 312	Initial	04-OCT-16	5.220	ppb
51540	51540-3-HAL-F08	Hall Outside 312	Initial	19-APR-23	1.780	ug/L
51540	51540-3-HAL-F07	Hall Outside 312	Initial	19-APR-23	1.750	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	19-APR-23	4.650	ug/L
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	19-APR-23	3.490	ug/L
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	19-APR-23	3.310	ug/L
51540	51540-3-HAL-F03	Hall Outside 319	Flush180	19-APR-23	3.450	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	19-APR-23	3.090	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	19-APR-23	2.680	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	19-APR-23	2.660	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Flush180	19-APR-23	2.610	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F03	Hall Outside 319	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F03	Hall Outside 319	Initial	19-APR-23	3.180	ug/L
51540	51540-3-HAL-F04	Hall Outside 319	Initial	19-APR-23	2.770	ug/L
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	19-APR-23	1.860	ug/L
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	19-APR-23	1.790	ug/L
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	19-APR-23	1.330	ug/L
51540	51540-2-HAL-F11	Hall Outside RM 210	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F12	Hall Outside RM 210	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F11	Hall Outside RM 210	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F12	Hall Outside RM 210	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F11	Hall Outside RM 210	Initial	19-APR-23	1.990	ug/L
51540	51540-2-HAL-F12	Hall Outside RM 210	Initial	19-APR-23	2.220	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F10					
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F09	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F09	Hall Outside RM 212	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F09	Hall Outside RM 212	Initial	19-APR-23	1.040	ug/L
51540	51540-2-HAL-F10	Hall Outside RM 212	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F07	Hall Outside RM 216	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	19-APR-23	1.490	ug/L
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	19-APR-23	1.250	ug/L
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	19-APR-23	1.830	ug/L
51540	51540-2-HAL-F08	Hall Outside RM 216	Flush180	19-APR-23	1.180	ug/L
51540	51540-2-HAL-F08	Hall Outside RM 216	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F07	Hall Outside RM 216	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F07	Hall Outside RM 216	Initial	19-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-2-HAL-F08	Hall Outside RM 216	Initial	19-APR-23	2.510	ug/L
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.130	ug/L
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F05	Hall Outside RM 219/Gym	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F06	Hall Outside RM 219/Gym	Initial	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F05	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F05	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F05	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F05	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	19-APR-23	3.230	ug/L
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	19-APR-23	2.460	ug/L
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	19-APR-23	2.680	ug/L
51540	51540-3-HAL-F06	Hall Outside RM 316	Flush180	19-APR-23	3.070	ug/L
51540	51540-3-HAL-F05	Hall Outside RM 316	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F06	Hall Outside RM 316	Initial	19-APR-23	1.930	ug/L
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F01	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F02	Hall outside RM 330	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F01	Hall outside RM 330	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F02	Hall outside RM 330	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F01	Hall outside RM 330	Initial	19-APR-23	1.060	ug/L
51540	51540-3-HAL-F02	Hall outside RM 330	Initial	19-APR-23	1.030	ug/L
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F04	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F04	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F04	Hallway Outside RM 232	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F03	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F03	Hallway Outside RM 232	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F04	Hallway Outside RM 232	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F03	Hallway Outside RM 232	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF02	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF02	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-RBF02	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-	Hallway Outside RM 232	Flush180	19-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	RBF02					
51540	51540-2-HAL-RBF02	Hallway Outside RM 232	Initial	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F06	Near 112	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F06	Near 112	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F06	Near 112	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F06	Near 112	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F06	Near 112	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F06	Near 112	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F06	Near 112	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F06	Near 112	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F06	Near 112	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F06	Near 112	Initial	19-APR-23	1.320	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-MAY-23	1.000	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-MAY-23	1.000	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-MAY-23	2.010	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-MAY-23	2.360	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F07	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F07	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F07	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F07	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F08	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F08	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F08	Near 116	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F08	Near 116	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F08	Near 116	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F08	Near 116	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F08	Near 116	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-APR-23	4.960	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-APR-23	3.990	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-APR-23	3.370	ug/L
51540	51540-1-HAL-F07	Near 116	Flush180	19-APR-23	3.870	ug/L
51540	51540-1-HAL-F07	Near 116	Initial	19-MAY-23	1.000	ug/L
51540	51540-1-HAL-F07	Near 116	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F08	Near 116	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F08	Near 116	Initial	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F07	Near 116	Initial	19-APR-23	26.200	ug/L
51540	51540-1-HAL-	Near Door 11	Flush180	04-OCT-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51540	51540-1-HAL-F01	Near Door 11	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F01	Near Door 11	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F01	Near Door 11	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F01	Near Door 11	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F01	Near Door 11	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F01	Near Door 11	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F01	Near Door 11	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F01	Near Door 11	Initial	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F03	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F02	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F02	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F02	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F02	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F03	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F03	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F03	Near RM 104	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F02	Near RM 104	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F02	Near RM 104	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F03	Near RM 104	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F03	Near RM 104	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F03	Near RM 104	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F02	Near RM 104	Flush180	19-APR-23	1.180	ug/L
51540	51540-1-HAL-F02	Near RM 104	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F02	Near RM 104	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F03	Near RM 104	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F03	Near RM 104	Initial	19-APR-23	1.250	ug/L
51540	51540-1-HAL-F02	Near RM 104	Initial	19-APR-23	2.110	ug/L
51540	51540-1-HAL-F04	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F04	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F04	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F04	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F05	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F05	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F05	Near RM 106	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F05	Near RM 106	Flush180	04-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-1-HAL-F05	Near RM 106	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F05	Near RM 106	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F05	Near RM 106	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F05	Near RM 106	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F04	Near RM 106	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F05	Near RM 106	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F05	Near RM 106	Initial	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F09	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F09	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F09	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F09	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F10	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F10	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F10	Near RM 122	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F09	Near RM 122	Flush180	19-APR-23	1.600	ug/L
51540	51540-1-HAL-F09	Near RM 122	Flush180	19-APR-23	1.920	ug/L
51540	51540-1-HAL-F09	Near RM 122	Flush180	19-APR-23	1.180	ug/L
51540	51540-1-HAL-F09	Near RM 122	Flush180	19-APR-23	1.080	ug/L
51540	51540-1-HAL-F10	Near RM 122	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F10	Near RM 122	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F10	Near RM 122	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F10	Near RM 122	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F09	Near RM 122	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F10	Near RM 122	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F09	Near RM 122	Initial	19-APR-23	2.410	ug/L
51540	51540-1-HAL-F10	Near RM 122	Initial	19-APR-23	1.500	ug/L
51540	51540-1-HAL-F11	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F12	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F12	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F12	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F12	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F11	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F11	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F11	Near RM 134	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F11	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F11	Near RM 134	Flush180	19-APR-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-1-HAL-F11	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F11	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F12	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F12	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F12	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F12	Near RM 134	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-HAL-F12	Near RM 134	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F11	Near RM 134	Initial	04-OCT-16	1.000	ppb
51540	51540-1-HAL-F11	Near RM 134	Initial	19-APR-23	1.820	ug/L
51540	51540-1-HAL-F12	Near RM 134	Initial	19-APR-23	1.190	ug/L
51540	51540-1-164-F01	Near RM 164	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-164-F01	Near RM 164	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-164-F01	Near RM 164	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-164-F01	Near RM 164	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-164-F01	Near RM 164	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-164-F01	Near RM 164	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-164-F01	Near RM 164	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-164-F01	Near RM 164	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-164-F01	Near RM 164	Initial	04-OCT-16	1.000	ppb
51540	51540-1-164-F01	Near RM 164	Initial	19-APR-23	1.000	ug/L
51540	51540-1-171-F01	Near RM 171	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-171-F01	Near RM 171	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-171-F01	Near RM 171	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-171-F01	Near RM 171	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-171-F01	Near RM 171	Flush180	16-DEC-20	1.000	ug/L
51540	51540-1-171-F01	Near RM 171	Initial	04-OCT-16	1.000	ppb
51540	51540-1-171-F01	Near RM 171	Initial	16-DEC-20	1.000	ug/L
51540	51540-1-171-RBF01	Near RM 171	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-171-RBF01	Near RM 171	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-171-RBF01	Near RM 171	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-171-RBF01	Near RM 171	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-171-RBF01	Near RM 171	Initial	19-APR-23	1.000	ug/L
51540	51540-1-185-F01	Near RM 185	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-185-F01	Near RM 185	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-185-F01	Near RM 185	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-185-F01	Near RM 185	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-185-F01	Near RM 185	Flush180	19-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51540	51540-1-185-F01	Near RM 185	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-185-F01	Near RM 185	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-185-F01	Near RM 185	Initial	04-OCT-16	1.000	ppb
51540	51540-1-185-F01	Near RM 185	Initial	19-APR-23	1.070	ug/L
51540	51540-3-HAL-RBF01	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-RBF01	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-RBF01	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-RBF01	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-RBF01	Outside 308	Initial	19-APR-23	1.540	ug/L
51540	51540-2-HAL-F02	Outside Dining RM East Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F02	Outside Dining RM East Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F02	Outside Dining RM East Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F02	Outside Dining RM East Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F02	Outside Dining RM East Side	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F01	Outside Dining RM West Side	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F01	Outside Dining RM West Side	Initial	04-OCT-16	1.000	ppb
51540	51540-2-HAL-F01	Outside Dining RM West Side	Initial	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F13	Outside RM 206	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F13	Outside RM 206	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F13	Outside RM 206	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F13	Outside RM 206	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-HAL-F13	Outside RM 206	Initial	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F12	Outside 308	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F12	Outside 308	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F12	Outside 308	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F12	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F12	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F12	Outside 308	Flush180	19-APR-23	1.000	ug/L
51540	51540-3-HAL-F12	Outside 308	Flush180	19-APR-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F12					
51540	51540-3-HAL-F12	Outsude 308	Initial	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F12	Outsude 308	Initial	19-APR-23	1.920	ug/L
51540	51540-3-HAL-F11	Outsude 309	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F11	Outsude 309	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F11	Outsude 309	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F11	Outsude 309	Flush180	04-OCT-16	1.000	ppb
51540	51540-3-HAL-F11	Outsude 309	Initial	04-OCT-16	1.000	ppb
51540	51540-1-POL-F01	Pool area	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-POL-F01	Pool area	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-POL-F01	Pool area	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-POL-F01	Pool area	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-POL-F01	Pool area	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-POL-F01	Pool area	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-POL-F01	Pool area	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-POL-F01	Pool area	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-POL-F01	Pool area	Initial	04-OCT-16	1.000	ppb
51540	51540-1-POL-F01	Pool area	Initial	19-APR-23	1.000	ug/L
51540	51540-1-166-F01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-F01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-F01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-F01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-S01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-S01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-S01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-S01	RM 166	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-166-F01	RM 166	Flush180	19-APR-23	2.570	ug/L
51540	51540-1-166-F01	RM 166	Flush180	19-APR-23	2.290	ug/L
51540	51540-1-166-F01	RM 166	Flush180	19-APR-23	2.440	ug/L
51540	51540-1-166-F01	RM 166	Flush180	19-APR-23	2.380	ug/L
51540	51540-1-166-S01	RM 166	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-166-S01	RM 166	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-166-S01	RM 166	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-166-S01	RM 166	Flush180	19-APR-23	1.000	ug/L
51540	51540-1-166-F01	RM 166	Initial	04-OCT-16	1.000	ppb
51540	51540-1-166-S01	RM 166	Initial	04-OCT-16	1.000	ppb
51540	51540-1-166-F01	RM 166	Initial	19-APR-23	2.940	ug/L
51540	51540-1-166-S01	RM 166	Initial	19-APR-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51540	51540-1-191-F01	RM 191	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-191-F01	RM 191	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-191-F01	RM 191	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-191-F01	RM 191	Flush180	04-OCT-16	1.000	ppb
51540	51540-1-191-F01	RM 191	Initial	04-OCT-16	1.000	ppb
51540	51540-2-206-S01	Room 206	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-206-S01	Room 206	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-206-S01	Room 206	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-206-S01	Room 206	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-206-S01	Room 206	Initial	04-OCT-16	1.000	ppb
51540	51540-2-215-F01	Student Dining RM 215	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-215-F01	Student Dining RM 215	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-215-F01	Student Dining RM 215	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-215-F01	Student Dining RM 215	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-215-F01	Student Dining RM 215	Flush180	16-DEC-20	1.000	ug/L
51540	51540-2-215-F01	Student Dining RM 215	Flush180	19-APR-23	1.080	ug/L
51540	51540-2-215-F01	Student Dining RM 215	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-215-F01	Student Dining RM 215	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-215-F01	Student Dining RM 215	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-215-F01	Student Dining RM 215	Initial	04-OCT-16	1.000	ppb
51540	51540-2-215-F01	Student Dining RM 215	Initial	16-DEC-20	1.000	ug/L
51540	51540-2-215-F01	Student Dining RM 215	Initial	19-APR-23	1.150	ug/L
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	04-OCT-16	1.000	ppb
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	19-APR-23	1.010	ug/L
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-F01	Teacher's Lounge RM 271	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-F01	Teacher's Lounge RM 271	Initial	04-OCT-16	1.000	ppb
51540	51540-2-271-F01	Teacher's Lounge RM 271	Initial	19-APR-23	2.440	ug/L
51540	51540-2-271-WCD01	Teachers Lounge Water Cooler Dispenser	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-WCD01	Teachers Lounge Water Cooler Dispenser	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-WCD01	Teachers Lounge Water Cooler Dispenser	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-WCD01	Teachers Lounge Water Cooler Dispenser	Flush180	19-APR-23	1.000	ug/L
51540	51540-2-271-WCD01	Teachers Lounge Water Cooler Dispenser	Initial	19-APR-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.460	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.710	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.440	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.060	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Initial	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Initial	28-AUG-19	1.440	ug/L
56204	56204-1-S-CAF-S01	Cafeteria - First Floor Northeast End at Serving Line	Initial	28-AUG-19	6.460	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Initial	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Initial	28-AUG-19	1.000	ug/L
56204	56204-1-S-CAF-S02	Cafeteria - First Floor Southeast end of Serving Line	Initial	28-AUG-19	3.540	ug/L
56204	56204-1-W-HAL-F07	Hallway - First Floor West End	Flush180	10-SEP-19	1.000	ug/L
56204	56204-1-W-HAL-F07	Hallway - First Floor West End	Flush180	10-SEP-19	1.000	ug/L
56204	56204-1-W-HAL-F07	Hallway - First Floor West End	Flush180	10-SEP-19	1.000	ug/L
56204	56204-1-W-HAL-F07	Hallway - First Floor West End	Flush180	10-SEP-19	1.000	ug/L
56204	56204-1-W-HAL-F07	Hallway - First Floor West End	Initial	10-SEP-19	1.000	ug/L
56204	56204-1-N-HAL-F02	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-N-HAL-F02	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-N-	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02					
56204	56204-1-N-HAL-F02	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-N-HAL-F02	Hallway - First Floor at North End	Initial	28-AUG-19	3.830	ug/L
56204	56204-1-N-HAL-F01	Hallway - First Floor at North End	Flush180	28-AUG-19	1.550	ug/L
56204	56204-1-N-HAL-F01	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-N-HAL-F01	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-N-HAL-F01	Hallway - First Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-N-HAL-F01	Hallway - First Floor at North End	Initial	28-AUG-19	3.120	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	28-AUG-19	6.260	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	23-APR-20	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	23-APR-20	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	23-APR-20	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Flush180	23-APR-20	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Initial	28-AUG-19	1.000	ug/L
56204	56204-1-S-HAL-F04	Hallway - First Floor at South End	Initial	23-APR-20	1.000	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	28-AUG-19	2.070	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	28-AUG-19	18.700	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	11-SEP-19	1.000	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	11-SEP-19	1.000	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Flush180	11-SEP-19	1.000	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Initial	28-AUG-19	2.130	ug/L
56204	56204-1-S-HAL-F03	Hallway - First Floor at South End	Initial	11-SEP-19	1.000	ug/L
56204	56204-2-N-HAL-F01	Hallway - Second Floor at North End	Flush180	28-AUG-19	2.070	ug/L
56204	56204-2-N-HAL-F01	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F01	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F01	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F01	Hallway - Second Floor at North End	Initial	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F02	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F02	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F02	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F02	Hallway - Second Floor at North End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-N-HAL-F02	Hallway - Second Floor at North End	Initial	28-AUG-19	1.240	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	End				
56204	56204-2-S-HAL-F04	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.520	ug/L
56204	56204-2-S-HAL-F04	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-S-HAL-F04	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-S-HAL-F04	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-S-HAL-F03	Hallway - Second Floor at South End	Flush180	28-AUG-19	2.500	ug/L
56204	56204-2-S-HAL-F03	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-S-HAL-F03	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-S-HAL-F03	Hallway - Second Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-2-S-HAL-F04	Hallway - Second Floor at South End	Initial	28-AUG-19	2.040	ug/L
56204	56204-2-S-HAL-F03	Hallway - Second Floor at South End	Initial	28-AUG-19	2.730	ug/L
56204	56204-3-S-HAL-F03	Hallway - Third Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-3-S-HAL-F03	Hallway - Third Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-3-S-HAL-F03	Hallway - Third Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-3-S-HAL-F03	Hallway - Third Floor at South End	Flush180	28-AUG-19	1.000	ug/L
56204	56204-3-S-HAL-F03	Hallway - Third Floor at South End	Initial	28-AUG-19	1.500	ug/L
56204	56204-1-S-KIT-SO5	Kitchen - 3 Basin Sink at Left (North)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO5	Kitchen - 3 Basin Sink at Left (North)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO5	Kitchen - 3 Basin Sink at Left (North)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO5	Kitchen - 3 Basin Sink at Left (North)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO5	Kitchen - 3 Basin Sink at Left (North)	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO7	Kitchen - Center	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO7	Kitchen - Center	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO7	Kitchen - Center	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO7	Kitchen - Center	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO7	Kitchen - Center	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO3	Kitchen - Food Prep Area at S. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO3	Kitchen - Food Prep Area at S. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO3	Kitchen - Food Prep Area at S. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO3	Kitchen - Food Prep Area at S. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO3	Kitchen - Food Prep Area at S. End	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-S10	Kitchen - Food Service Area, N. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-S10	Kitchen - Food Service Area, N. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-S10	Kitchen - Food Service Area, N. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-S10	Kitchen - Food Service Area, N. End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-S10	Kitchen - Food Service Area, N. End	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO9	Kitchen - Hand Sink at Northwest End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO9	Kitchen - Hand Sink at Northwest End	Flush180	31-AUG-19	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
56204	56204-1-S-KIT-SO9	Kitchen - Hand Sink at Northwest End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO9	Kitchen - Hand Sink at Northwest End	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO9	Kitchen - Hand Sink at Northwest End	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO8	Kitchen - Prep Sink, North	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO8	Kitchen - Prep Sink, North	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO8	Kitchen - Prep Sink, North	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO8	Kitchen - Prep Sink, North	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO8	Kitchen - Prep Sink, North	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO1	Kitchen - Serving Area	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO1	Kitchen - Serving Area	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO1	Kitchen - Serving Area	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO1	Kitchen - Serving Area	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO1	Kitchen - Serving Area	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO2	Kitchen - Serving Area (near cash register)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO2	Kitchen - Serving Area (near cash register)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO2	Kitchen - Serving Area (near cash register)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO2	Kitchen - Serving Area (near cash register)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO2	Kitchen - Serving Area (near cash register)	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO6	Kitchen - at 3 Basin Sink, Right (South)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO6	Kitchen - at 3 Basin Sink, Right (South)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO6	Kitchen - at 3 Basin Sink, Right (South)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO6	Kitchen - at 3 Basin Sink, Right (South)	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO6	Kitchen - at 3 Basin Sink, Right (South)	Initial	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO4	Kitchen - next to 3 Basin Sink	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO4	Kitchen - next to 3 Basin Sink	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO4	Kitchen - next to 3 Basin Sink	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO4	Kitchen - next to 3 Basin Sink	Flush180	31-AUG-19	1.000	ug/L
56204	56204-1-S-KIT-SO4	Kitchen - next to 3 Basin Sink	Initial	31-AUG-19	1.000	ug/L