



**Sep 10, 2024**

**TALCOTT**

**1840 W OHIO ST, Chicago IL 60622.**

Dear **TALCOTT** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**TALCOTT**

**1840 W OHIO ST, Chicago IL 60622.**

Estimadas familias de **TALCOTT**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51147	51147-1-S-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC01		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC02		Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC01		Initial	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-WC02		Initial	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC01		Initial	15-JAN-20	1.000	ug/L
51147	51147-2-E-HAL-WC02		Initial	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	10-JUN-16	1.740	ppb
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	10-JUN-16	0.360	ppb
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	10-JUN-16	0.533	ppb
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	10-JUN-16	0.683	ppb
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Initial	10-JUN-16	0.360	ppb
51147	51147-B-E-HAL-WC01	Across from B-13 (North), Fountain 1	Initial	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	10-JUN-16	0.275	ppb
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	10-JUN-16	0.307	ppb
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	10-JUN-16	0.306	ppb
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	10-JUN-16	0.294	ppb
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Initial	10-JUN-16	0.797	ppb
51147	51147-B-E-HAL-WC02	Across from B-13 (South), Fountain 2	Initial	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	10-JUN-16	2.510	ppb
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	10-JUN-16	1.300	ppb
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	10-JUN-16	0.932	ppb
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	10-JUN-16	1.750	ppb
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	15-JAN-20	1.590	ug/L
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Initial	10-JUN-16	1.420	ppb
51147	51147-B-E-HAL-F03	Across from B-7 (North), Fountain 1	Initial	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	10-JUN-16	0.646	ppb
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	10-JUN-16	0.857	ppb
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	10-JUN-16	0.632	ppb
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	10-JUN-16	1.310	ppb
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Initial	10-JUN-16	1.810	ppb
51147	51147-B-E-HAL-F04	Across from B-7 (South), Fountain 2	Initial	15-JAN-20	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-FEB-21	18.200	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-FEB-21	12.500	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-FEB-21	7.690	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-FEB-21	5.720	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-MAY-21	4.320	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-MAY-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-MAY-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-MAY-21	1.000	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	12-MAY-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	05-JAN-21	1.260	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	21-JAN-21	2.010	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	21-JAN-21	2.030	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	21-JAN-21	3.680	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Flush180	21-JAN-21	2.810	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Initial	12-FEB-21	12.700	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Initial	10-JUN-21	1.640	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Initial	12-MAY-21	5.100	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Initial	05-JAN-21	24.200	ug/L
51147	51147-1-W-HAL-BF01	Bottle filler by room 112	Initial	21-JAN-21	5.410	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	31-JUL-20	1.940	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	05-JAN-21	7.340	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	05-JAN-21	7.350	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	05-JAN-21	7.140	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	05-JAN-21	6.070	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	14-OCT-20	8.830	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	14-OCT-20	6.000	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	14-OCT-20	4.820	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	14-OCT-20	3.350	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	21-JAN-21	3.130	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	21-JAN-21	1.990	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	21-JAN-21	2.170	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	21-JAN-21	2.080	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	24-NOV-20	4.460	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	24-NOV-20	4.600	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	24-NOV-20	4.630	ug/L
51147	51147-3-HAL-F06	Hall	Flush180	24-NOV-20	3.930	ug/L
51147	51147-3-HAL-F06	Hall	Initial	31-JUL-20	6.090	ug/L
51147	51147-3-HAL-F06	Hall	Initial	05-JAN-21	8.990	ug/L
51147	51147-3-HAL-F06	Hall	Initial	14-OCT-20	11.200	ug/L
51147	51147-3-HAL-F06	Hall	Initial	21-JAN-21	4.000	ug/L
51147	51147-3-HAL-F06	Hall	Initial	24-NOV-20	7.710	ug/L
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	12-AUG-16	1.000	ppb
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	12-AUG-16	1.000	ppb
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	12-AUG-16	1.000	ppb
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	12-AUG-16	1.000	ppb
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-W-	Inside Room 203, Sink	Flush180	15-JAN-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	203-S06					
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-W-203-S06	Inside Room 203, Sink	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-W-203-S06	Inside Room 203, Sink	Initial	12-AUG-16	1.000	ppb
51147	51147-2-W-203-S06	Inside Room 203, Sink	Initial	15-JAN-20	1.000	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	10-JUN-16	0.181	ppb
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	10-JUN-16	0.263	ppb
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	10-JUN-16	0.201	ppb
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	10-JUN-16	0.173	ppb
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	15-JAN-20	3.350	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	15-JAN-20	1.960	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	15-JAN-20	3.070	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	15-JAN-20	1.110	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Flush180	05-JAN-21	1.000	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Initial	10-JUN-16	0.411	ppb
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Initial	15-JAN-20	2.180	ug/L
51147	51147-B-N-KIT-KS05	Kitchen (North), Sink 1	Initial	05-JAN-21	1.000	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	10-JUN-16	0.587	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	10-JUN-16	0.425	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	10-JUN-16	39.600	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	12-AUG-16	4.000	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	12-AUG-16	3.400	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	12-AUG-16	2.400	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	12-AUG-16	1.000	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	10-JUN-16	0.393	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Flush180	05-JAN-21	1.000	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Initial	10-JUN-16	0.332	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Initial	12-AUG-16	5.400	ppb
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Initial	15-JAN-20	1.030	ug/L
51147	51147-B-N-KIT-KS06	Kitchen (South), Sink 2	Initial	05-JAN-21	1.000	ug/L
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	10-JUN-16	0.591	ppb
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	10-JUN-16	0.618	ppb
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	10-JUN-16	0.413	ppb
51147	51147-1-S-	Next to RooNext to Room 101	Flush180	10-JUN-16	0.529	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	(West), Fountain 2				
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	15-JAN-20	1.800	ug/L
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Initial	10-JUN-16	0.553	ppb
51147	51147-1-S-HAL-F02	Next to RooNext to Room 101 (West), Fountain 2	Initial	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	10-JUN-16	0.521	ppb
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	10-JUN-16	0.481	ppb
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	10-JUN-16	0.795	ppb
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	10-JUN-16	0.538	ppb
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Initial	10-JUN-16	0.446	ppb
51147	51147-1-S-HAL-F03	Next to Room 101 (East), Fountain 1	Initial	15-JAN-20	1.000	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-16	1.700	ppb
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-16	2.390	ppb
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-16	2.270	ppb
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-16	1.960	ppb
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	15-JAN-20	8.700	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	15-JAN-20	9.490	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	15-JAN-20	6.520	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	15-JAN-20	5.160	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	31-JUL-20	9.830	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	12-FEB-21	2.740	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	12-FEB-21	3.290	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	12-FEB-21	3.210	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	12-FEB-21	3.120	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	19-MAY-20	10.100	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	19-MAY-20	12.500	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	19-MAY-20	7.450	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	19-MAY-20	8.390	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	05-JAN-21	10.500	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	05-JAN-21	11.500	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	05-JAN-21	8.400	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	05-JAN-21	7.710	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	14-OCT-20	15.800	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	14-OCT-20	11.900	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	14-OCT-20	8.490	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	24-NOV-20	6.280	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	24-NOV-20	6.560	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	24-NOV-20	5.060	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	24-NOV-20	4.940	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	21-JAN-21	3.700	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	21-JAN-21	3.240	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	21-JAN-21	4.550	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	21-JAN-21	7.090	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Flush180	14-OCT-20	13.900	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	10-JUN-16	4.500	ppb
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	15-JAN-20	9.120	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	31-JUL-20	4.980	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	12-FEB-21	2.190	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	10-JUN-21	1.000	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	19-MAY-20	5.600	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	05-JAN-21	8.010	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	14-OCT-20	13.600	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	24-NOV-20	4.220	ug/L
51147	51147-1-S-HAL-F01	Next to Room 104, Fountain	Initial	21-JAN-21	3.290	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-16	2.990	ppb
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-16	3.240	ppb
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-16	2.500	ppb
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-16	2.910	ppb
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	15-JAN-20	8.750	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	15-JAN-20	8.040	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	15-JAN-20	9.500	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	15-JAN-20	4.300	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	19-MAY-20	6.900	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	19-MAY-20	7.570	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	19-MAY-20	9.700	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Flush180	19-MAY-20	9.700	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Initial	10-JUN-16	2.950	ppb
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Initial	15-JAN-20	9.500	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Initial	10-JUN-21	1.000	ug/L
51147	51147-2-S-HAL-F03	Next to Room 204, Fountain	Initial	19-MAY-20	3.100	ug/L
51147	51147-2-HAL-WC01	Next to Room 212 (North), Fountain 1	Flush180	10-JUN-16	0.982	ppb
51147	51147-2-HAL-WC01	Next to Room 212 (North), Fountain 1	Flush180	10-JUN-16	0.946	ppb
51147	51147-2-HAL-WC01	Next to Room 212 (North), Fountain 1	Flush180	10-JUN-16	0.990	ppb
51147	51147-2-HAL-WC01	Next to Room 212 (North), Fountain 1	Flush180	10-JUN-16	0.937	ppb
51147	51147-2-HAL-WC01	Next to Room 212 (North), Fountain 1	Initial	10-JUN-16	0.814	ppb
51147	51147-2-HAL-WC02	Next to Room 212 (South), Fountain 2	Flush180	10-JUN-16	0.605	ppb
51147	51147-2-HAL-WC02	Next to Room 212 (South), Fountain 2	Flush180	10-JUN-16	1.400	ppb
51147	51147-2-HAL-WC02	Next to Room 212 (South), Fountain 2	Flush180	10-JUN-16	0.517	ppb
51147	51147-2-HAL-WC02	Next to Room 212 (South), Fountain 2	Flush180	10-JUN-16	0.814	ppb
51147	51147-2-HAL-WC02	Next to Room 212 (South), Fountain 2	Initial	10-JUN-16	0.432	ppb
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	10-JUN-16	0.713	ppb
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	10-JUN-16	0.927	ppb
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	10-JUN-16	0.807	ppb
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	10-JUN-16	0.761	ppb
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Initial	10-JUN-16	1.010	ppb
51147	51147-3-S-HAL-F05	Next to Room 301 (East), Fountain 1	Initial	15-JAN-20	1.840	ug/L
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	10-JUN-16	2.360	ppb
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	10-JUN-16	2.530	ppb
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	10-JUN-16	2.300	ppb
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	10-JUN-16	2.450	ppb
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Initial	10-JUN-16	5.710	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04	Fountain 2				
51147	51147-3-S-HAL-F04	Next to Room 301 (West), Fountain 2	Initial	15-JAN-20	1.500	ug/L
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	10-JUN-16	0.372	ppb
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	10-JUN-16	0.863	ppb
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	10-JUN-16	0.212	ppb
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	10-JUN-16	0.514	ppb
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	15-JAN-20	1.030	ug/L
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	15-JAN-20	1.060	ug/L
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Flush180	15-JAN-20	1.020	ug/L
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Initial	10-JUN-16	0.675	ppb
51147	51147-3-E-HAL-WC01	Next to Room 312 (North), Fountain 1	Initial	15-JAN-20	1.000	ug/L
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	10-JUN-16	1.030	ppb
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	10-JUN-16	0.780	ppb
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	10-JUN-16	0.871	ppb
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	10-JUN-16	0.970	ppb
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	15-JAN-20	1.120	ug/L
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	15-JAN-20	1.120	ug/L
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	15-JAN-20	1.110	ug/L
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Flush180	15-JAN-20	1.050	ug/L
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Initial	10-JUN-16	1.020	ppb
51147	51147-3-E-HAL-WC02	Next to Room 312 (South), Fountain 2	Initial	15-JAN-20	1.420	ug/L
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	10-JUN-16	0.518	ppb
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	10-JUN-16	0.585	ppb
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	10-JUN-16	0.538	ppb
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	10-JUN-16	0.641	ppb
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Initial	10-JUN-16	0.527	ppb
51147	51147-2-S-HAL-F05	Outside Room 201 (East), Fountain 1	Initial	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	10-JUN-16	0.742	ppb
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	10-JUN-16	0.807	ppb
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	10-JUN-16	0.883	ppb
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	10-JUN-16	0.883	ppb
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-	Outside Room 201 (West),	Flush180	15-JAN-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F04	Fountain 2				
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Flush180	15-JAN-20	1.000	ug/L
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Initial	10-JUN-16	0.699	ppb
51147	51147-2-S-HAL-F04	Outside Room 201 (West), Fountain 2	Initial	15-JAN-20	1.000	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-16	7.910	ppb
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-16	7.220	ppb
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-16	8.740	ppb
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-16	9.570	ppb
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	15-JAN-20	6.010	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	15-JAN-20	5.420	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	15-JAN-20	5.500	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	15-JAN-20	5.330	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-FEB-21	12.400	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-FEB-21	14.800	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-FEB-21	12.300	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-FEB-21	11.700	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	19-MAY-20	7.570	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	19-MAY-20	7.500	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-21	4.240	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	10-JUN-21	1.000	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	19-MAY-20	8.290	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	19-MAY-20	8.760	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-MAY-21	4.410	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-MAY-21	7.500	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-MAY-21	3.490	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	12-MAY-21	7.800	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	05-JAN-21	13.500	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	21-JAN-21	30.800	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	21-JAN-21	28.500	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	21-JAN-21	24.800	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Flush180	21-JAN-21	22.100	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	10-JUN-16	7.000	ppb
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	15-JAN-20	5.100	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	12-FEB-21	5.840	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	10-JUN-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	19-MAY-20	4.320	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	12-MAY-21	7.840	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	05-JAN-21	15.100	ug/L
51147	51147-3-S-HAL-F03	Outside Room 304, Fountain	Initial	21-JAN-21	43.300	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-FEB-21	4.230	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-FEB-21	9.310	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-FEB-21	13.200	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-FEB-21	3.930	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-MAY-21	1.000	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-MAY-21	1.030	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-MAY-21	1.000	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	12-MAY-21	1.000	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	05-JAN-21	13.500	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	21-JAN-21	10.400	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	21-JAN-21	4.510	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	21-JAN-21	4.550	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Flush180	21-JAN-21	6.770	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Initial	12-FEB-21	4.000	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Initial	12-MAY-21	4.580	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Initial	05-JAN-21	36.800	ug/L
51147	51147-2-S-HAL-BF01	Second floor Bottle Filler, across from boys bathroom	Initial	21-JAN-21	4.010	ug/L