



Sep 10, 2024

TILL

6543 S CHAMPLAIN AVE, Chicago IL 60637.

Dear **TILL** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

TILL

6543 S CHAMPLAIN AVE, Chicago IL 60637.

Estimadas familias de **TILL**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51407	51407-1-HAL-F02	Across From Room 105 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F02	Across From Room 105 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F02	Across From Room 105 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F02	Across From Room 105 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F02	Across From Room 105 North, Fountain 1	Initial	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F03	Across From Room 105 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F03	Across From Room 105 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F03	Across From Room 105 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F03	Across From Room 105 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F03	Across From Room 105 South, Fountain 2	Initial	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F01	Across From Room 210, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F01	Across From Room 210, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F01	Across From Room 210, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F01	Across From Room 210, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F01	Across From Room 210, Fountain	Initial	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F02	Across From Room 305 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F02	Across From Room 305 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F02	Across From Room 305 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F02	Across From Room 305 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F02	Across From Room 305 North, Fountain 1	Initial	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F03	Across From Room 305 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F03	Across From Room 305 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F03	Across From Room 305 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F03	Across From Room 305 South, Fountain 2	Flush180	18-AUG-20	1.440	ug/L
51407	51407-3-HAL-F03	Across From Room 305 South, Fountain 2	Initial	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F03	Across From Room 305 South, Fountain 2	Initial	18-AUG-20	1.440	ug/L
51407	51407-1-HAL-RBF01	Across from Room 105, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-1-HAL-RBF01	Across from Room 105, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-1-HAL-RBF01	Across from Room 105, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-1-HAL-RBF01	Across from Room 105, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-1-HAL-RBF01	Across from Room 105, Retrofitted Bottle Filler	Initial	19-NOV-21	1.000	ug/L
51407	51407-2-HAL-RBF02	Across from Room 205, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-2-HAL-RBF02	Across from Room 205, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-2-HAL-RBF02	Across from Room 205, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51407	51407-2-HAL-RBF02	Across from Room 205, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-2-HAL-RBF02	Across from Room 205, Retrofitted Bottle Filler	Initial	19-NOV-21	1.000	ug/L
51407	51407-3-HAL-RBF03	Across from Room 305, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-3-HAL-RBF03	Across from Room 305, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-3-HAL-RBF03	Across from Room 305, Retrofitted Bottle Filler	Flush180	19-NOV-21	1.000	ug/L
51407	51407-3-HAL-RBF03	Across from Room 305, Retrofitted Bottle Filler	Initial	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	11-JUN-16	5.320	ppb
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	11-JUN-16	5.950	ppb
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	11-JUN-16	6.080	ppb
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	11-JUN-16	5.310	ppb
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	19-NOV-21	3.200	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	19-NOV-21	2.340	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	19-NOV-21	2.920	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	19-NOV-21	1.790	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	07-DEC-21	1.560	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	07-DEC-21	1.700	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	07-DEC-21	1.690	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Flush180	07-DEC-21	2.150	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Initial	11-JUN-16	7.240	ppb
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Initial	19-NOV-21	5.430	ug/L
51407	51407-B-CAF-F03	Back Lunchroom Fountain, North Wall, Left	Initial	07-DEC-21	3.480	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	11-JUN-16	6.800	ppb
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	11-JUN-16	5.390	ppb
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	19-NOV-21	1.920	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	19-NOV-21	1.710	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	19-NOV-21	1.310	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	28-DEC-21	4.610	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	28-DEC-21	3.780	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	07-DEC-21	12.000	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	07-DEC-21	2.250	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	07-DEC-21	2.660	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	07-DEC-21	3.940	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	28-DEC-21	3.510	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Flush180	28-DEC-21	4.350	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Initial	11-JUN-16	5.450	ppb
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Initial	19-NOV-21	5.570	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Initial	07-DEC-21	6.000	ug/L
51407	51407-B-CAF-F04	Back Lunchroom Fountain, North Wall, Right	Initial	28-DEC-21	2.370	ug/L
51407	51407-B-CAF-F05	Back Lunchroom Fountain, South Wall, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F05	Back Lunchroom Fountain, South Wall, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F05	Back Lunchroom Fountain, South Wall, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F05	Back Lunchroom Fountain, South Wall, Left	Flush180	19-NOV-21	2.340	ug/L
51407	51407-B-CAF-F05	Back Lunchroom Fountain, South Wall, Left	Initial	19-NOV-21	1.380	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	19-NOV-21	2.820	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	19-NOV-21	1.470	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	07-DEC-21	1.740	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	07-DEC-21	1.110	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	07-DEC-21	1.390	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Flush180	07-DEC-21	2.180	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Initial	19-NOV-21	5.040	ug/L
51407	51407-B-CAF-F06	Back Lunchroom Fountain, South Wall, Right	Initial	07-DEC-21	2.980	ug/L
51407	51407-B-KIT-KS02	Basement Kitchen Sink, Center	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS02	Basement Kitchen Sink, Center	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS02	Basement Kitchen Sink, Center	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS02	Basement Kitchen Sink, Center	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS02	Basement Kitchen Sink, Center	Initial	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Initial	11-JUN-16	1.000	ppb
51407	51407-B-KIT-KS01	Basement Kitchen Sink, Left	Initial	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS03	Basement Kitchen Sink, Right	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS03	Basement Kitchen Sink, Right	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS03	Basement Kitchen Sink, Right	Flush180	19-NOV-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS03					
51407	51407-B-KIT-KS03	Basement Kitchen Sink, Right	Flush180	19-NOV-21	1.000	ug/L
51407	51407-B-KIT-KS03	Basement Kitchen Sink, Right	Initial	19-NOV-21	1.000	ug/L
51407	51407-B-CAF-F01	Main Lunchroom Fountain, Left	Flush180	19-NOV-21	2.430	ug/L
51407	51407-B-CAF-F01	Main Lunchroom Fountain, Left	Flush180	19-NOV-21	2.690	ug/L
51407	51407-B-CAF-F01	Main Lunchroom Fountain, Left	Flush180	19-NOV-21	3.100	ug/L
51407	51407-B-CAF-F01	Main Lunchroom Fountain, Left	Flush180	19-NOV-21	3.300	ug/L
51407	51407-B-CAF-F01	Main Lunchroom Fountain, Left	Initial	19-NOV-21	3.260	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	11-JUN-16	5.590	ppb
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	11-JUN-16	1.000	ppb
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	11-JUN-16	6.540	ppb
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	09-FEB-22	1.000	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	09-FEB-22	1.000	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	09-FEB-22	1.000	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	09-FEB-22	1.000	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	19-NOV-21	5.060	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	19-NOV-21	8.480	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	18-JAN-22	6.040	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	18-JAN-22	4.960	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	18-JAN-22	4.040	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	18-JAN-22	4.070	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	07-DEC-21	5.870	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	07-DEC-21	6.560	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	07-DEC-21	7.370	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	07-DEC-21	6.920	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	28-DEC-21	9.480	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	28-DEC-21	14.700	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	28-DEC-21	12.000	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	28-DEC-21	8.700	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	19-NOV-21	5.040	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Flush180	19-NOV-21	5.090	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Initial	11-JUN-16	7.310	ppb
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Initial	09-FEB-22	1.000	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Initial	18-JAN-22	11.400	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Initial	07-DEC-21	7.690	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Initial	28-DEC-21	3.680	ug/L
51407	51407-B-CAF-F02	Main Lunchroom Fountain, Right	Initial	19-NOV-21	7.600	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02					
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Flush180	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Flush180	18-AUG-20	1.000	ug/L
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Initial	11-JUN-16	1.000	ppb
51407	51407-1-HAL-F01	Outside Of Room 110, Fountain	Initial	18-AUG-20	1.750	ug/L
51407	51407-2-HAL-F02	Outside Of Room 205 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F02	Outside Of Room 205 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F02	Outside Of Room 205 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F02	Outside Of Room 205 North, Fountain 1	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F02	Outside Of Room 205 North, Fountain 1	Initial	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F03	Outside Of Room 205 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F03	Outside Of Room 205 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F03	Outside Of Room 205 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F03	Outside Of Room 205 South, Fountain 2	Flush180	11-JUN-16	1.000	ppb
51407	51407-2-HAL-F03	Outside Of Room 205 South, Fountain 2	Initial	11-JUN-16	1.000	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-JUN-16	8.070	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-JUN-16	10.800	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-JUN-16	8.470	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-JUN-16	11.400	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-AUG-16	8.800	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-AUG-16	8.200	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-AUG-16	17.000	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	11-AUG-16	8.200	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	25-AUG-16	2.200	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	25-AUG-16	1.000	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	25-AUG-16	1.000	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	25-AUG-16	1.000	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	16-NOV-16	7.020	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	16-NOV-16	4.450	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	16-NOV-16	6.680	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Flush180	16-NOV-16	5.860	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Initial	16-NOV-16	1.380	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Initial	11-JUN-16	15.600	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Initial	11-AUG-16	14.000	ppb
51407	51407-3-HAL-F01	Outside Of Room 310, Fountain	Initial	25-AUG-16	1.000	ppb

