



Sep 10, 2024

UPLIFT HS

900 W WILSON AVE, Chicago IL 60640.

Dear **UPLIFT HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

UPLIFT HS

900 W WILSON AVE, Chicago IL 60640.

Estimadas familias de **UPLIFT HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush180	14-OCT-16	0.178	ppb
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush180	14-OCT-16	0.400	ppb
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush180	14-OCT-16	0.350	ppb
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Flush180	14-OCT-16	0.688	ppb
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Initial	14-OCT-16	2.020	ppb
51066	51066-1-HAL-F04	Main- House C Commons, Left Fountain	Initial	15-NOV-2023	1.380	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush180	14-OCT-16	0.239	ppb
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush180	14-OCT-16	0.205	ppb
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush180	14-OCT-16	0.222	ppb
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush180	14-OCT-16	0.304	ppb
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Flush180	17-DEC-20	1.000	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Initial	14-OCT-16	0.256	ppb
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Initial	17-DEC-20	1.000	ug/L
51066	51066-1-HAL-F05	Main- House C Commons, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-3-301-S09	Main- Inside Room 301, South Wall, Sink	Flush180	14-OCT-16	0.991	ppb
51066	51066-3-301-S09	Main- Inside Room 301, South Wall, Sink	Flush180	14-OCT-16	1.150	ppb
51066	51066-3-301-S09	Main- Inside Room 301, South Wall, Sink	Flush180	14-OCT-16	0.765	ppb
51066	51066-3-301-S09	Main- Inside Room 301, South Wall, Sink	Flush180	14-OCT-16	0.722	ppb
51066	51066-3-301-S09	Main- Inside Room 301, South Wall, Sink	Initial	14-OCT-16	1.140	ppb
51066	51066-3-301-S10	Main- Inside Room 301, West Wall, Sink	Flush180	14-OCT-16	1.650	ppb
51066	51066-3-301-S10	Main- Inside Room 301, West Wall, Sink	Flush180	14-OCT-16	0.231	ppb
51066	51066-3-301-S10	Main- Inside Room 301, West Wall, Sink	Flush180	14-OCT-16	0.601	ppb
51066	51066-3-301-S10	Main- Inside Room 301, West Wall, Sink	Flush180	14-OCT-16	0.346	ppb
51066	51066-3-301-S10	Main- Inside Room 301, West Wall, Sink	Initial	14-OCT-16	0.715	ppb
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	15-NOV-2023	3.850	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	15-NOV-2023	3.640	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	15-NOV-2023	2.340	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	15-NOV-2023	5.480	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	27-MAR-2024	5.580	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	27-MAR-2024	4.660	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	27-MAR-2024	5.320	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	27-MAR-2024	7.180	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	10-JAN-2024	8.640	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	10-JAN-2024	5.020	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	10-JAN-2024	6.120	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	06-FEB-2024	7.050	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	06-FEB-2024	8.370	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	06-FEB-2024	13.000	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	06-FEB-2024	8.950	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Flush	10-JAN-2024	7.330	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Initial	15-NOV-2023	11.600	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Initial	27-MAR-2024	1.960	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Initial	10-JAN-2024	13.700	ug/L
51066	51066-1-KIT-KS04	Main- Kitchen Pot Filler	Initial	06-FEB-2024	14.500	ug/L
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Flush180	14-OCT-16	0.512	ppb
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Initial	14-OCT-16	0.533	ppb
51066	51066-1-KIT-KS02	Main- Kitchen, 3-Basin, Center Fountain	Initial	15-NOV-2023	1.190	ug/L
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush	15-NOV-2023	1.690	ug/L
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush180	14-OCT-16	0.563	ppb
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush180	14-OCT-16	0.237	ppb
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush180	14-OCT-16	1.380	ppb
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Flush180	14-OCT-16	0.211	ppb
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Initial	14-OCT-16	1.030	ppb
51066	51066-1-KIT-KS01	Main- Kitchen, 3-Basin, Left Fountain	Initial	15-NOV-2023	1.890	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush180	14-OCT-16	0.429	ppb
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Initial	14-OCT-16	0.442	ppb
51066	51066-1-KIT-KS03	Main- Kitchen, 3-Basin, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-BF01	Main- Oustide Room A101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-BF01	Main- Oustide Room A101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-BF01	Main- Oustide Room A101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-BF01	Main- Oustide Room A101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-BF01	Main- Oustide Room A101, Bottle Filler	Initial	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Flush180	14-OCT-16	0.797	ppb
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Flush180	14-OCT-16	0.435	ppb
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Flush180	14-OCT-16	0.332	ppb
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Flush180	14-OCT-16	0.343	ppb
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Flush180	17-DEC-20	1.000	ug/L
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Initial	14-OCT-16	0.848	ppb
51066	51066-1-HAL-F08	Main- Oustide Room A101, Left Fountain	Initial	17-DEC-20	1.000	ug/L
51066	51066-1-HAL-F09	Main- Oustide Room A101, Right Fountain	Flush180	14-OCT-16	0.554	ppb
51066	51066-1-HAL-F09	Main- Oustide Room A101, Right Fountain	Flush180	14-OCT-16	0.459	ppb
51066	51066-1-HAL-F09	Main- Oustide Room A101, Right Fountain	Flush180	14-OCT-16	0.472	ppb
51066	51066-1-HAL-F09	Main- Oustide Room A101, Right Fountain	Flush180	14-OCT-16	0.342	ppb
51066	51066-1-HAL-F09	Main- Oustide Room A101, Right Fountain	Initial	14-OCT-16	0.521	ppb
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush180	14-OCT-16	1.720	ppb
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush180	14-OCT-16	1.250	ppb
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush180	14-OCT-16	0.543	ppb
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Flush180	14-OCT-16	1.050	ppb
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Initial	14-OCT-16	1.450	ppb
51066	51066-2-HAL-F06	Main- Oustide Room A200, Left Fountain	Initial	15-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush180	14-OCT-16	0.751	ppb
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush180	14-OCT-16	0.765	ppb
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush180	14-OCT-16	0.826	ppb
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Flush180	14-OCT-16	0.656	ppb
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Initial	14-OCT-16	0.755	ppb
51066	51066-2-HAL-F07	Main- Oustide Room A200, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush180	14-OCT-16	0.331	ppb
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush180	14-OCT-16	0.326	ppb
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush180	14-OCT-16	0.321	ppb
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Flush180	14-OCT-16	0.343	ppb
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Initial	14-OCT-16	0.289	ppb
51066	51066-3-HAL-F07	Main- Oustide Room A300, Left Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush180	14-OCT-16	0.351	ppb
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush180	14-OCT-16	0.333	ppb
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush180	14-OCT-16	0.332	ppb
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Flush180	14-OCT-16	0.324	ppb
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Initial	14-OCT-16	0.305	ppb
51066	51066-3-HAL-F08	Main- Oustide Room A300, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-RBF01	Main- Oustide Room B101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-RBF01	Main- Oustide Room B101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-RBF01	Main- Oustide Room B101, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-RBF01	Main- Oustide Room B101, Bottle Filler	Initial	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush	15-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush180	14-OCT-16	0.964	ppb
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush180	14-OCT-16	1.370	ppb
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush180	14-OCT-16	1.100	ppb
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Flush180	14-OCT-16	1.210	ppb
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Initial	14-OCT-16	1.160	ppb
51066	51066-1-HAL-F06	Main- Oustide Room B101, Left Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-1-HAL-F07	Main- Oustide Room B101, Right Fountain	Flush180	14-OCT-16	1.090	ppb
51066	51066-1-HAL-F07	Main- Oustide Room B101, Right Fountain	Flush180	14-OCT-16	0.854	ppb
51066	51066-1-HAL-F07	Main- Oustide Room B101, Right Fountain	Flush180	14-OCT-16	0.597	ppb
51066	51066-1-HAL-F07	Main- Oustide Room B101, Right Fountain	Flush180	14-OCT-16	0.516	ppb
51066	51066-1-HAL-F07	Main- Oustide Room B101, Right Fountain	Initial	14-OCT-16	0.846	ppb
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush180	14-OCT-16	0.729	ppb
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush180	14-OCT-16	1.150	ppb
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush180	14-OCT-16	1.280	ppb
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Flush180	14-OCT-16	2.880	ppb
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Initial	14-OCT-16	1.960	ppb
51066	51066-2-HAL-F04	Main- Oustide Room B200, Left Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-RBF01	Main- Oustide Room B200, Right Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-RBF01	Main- Oustide Room B200, Right Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-RBF01	Main- Oustide Room B200, Right Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-RBF01	Main- Oustide Room B200, Right Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-RBF01	Main- Oustide Room B200, Right Bottle Filler	Initial	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F05	Main- Oustide Room B200, Right Fountain	Flush180	14-OCT-16	0.461	ppb
51066	51066-2-HAL-F05	Main- Oustide Room B200, Right Fountain	Flush180	14-OCT-16	0.437	ppb
51066	51066-2-HAL-F05	Main- Oustide Room B200, Right Fountain	Flush180	14-OCT-16	0.420	ppb
51066	51066-2-HAL-F05	Main- Oustide Room B200, Right Fountain	Flush180	14-OCT-16	0.426	ppb
51066	51066-2-HAL-F05	Main- Oustide Room B200, Right Fountain	Initial	14-OCT-16	0.341	ppb
51066	51066-3-HAL-F05	Main- Oustide Room B300, Left Fountain	Flush180	14-OCT-16	0.157	ppb
51066	51066-3-HAL-F05	Main- Oustide Room B300, Left Fountain	Flush180	14-OCT-16	0.159	ppb
51066	51066-3-HAL-F05	Main- Oustide Room B300, Left Fountain	Flush180	14-OCT-16	0.131	ppb
51066	51066-3-HAL-F05	Main- Oustide Room B300, Left Fountain	Flush180	14-OCT-16	0.157	ppb
51066	51066-3-HAL-F05	Main- Oustide Room B300, Left Fountain	Initial	14-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F05	Fountain				
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F06	Main- Oustide Room B300, Right Fountain	Flush180	14-OCT-16	0.192	ppb
51066	51066-3-HAL-F06	Main- Oustide Room B300, Right Fountain	Flush180	14-OCT-16	0.264	ppb
51066	51066-3-HAL-F06	Main- Oustide Room B300, Right Fountain	Flush180	14-OCT-16	0.223	ppb
51066	51066-3-HAL-F06	Main- Oustide Room B300, Right Fountain	Flush180	14-OCT-16	0.288	ppb
51066	51066-3-HAL-F06	Main- Oustide Room B300, Right Fountain	Initial	14-OCT-16	1.000	ppb
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Initial	15-NOV-2023	1.010	ug/L
51066	51066-3-HAL-RBF01	Main- Oustide Room B300, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush180	14-OCT-16	0.132	ppb
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush180	14-OCT-16	0.129	ppb
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Flush180	14-OCT-16	1.010	ppb
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Initial	14-OCT-16	0.244	ppb
51066	51066-3-HAL-F01	Main- Oustide Room C301, Left Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush180	14-OCT-16	0.125	ppb
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush180	14-OCT-16	0.124	ppb
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush180	14-OCT-16	0.126	ppb
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Initial	14-OCT-16	0.146	ppb
51066	51066-3-HAL-F02	Main- Oustide Room C301, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-	Main- Oustide Room C332, Left Fountain	Flush	15-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush180	14-OCT-16	2.810	ppb
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush180	14-OCT-16	2.480	ppb
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush180	14-OCT-16	7.270	ppb
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Flush180	14-OCT-16	2.250	ppb
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Initial	14-OCT-16	6.260	ppb
51066	51066-3-HAL-F03	Main- Oustide Room C332, Left Fountain	Initial	15-NOV-2023	1.270	ug/L
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush180	14-OCT-16	0.275	ppb
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush180	14-OCT-16	0.259	ppb
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush180	14-OCT-16	0.258	ppb
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Flush180	14-OCT-16	0.378	ppb
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Initial	14-OCT-16	0.394	ppb
51066	51066-3-HAL-F04	Main- Oustide Room C332, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush	15-NOV-2023	4.910	ug/L
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush	15-NOV-2023	1.000	ug/L
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Flush180	14-OCT-16	1.000	ppb
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Initial	14-OCT-16	0.204	ppb
51066	51066-2-HAL-F03	Main- Outside Music Room 229, Fountain	Initial	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush	15-NOV-2023	1.020	ug/L
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush	15-NOV-2023	1.120	ug/L
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush	15-NOV-2023	1.060	ug/L
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush180	14-OCT-16	0.253	ppb
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush180	14-OCT-16	0.270	ppb
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush180	14-OCT-16	0.267	ppb
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Flush180	14-OCT-16	0.262	ppb
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Initial	14-OCT-16	0.409	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52495	52495-1-HAL-F05	Annex- 1st Floor Outside Mens Restroom, Left Fount	Initial	15-NOV-2023	1.080	ug/L
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush	15-NOV-2023	1.050	ug/L
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush	15-NOV-2023	1.020	ug/L
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush180	14-OCT-16	0.221	ppb
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush180	14-OCT-16	0.223	ppb
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush180	14-OCT-16	0.218	ppb
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Flush180	14-OCT-16	0.222	ppb
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Initial	14-OCT-16	0.189	ppb
52495	52495-1-HAL-F06	Annex- 1st Floor Outside Mens Restroom, Right Foun	Initial	15-NOV-2023	1.000	ug/L
52495	52395-1-HAL-BF01	Annex- 1st Floor Outside Womens Restroom, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
52495	52395-1-HAL-BF01	Annex- 1st Floor Outside Womens Restroom, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
52495	52395-1-HAL-BF01	Annex- 1st Floor Outside Womens Restroom, Bottle Filler	Flush	15-NOV-2023	1.000	ug/L
52495	52395-1-HAL-BF01	Annex- 1st Floor Outside Womens Restroom, Bottle Filler	Initial	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Initial	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F03	Annex- 1st Floor Outside Womens Restroom, Left Fou	Initial	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Flush180	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Initial	14-OCT-16	1.000	ppb
52495	52495-1-HAL-F04	Annex- 1st Floor Outside Womens Restroom, Right Fo	Initial	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush180	14-OCT-16	0.145	ppb
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush180	14-OCT-16	0.163	ppb
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush180	14-OCT-16	0.225	ppb
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Flush180	14-OCT-16	0.200	ppb
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Initial	14-OCT-16	0.222	ppb
52495	52495-2-LR-F03	Annex- Boys Locker Room, Left Fountain	Initial	15-NOV-2023	1.040	ug/L
52495	52495-2-LR-F04	Annex- Boys Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F04	Annex- Boys Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F04	Annex- Boys Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F04	Annex- Boys Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F04	Annex- Boys Locker Room, Right Fountain	Initial	15-NOV-2023	1.470	ug/L
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Initial	14-OCT-16	1.000	ppb
52495	52495-2-LR-F05	Annex- Girls Locker Room, Left Fountain	Initial	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Flush180	14-OCT-16	1.000	ppb
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Initial	14-OCT-16	1.000	ppb
52495	52495-2-LR-F06	Annex- Girls Locker Room, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
52495	52495-2-HAL-F01	Annex- Outside Locker Rooms, Left Fountain	Flush180	14-OCT-16	1.470	ppb
52495	52495-2-HAL-F01	Annex- Outside Locker Rooms, Left Fountain	Flush180	14-OCT-16	1.180	ppb
52495	52495-2-HAL-F01	Annex- Outside Locker Rooms, Left Fountain	Flush180	14-OCT-16	1.240	ppb
52495	52495-2-HAL-	Annex- Outside Locker Rooms,	Flush180	14-OCT-16	1.210	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Left Fountain				
52495	52495-2-HAL-F01	Annex- Outside Locker Rooms, Left Fountain	Initial	14-OCT-16	1.390	ppb
52495	52495-2-HAL-F02	Annex- Outside Locker Rooms, Right Fountain	Flush180	14-OCT-16	1.050	ppb
52495	52495-2-HAL-F02	Annex- Outside Locker Rooms, Right Fountain	Flush180	14-OCT-16	1.330	ppb
52495	52495-2-HAL-F02	Annex- Outside Locker Rooms, Right Fountain	Flush180	14-OCT-16	1.510	ppb
52495	52495-2-HAL-F02	Annex- Outside Locker Rooms, Right Fountain	Flush180	14-OCT-16	0.706	ppb
52495	52495-2-HAL-F02	Annex- Outside Locker Rooms, Right Fountain	Initial	14-OCT-16	2.950	ppb
52495	52495-1-HAL-F01	Annex- Outside Room P108, Left Fountain	Flush180	14-OCT-16	0.613	ppb
52495	52495-1-HAL-F01	Annex- Outside Room P108, Left Fountain	Flush180	14-OCT-16	1.060	ppb
52495	52495-1-HAL-F01	Annex- Outside Room P108, Left Fountain	Flush180	14-OCT-16	1.050	ppb
52495	52495-1-HAL-F01	Annex- Outside Room P108, Left Fountain	Flush180	14-OCT-16	0.548	ppb
52495	52495-1-HAL-F01	Annex- Outside Room P108, Left Fountain	Initial	14-OCT-16	7.880	ppb
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush	15-NOV-2023	1.000	ug/L
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush180	14-OCT-16	0.352	ppb
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush180	14-OCT-16	0.299	ppb
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush180	14-OCT-16	0.299	ppb
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Flush180	14-OCT-16	0.593	ppb
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Initial	14-OCT-16	0.747	ppb
52495	52495-1-HAL-F02	Annex- Outside Room P108, Right Fountain	Initial	15-NOV-2023	1.000	ug/L
52495	52495-1-POOL-F07	Annex- Pool Area, Fountain	Flush180	14-OCT-16	0.374	ppb
52495	52495-1-POOL-F07	Annex- Pool Area, Fountain	Flush180	14-OCT-16	0.382	ppb
52495	52495-1-POOL-F07	Annex- Pool Area, Fountain	Flush180	14-OCT-16	0.493	ppb
52495	52495-1-POOL-F07	Annex- Pool Area, Fountain	Flush180	14-OCT-16	0.411	ppb
52495	52495-1-POOL-F07	Annex- Pool Area, Fountain	Initial	14-OCT-16	0.771	ppb