



Sep 10, 2024

VICK

2554 W 113TH ST, Chicago IL 60655.

Dear **VICK** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

VICK

2554 W 113TH ST, Chicago IL 60655.

Estimadas familias de **VICK**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51429	51429-1-HAL-WC01	Hallway by RR	Flush180	25-MAY-16	1.050	ppb
51429	51429-1-HAL-WC01	Hallway by RR	Flush180	25-MAY-16	0.127	ppb
51429	51429-1-HAL-WC01	Hallway by RR	Flush180	25-MAY-16	0.934	ppb
51429	51429-1-HAL-WC01	Hallway by RR	Flush180	25-MAY-16	0.723	ppb
51429	51429-1-HAL-WC01	Hallway by RR	Flush180	21-AUG-20	1.000	ug/L
51429	51429-1-HAL-WC01	Hallway by RR	Initial	25-MAY-16	0.898	ppb
51429	51429-1-HAL-WC01	Hallway by RR	Initial	21-AUG-20	1.420	ug/L
51429	51429-1-101-BF01	PKC - Room 101 Bottle Filler	Flush180	16-AUG-23	5.450	ug/L
51429	51429-1-101-BF01	PKC - Room 101 Bottle Filler	Flush180	16-AUG-23	4.800	ug/L
51429	51429-1-101-BF01	PKC - Room 101 Bottle Filler	Flush180	16-AUG-23	4.140	ug/L
51429	51429-1-101-BF01	PKC - Room 101 Bottle Filler	Flush180	16-AUG-23	3.920	ug/L
51429	51429-1-101-BF01	PKC - Room 101 Bottle Filler	Initial	16-AUG-23	26.700	ug/L
51429	51429-1-101-F01	PKC - Room 101 Fountain	Flush180	16-AUG-23	3.290	ug/L
51429	51429-1-101-F01	PKC - Room 101 Fountain	Flush180	16-AUG-23	1.940	ug/L
51429	51429-1-101-F01	PKC - Room 101 Fountain	Flush180	16-AUG-23	1.940	ug/L
51429	51429-1-101-F01	PKC - Room 101 Fountain	Flush180	16-AUG-23	1.670	ug/L
51429	51429-1-101-F01	PKC - Room 101 Fountain	Initial	16-AUG-23	4.530	ug/L
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	25-MAY-16	3.180	ppb
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	25-MAY-16	3.110	ppb
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	25-MAY-16	3.350	ppb
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	25-MAY-16	3.660	ppb
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	16-AUG-23	2.270	ug/L
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	16-AUG-23	2.030	ug/L
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	16-AUG-23	1.570	ug/L
51429	51429-1-101-S01	PKC - Room 101 Sink	Flush180	16-AUG-23	1.710	ug/L
51429	51429-1-101-S01	PKC - Room 101 Sink	Initial	25-MAY-16	1.340	ppb
51429	51429-1-101-S01	PKC - Room 101 Sink	Initial	16-AUG-23	3.850	ug/L
51429	51429-1-102-BF01	PKC - Room 102 Bottle Filler	Flush180	16-AUG-23	18.900	ug/L
51429	51429-1-102-BF01	PKC - Room 102 Bottle Filler	Flush180	16-AUG-23	20.600	ug/L
51429	51429-1-102-BF01	PKC - Room 102 Bottle Filler	Flush180	16-AUG-23	9.480	ug/L
51429	51429-1-102-BF01	PKC - Room 102 Bottle Filler	Flush180	16-AUG-23	29.900	ug/L
51429	51429-1-102-BF01	PKC - Room 102 Bottle Filler	Initial	16-AUG-23	56.700	ug/L
51429	51429-1-102-F01	PKC - Room 102 Fountain	Flush180	16-AUG-23	7.650	ug/L
51429	51429-1-102-F01	PKC - Room 102 Fountain	Flush180	16-AUG-23	3.730	ug/L
51429	51429-1-102-F01	PKC - Room 102 Fountain	Flush180	16-AUG-23	9.850	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51429	51429-1-102-F01	PKC - Room 102 Fountain	Flush180	16-AUG-23	2.870	ug/L
51429	51429-1-102-F01	PKC - Room 102 Fountain	Initial	16-AUG-23	47.800	ug/L
51429	51429-1-103-BF01	PKC - Room 103 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-BF01	PKC - Room 103 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-BF01	PKC - Room 103 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-BF01	PKC - Room 103 Bottle Filler	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-103-F01	PKC - Room 103 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-F01	PKC - Room 103 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-F01	PKC - Room 103 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-F01	PKC - Room 103 Fountain	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	25-MAY-16	0.131	ppb
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	25-MAY-16	0.188	ppb
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-S01	PKC - Room 103 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-103-S01	PKC - Room 103 Sink	Initial	25-MAY-16	0.154	ppb
51429	51429-1-103-S01	PKC - Room 103 Sink	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-104-BF01	PKC - Room 104 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-BF01	PKC - Room 104 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-BF01	PKC - Room 104 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-BF01	PKC - Room 104 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-BF01	PKC - Room 104 Bottle Filler	Initial	16-AUG-23	1.360	ug/L
51429	51429-1-104-F01	PKC - Room 104 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-F01	PKC - Room 104 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-F01	PKC - Room 104 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-F01	PKC - Room 104 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-F01	PKC - Room 104 Fountain	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	25-MAY-16	0.180	ppb
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	25-MAY-16	0.297	ppb
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	25-MAY-16	0.233	ppb
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	25-MAY-16	1.330	ppb
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	29-OCT-20	1.000	ug/L

Water Quality Assessment Barbara Vick Early Childhood & Family Center

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	29-OCT-20	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	29-OCT-20	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	29-OCT-20	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	21-AUG-20	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Initial	25-MAY-16	1.200	ppb
51429	51429-1-104-S01	PKC - Room 104 Sink	Initial	29-OCT-20	1.000	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Initial	21-AUG-20	8.620	ug/L
51429	51429-1-104-S01	PKC - Room 104 Sink	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-105-BF01	PKC - Room 105 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-BF01	PKC - Room 105 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-BF01	PKC - Room 105 Bottle Filler	Flush180	16-AUG-23	1.090	ug/L
51429	51429-1-105-BF01	PKC - Room 105 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-BF01	PKC - Room 105 Bottle Filler	Initial	16-AUG-23	1.150	ug/L
51429	51429-1-105-F01	PKC - Room 105 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-F01	PKC - Room 105 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-F01	PKC - Room 105 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-F01	PKC - Room 105 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-F01	PKC - Room 105 Fountain	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-105-S01	PKC - Room 105 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-105-S01	PKC - Room 105 Sink	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-105-S01	PKC - Room 105 Sink	Initial	25-MAY-16	0.280	ppb
51429	51429-1-106-BF01	PKC - Room 106 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-BF01	PKC - Room 106 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-BF01	PKC - Room 106 Bottle Filler	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-BF01	PKC - Room 106 Bottle Filler	Initial	16-AUG-23	2.000	ug/L
51429	51429-1-106-	PKC - Room 106 Fountain	Flush180	16-AUG-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51429	51429-1-106-F01	PKC - Room 106 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-F01	PKC - Room 106 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-F01	PKC - Room 106 Fountain	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-F01	PKC - Room 106 Fountain	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	16-AUG-23	1.000	ug/L
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	25-MAY-16	0.192	ppb
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-106-S01	PKC - Room 106 Sink	Flush180	25-MAY-16	0.618	ppb
51429	51429-1-106-S01	PKC - Room 106 Sink	Initial	16-AUG-23	1.000	ug/L
51429	51429-1-106-S01	PKC - Room 106 Sink	Initial	25-MAY-16	1.000	ppb
51429	51429-1-102-S01	Room 102	Flush180	25-MAY-16	0.181	ppb
51429	51429-1-102-S01	Room 102	Flush180	25-MAY-16	1.000	ppb
51429	51429-1-102-S01	Room 102	Flush180	25-MAY-16	0.882	ppb
51429	51429-1-102-S01	Room 102	Flush180	25-MAY-16	0.132	ppb
51429	51429-1-102-S01	Room 102	Initial	25-MAY-16	0.380	ppb
55055	55055-1-STU-BF01	Bottle Filler inside Studio Room	Flush180	21-DEC-21	2.060	ug/L
55055	55055-1-STU-BF01	Bottle Filler inside Studio Room	Flush180	21-DEC-21	3.300	ug/L
55055	55055-1-STU-BF01	Bottle Filler inside Studio Room	Flush180	21-DEC-21	3.300	ug/L
55055	55055-1-STU-BF01	Bottle Filler inside Studio Room	Flush180	21-DEC-21	3.100	ug/L
55055	55055-1-STU-BF01	Bottle Filler inside Studio Room	Initial	21-DEC-21	2.200	ug/L
55055	55055-1-202-BF01	Bottle Filler inside rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-BF01	Bottle Filler inside rm 202	Flush180	21-DEC-21	1.060	ug/L
55055	55055-1-202-BF01	Bottle Filler inside rm 202	Flush180	21-DEC-21	1.070	ug/L
55055	55055-1-202-BF01	Bottle Filler inside rm 202	Flush180	21-DEC-21	1.090	ug/L
55055	55055-1-202-BF01	Bottle Filler inside rm 202	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-203-BF01	Bottle Filler inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-BF01	Bottle Filler inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-BF01	Bottle Filler inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-BF01	Bottle Filler inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-BF01	Bottle Filler inside rm 203	Initial	21-DEC-21	1.740	ug/L
55055	55055-1-204-BF01	Bottle Filler inside rm 204	Flush180	21-DEC-21	1.520	ug/L
55055	55055-1-204-BF01	Bottle Filler inside rm 204	Flush180	21-DEC-21	1.400	ug/L
55055	55055-1-204-	Bottle Filler inside rm 204	Flush180	21-DEC-21	1.600	ug/L

Water Quality Assessment Barbara Vick Early Childhood & Family Center

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01					
55055	55055-1-204-BF01	Bottle Filler inside rm 204	Flush180	21-DEC-21	1.800	ug/L
55055	55055-1-204-BF01	Bottle Filler inside rm 204	Initial	21-DEC-21	2.800	ug/L
55055	55055-1-205-BF01	Bottle Filler inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-BF01	Bottle Filler inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-BF01	Bottle Filler inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-BF01	Bottle Filler inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-BF01	Bottle Filler inside rm 205	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-206-BF01	Bottle Filler inside rm 206	Flush180	21-DEC-21	1.030	ug/L
55055	55055-1-206-BF01	Bottle Filler inside rm 206	Flush180	21-DEC-21	1.530	ug/L
55055	55055-1-206-BF01	Bottle Filler inside rm 206	Flush180	21-DEC-21	1.570	ug/L
55055	55055-1-206-BF01	Bottle Filler inside rm 206	Flush180	21-DEC-21	1.580	ug/L
55055	55055-1-206-BF01	Bottle Filler inside rm 206	Initial	21-DEC-21	1.780	ug/L
55055	55055-1-STU-F01	Fountain inside Studio Room	Flush180	21-DEC-21	2.600	ug/L
55055	55055-1-STU-F01	Fountain inside Studio Room	Flush180	21-DEC-21	2.100	ug/L
55055	55055-1-STU-F01	Fountain inside Studio Room	Flush180	21-DEC-21	1.420	ug/L
55055	55055-1-STU-F01	Fountain inside Studio Room	Flush180	21-DEC-21	1.270	ug/L
55055	55055-1-STU-F01	Fountain inside Studio Room	Initial	21-DEC-21	2.800	ug/L
55055	55055-1-202-F01	Fountain inside rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-F01	Fountain inside rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-F01	Fountain inside rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-F01	Fountain inside rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-F01	Fountain inside rm 202	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-203-F01	Fountain inside rm 203	Flush180	21-DEC-21	1.180	ug/L
55055	55055-1-203-F01	Fountain inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-F01	Fountain inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-F01	Fountain inside rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-F01	Fountain inside rm 203	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-204-F01	Fountain inside rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-F01	Fountain inside rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-F01	Fountain inside rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-F01	Fountain inside rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-F01	Fountain inside rm 204	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-205-F01	Fountain inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-F01	Fountain inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-F01	Fountain inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-F01	Fountain inside rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-F01	Fountain inside rm 205	Initial	21-DEC-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
55055	55055-1-206-F01	Fountain inside rm 206	Flush180	21-DEC-21	1.440	ug/L
55055	55055-1-206-F01	Fountain inside rm 206	Flush180	21-DEC-21	1.380	ug/L
55055	55055-1-206-F01	Fountain inside rm 206	Flush180	21-DEC-21	1.380	ug/L
55055	55055-1-206-F01	Fountain inside rm 206	Flush180	21-DEC-21	1.280	ug/L
55055	55055-1-206-F01	Fountain inside rm 206	Initial	21-DEC-21	1.770	ug/L
55055	55055-1-101-BF01	Room 101 Bottle Filler	Flush180	27-SEP-23	1.790	ug/L
55055	55055-1-101-BF01	Room 101 Bottle Filler	Flush180	27-SEP-23	2.670	ug/L
55055	55055-1-101-BF01	Room 101 Bottle Filler	Flush180	27-SEP-23	2.190	ug/L
55055	55055-1-101-BF01	Room 101 Bottle Filler	Flush180	27-SEP-23	2.130	ug/L
55055	55055-1-101-BF01	Room 101 Bottle Filler	Initial	27-SEP-23	2.350	ug/L
55055	55055-1-102-BF01	Room 102 Bottle Filler	Flush180	27-SEP-23	1.000	ug/L
55055	55055-1-102-BF01	Room 102 Bottle Filler	Flush180	27-SEP-23	1.000	ug/L
55055	55055-1-102-BF01	Room 102 Bottle Filler	Flush180	27-SEP-23	1.000	ug/L
55055	55055-1-102-BF01	Room 102 Bottle Filler	Flush180	27-SEP-23	1.000	ug/L
55055	55055-1-102-BF01	Room 102 Bottle Filler	Initial	27-SEP-23	1.000	ug/L
55055	55055-1-102-F01	Room 102 Fountain	Flush180	27-SEP-23	1.540	ug/L
55055	55055-1-102-F01	Room 102 Fountain	Flush180	27-SEP-23	2.700	ug/L
55055	55055-1-102-F01	Room 102 Fountain	Flush180	27-SEP-23	4.110	ug/L
55055	55055-1-102-F01	Room 102 Fountain	Flush180	27-SEP-23	1.250	ug/L
55055	55055-1-102-F01	Room 102 Fountain	Initial	27-SEP-23	9.530	ug/L
55055	55055-1-202-S01	Sink,left(tall), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S01	Sink,left(tall), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S01	Sink,left(tall), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S01	Sink,left(tall), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S01	Sink,left(tall), Rm 202	Initial	21-DEC-21	2.200	ug/L
55055	55055-1-203-S01	Sink,left(tall), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S01	Sink,left(tall), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S01	Sink,left(tall), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S01	Sink,left(tall), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S01	Sink,left(tall), Rm 203	Initial	21-DEC-21	2.170	ug/L
55055	55055-1-204-S01	Sink,left(tall), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S01	Sink,left(tall), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S01	Sink,left(tall), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S01	Sink,left(tall), Rm 204	Initial	21-DEC-21	1.600	ug/L
55055	55055-1-STU-S01	Sink,left(tall), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S01	Sink,left(tall), Studio Room	Flush180	21-DEC-21	1.000	ug/L

Water Quality Assessment Barbara Vick Early Childhood & Family Center

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
55055	55055-1-STU-S01	Sink,left(tall), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S01	Sink,left(tall), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S01	Sink,left(tall), Studio Room	Initial	21-DEC-21	3.420	ug/L
55055	55055-1-205-S01	Sink,left(tall), rm 205	Flush180	21-DEC-21	2.210	ug/L
55055	55055-1-205-S01	Sink,left(tall), rm 205	Flush180	21-DEC-21	1.180	ug/L
55055	55055-1-205-S01	Sink,left(tall), rm 205	Flush180	21-DEC-21	1.020	ug/L
55055	55055-1-205-S01	Sink,left(tall), rm 205	Flush180	21-DEC-21	1.240	ug/L
55055	55055-1-205-S01	Sink,left(tall), rm 205	Initial	21-DEC-21	4.090	ug/L
55055	55055-1-206-S01	Sink,left(tall), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S01	Sink,left(tall), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S01	Sink,left(tall), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S01	Sink,left(tall), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S01	Sink,left(tall), rm 206	Initial	21-DEC-21	1.510	ug/L
55055	55055-1-202-S02	Sink,right (low), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S02	Sink,right (low), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S02	Sink,right (low), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S02	Sink,right (low), Rm 202	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-202-S02	Sink,right (low), Rm 202	Initial	21-DEC-21	2.920	ug/L
55055	55055-1-203-S02	Sink,right (low), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S02	Sink,right (low), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S02	Sink,right (low), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S02	Sink,right (low), Rm 203	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-203-S02	Sink,right (low), Rm 203	Initial	21-DEC-21	2.260	ug/L
55055	55055-1-204-S02	Sink,right (low), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S02	Sink,right (low), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S02	Sink,right (low), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S02	Sink,right (low), Rm 204	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-204-S02	Sink,right (low), Rm 204	Initial	21-DEC-21	1.690	ug/L
55055	55055-1-STU-S02	Sink,right (low), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S02	Sink,right (low), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S02	Sink,right (low), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S02	Sink,right (low), Studio Room	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-STU-S02	Sink,right (low), Studio Room	Initial	21-DEC-21	3.950	ug/L
55055	55055-1-205-S02	Sink,right (low), rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-S02	Sink,right (low), rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-S02	Sink,right (low), rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-S02	Sink,right (low), rm 205	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-205-S02	Sink,right (low), rm 205	Initial	21-DEC-21	3.200	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S02					
55055	55055-1-206-S02	Sink,right (low), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S02	Sink,right (low), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S02	Sink,right (low), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S02	Sink,right (low), rm 206	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-206-S02	Sink,right (low), rm 206	Initial	21-DEC-21	2.890	ug/L
55055	55055-1-HAL-F02	center fountain b/t Restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F02	center fountain b/t Restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F02	center fountain b/t Restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F02	center fountain b/t Restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F02	center fountain b/t Restrooms	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-BF01	left Bottle Filler b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-BF01	left Bottle Filler b/t restrooms	Flush180	21-DEC-21	1.050	ug/L
55055	55055-1-HAL-BF01	left Bottle Filler b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-BF01	left Bottle Filler b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-BF01	left Bottle Filler b/t restrooms	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F01	left fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F01	left fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F01	left fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F01	left fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F01	left fountain b/t restrooms	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F03	right fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F03	right fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F03	right fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F03	right fountain b/t restrooms	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-HAL-F03	right fountain b/t restrooms	Initial	21-DEC-21	1.000	ug/L
55055	55055-1-FAC-S01	sink inside faculty rm	Flush180	21-DEC-21	1.090	ug/L
55055	55055-1-FAC-S01	sink inside faculty rm	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-FAC-S01	sink inside faculty rm	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-FAC-S01	sink inside faculty rm	Flush180	21-DEC-21	1.000	ug/L
55055	55055-1-FAC-S01	sink inside faculty rm	Initial	21-DEC-21	1.120	ug/L