



Sep 10, 2024

VON STEUBEN HS

5039 N KIMBALL AVE, Chicago IL 60625.

Dear **VON STEUBEN HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

VON STEUBEN HS

5039 N KIMBALL AVE, Chicago IL 60625.

Estimadas familias de **VON STEUBEN HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Initial	28-APR-21	1.000	ug/L
51541	51541-1-HAL-BF01	1st floor, outside Women's Restroom	Initial	22-JAN-21	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Flush180	23-DEC-20	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Initial	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F01	3RD FLOOR SOUTHEAST HALL	Initial	23-DEC-20	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Initial	28-APR-21	1.000	ug/L
51541	51541-3-CAF-BF01	3rd floor, Cafeteria	Initial	22-JAN-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Flush180	22-JAN-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Initial	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF01	3rd floor, outside Women's Restroom	Initial	22-JAN-21	1.000	ug/L
51541	51541-1-HAL-F12	By 126-127	Flush180	28-APR-21	4.340	ug/L
51541	51541-1-HAL-F12	By 126-127	Flush180	28-APR-21	1.230	ug/L
51541	51541-1-HAL-F12	By 126-127	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F12	By 126-127	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F13	By 126-127	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F13	By 126-127	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F13	By 126-127	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F13	By 126-127	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F12	By 126-127	Initial	28-APR-21	2.300	ug/L
51541	51541-1-HAL-F13	By 126-127	Initial	28-APR-21	2.840	ug/L
51541	51541-2-HAL-F09	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F09	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F10	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F10	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F10	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F10	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F10	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-BF01	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-BF01	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-BF01	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-BF01	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F09	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F09	By east women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F10	By east women's bathroom	Initial	28-APR-21	1.000	ug/L
51541	51541-2-HAL-BF01	By east women's bathroom	Initial	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F09	By east women's bathroom	Initial	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	28-APR-21	9.090	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F09	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F09	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F09	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F09	By room 104	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	21-JUL-23	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	21-JUL-23	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51541	51541-1-HAL-F08	By room 104	Flush180	21-JUL-23	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Flush180	21-JUL-23	1.000	ug/L
51541	51541-1-HAL-F08	By room 104	Initial	28-APR-21	5.640	ug/L
51541	51541-1-HAL-F09	By room 104	Initial	28-APR-21	2.720	ug/L
51541	51541-1-HAL-F08	By room 104	Initial	21-JUL-23	1.000	ug/L
51541	51541-1-HAL-F11	By room 117-118	Flush180	28-APR-21	1.380	ug/L
51541	51541-1-HAL-F11	By room 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F11	By room 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F11	By room 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F11	By room 117-118	Initial	28-APR-21	2.970	ug/L
51541	51541-2-HAL-F01	By room 204	Flush180	28-APR-21	2.140	ug/L
51541	51541-2-HAL-F01	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F01	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F01	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F02	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F02	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F02	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F02	By room 204	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F02	By room 204	Initial	28-APR-21	1.980	ug/L
51541	51541-2-HAL-F01	By room 204	Initial	28-APR-21	1.660	ug/L
51541	51541-1-HAL-F10	By rooms 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F10	By rooms 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F10	By rooms 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F10	By rooms 117-118	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F10	By rooms 117-118	Initial	28-APR-21	2.360	ug/L
51541	51541-2-HAL-F04	By west Women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F04	By west Women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F04	By west Women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F04	By west Women's bathroom	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F04	By west Women's bathroom	Initial	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F03	By west Women's room	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F03	By west Women's room	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F03	By west Women's room	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F03	By west Women's room	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F03	By west Women's room	Initial	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F02	Corridor Across From Room 203, Fountain	Flush180	17-NOV-16	0.723	ppb
51541	51541-2-HAL-F02	Corridor Across From Room 203, Fountain	Flush180	17-NOV-16	647.000	ppb
51541	51541-2-HAL-	Corridor Across From Room 203,	Flush180	17-NOV-16	0.544	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F02	Fountain				
51541	51541-2-HAL-F02	Corridor Across From Room 203, Fountain	Flush180	17-NOV-16	0.676	ppb
51541	51541-2-HAL-F02	Corridor Across From Room 203, Fountain	Initial	17-NOV-16	0.827	ppb
51541	51541-2-HAL-F01	Corridor Across From Room 205, Fountain	Flush180	17-NOV-16	1.000	ppb
51541	51541-2-HAL-F01	Corridor Across From Room 205, Fountain	Flush180	17-NOV-16	1.000	ppb
51541	51541-2-HAL-F01	Corridor Across From Room 205, Fountain	Flush180	17-NOV-16	1.000	ppb
51541	51541-2-HAL-F01	Corridor Across From Room 205, Fountain	Flush180	17-NOV-16	1.000	ppb
51541	51541-2-HAL-F01	Corridor Across From Room 205, Fountain	Initial	17-NOV-16	0.330	ppb
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	23-NOV-16	0.250	ppb
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	23-NOV-16	0.260	ppb
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	23-NOV-16	0.230	ppb
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	23-NOV-16	0.250	ppb
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Initial	23-NOV-16	0.280	ppb
51541	51541-3-307A-KS04	Kitchen 2 Compartment Left Sink	Initial	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	23-NOV-16	0.210	ppb
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	23-NOV-16	0.300	ppb
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	23-NOV-16	0.210	ppb
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	23-NOV-16	0.250	ppb
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Initial	23-NOV-16	0.370	ppb
51541	51541-3-307A-KS05	Kitchen 2 Compartment Right Sink	Initial	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	23-NOV-16	0.190	ppb
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	23-NOV-16	0.160	ppb
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	23-NOV-16	0.220	ppb
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	23-NOV-16	1.000	ppb
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS02	Kitchen 3 Compartment Middle Sink	Initial	23-NOV-16	0.380	ppb
51541	51541-3-	Kitchen 3 Compartment Middle	Initial	28-APR-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	307A-KS02	Sink				
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	23-NOV-16	0.280	ppb
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	23-NOV-16	0.270	ppb
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	23-NOV-16	0.270	ppb
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	23-NOV-16	0.250	ppb
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	28-APR-21	5.390	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	28-APR-21	1.010	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	21-JUL-23	1.000	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	21-JUL-23	1.000	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	21-JUL-23	1.000	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Flush180	21-JUL-23	1.000	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Initial	23-NOV-16	0.580	ppb
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Initial	28-APR-21	1.950	ug/L
51541	51541-3-307A-KS03	Kitchen 3 Compartment Right Sink	Initial	21-JUL-23	1.000	ug/L
51541	51541-3-307A-KS06	Kitchen Left Faucet Across Stove	Flush180	23-NOV-16	1.000	ppb
51541	51541-3-307A-KS06	Kitchen Left Faucet Across Stove	Flush180	23-NOV-16	1.000	ppb
51541	51541-3-307A-KS06	Kitchen Left Faucet Across Stove	Flush180	23-NOV-16	0.220	ppb
51541	51541-3-307A-KS06	Kitchen Left Faucet Across Stove	Flush180	23-NOV-16	1.000	ppb
51541	51541-3-307A-KS06	Kitchen Left Faucet Across Stove	Initial	23-NOV-16	1.000	ppb
51541	51541-3-307A-KS07	Kitchen Right Faucet Across Stove	Flush180	23-NOV-16	0.410	ppb
51541	51541-3-307A-KS07	Kitchen Right Faucet Across Stove	Flush180	23-NOV-16	0.460	ppb
51541	51541-3-307A-KS07	Kitchen Right Faucet Across Stove	Flush180	23-NOV-16	0.450	ppb
51541	51541-3-307A-KS07	Kitchen Right Faucet Across Stove	Flush180	23-NOV-16	0.460	ppb
51541	51541-3-307A-KS07	Kitchen Right Faucet Across Stove	Initial	23-NOV-16	0.590	ppb
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	23-NOV-16	0.330	ppb
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	23-NOV-16	0.250	ppb
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	23-NOV-16	0.310	ppb
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	23-NOV-16	0.270	ppb
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Initial	23-NOV-16	0.230	ppb
51541	51541-3-307A-KS01	Kitchen Sink 3 Compartments Left Sink	Initial	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush	13-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Initial	23-NOV-16	0.600	ppb
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Initial	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F03	Left Fountain next to Rm 108	Initial	13-DEC-2023	1.000	ug/L
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	23-NOV-16	2.000	ppb
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	23-NOV-16	1.300	ppb
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	23-NOV-16	3.100	ppb
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	23-NOV-16	2.600	ppb
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F11	Next to Girls gym Left	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F11	Next to Girls gym Left	Initial	23-NOV-16	3.100	ppb
51541	51541-2-HAL-F11	Next to Girls gym Left	Initial	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	23-NOV-16	1.500	ppb
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	23-NOV-16	0.970	ppb
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	23-NOV-16	0.670	ppb
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	23-NOV-16	0.560	ppb
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F12	Next to Girls gym Right	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F12	Next to Girls gym Right	Initial	23-NOV-16	1.800	ppb
51541	51541-2-HAL-F12	Next to Girls gym Right	Initial	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	23-NOV-16	2.300	ppb
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	23-NOV-16	7.300	ppb
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	23-NOV-16	3.400	ppb
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	28-APR-21	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Initial	23-NOV-16	8.100	ppb
51541	51541-1-HAL-F06	Next to RM 111 Left Fountain	Initial	28-APR-21	1.890	ug/L
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	23-NOV-16	0.570	ppb
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	23-NOV-16	0.370	ppb
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	23-NOV-16	1.500	ppb
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	28-APR-21	1.680	ug/L
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	28-APR-21	1.430	ug/L
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Initial	23-NOV-16	0.600	ppb
51541	51541-1-HAL-F05	Next to RM 111 Right Fountain	Initial	28-APR-21	1.740	ug/L
51541	51541-B-HAL-F01	Outside Basement Kitchen (North), Fountain 1	Flush180	17-NOV-16	3.380	ppb
51541	51541-B-HAL-F01	Outside Basement Kitchen (North), Fountain 1	Flush180	17-NOV-16	4.620	ppb
51541	51541-B-HAL-F01	Outside Basement Kitchen (North), Fountain 1	Flush180	17-NOV-16	3.590	ppb
51541	51541-B-HAL-F01	Outside Basement Kitchen (North), Fountain 1	Flush180	17-NOV-16	3.270	ppb
51541	51541-B-HAL-F01	Outside Basement Kitchen (North), Fountain 1	Initial	17-NOV-16	2.540	ppb
51541	51541-B-HAL-F04	Outside EGINEERS Office (North), Fountain 1	Flush180	17-NOV-16	1.320	ppb
51541	51541-B-HAL-F04	Outside EGINEERS Office (North), Fountain 1	Flush180	17-NOV-16	1.430	ppb
51541	51541-B-HAL-F04	Outside EGINEERS Office (North), Fountain 1	Flush180	17-NOV-16	1.160	ppb
51541	51541-B-HAL-F04	Outside EGINEERS Office (North), Fountain 1	Flush180	17-NOV-16	1.090	ppb
51541	51541-B-HAL-F04	Outside EGINEERS Office (North), Fountain 1	Initial	17-NOV-16	4.630	ppb
51541	51541-2-HAL-F05	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F05	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F05	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F05	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F06	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F06	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F06	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F06	Outside RM 211	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F05	Outside RM 211	Initial	28-APR-21	1.330	ug/L
51541	51541-2-HAL-F06	Outside RM 211	Initial	28-APR-21	1.550	ug/L
51541	51541-3-HAL-BF02	Outside room 320	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF02	Outside room 320	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-	Outside room 320	Flush180	28-APR-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF02					
51541	51541-3-HAL-BF02	Outside room 320	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-BF02	Outside room 320	Initial	28-APR-21	1.000	ug/L
51541	51541-4-HAL-F03	Outside room 419	Flush180	28-APR-21	3.050	ug/L
51541	51541-4-HAL-F03	Outside room 419	Flush180	28-APR-21	3.000	ug/L
51541	51541-4-HAL-F03	Outside room 419	Flush180	28-APR-21	2.870	ug/L
51541	51541-4-HAL-F03	Outside room 419	Flush180	28-APR-21	3.020	ug/L
51541	51541-4-HAL-F03	Outside room 419	Initial	28-APR-21	2.920	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush	13-DEC-2023	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	23-NOV-16	0.170	ppb
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Flush180	23-DEC-20	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Initial	23-NOV-16	1.000	ppb
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Initial	28-APR-21	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Initial	23-DEC-20	1.000	ug/L
51541	51541-1-HAL-F04	Right Fountain next to RM 108	Initial	13-DEC-2023	1.000	ug/L
51541	51541-3-HAL-F02	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F02	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F02	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F02	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F03	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F03	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F03	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F03	outside 304	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F02	outside 304	Initial	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F03	outside 304	Initial	28-APR-21	1.050	ug/L
51541	51541-3-HAL-F04	outside 313	Flush180	28-APR-21	1.980	ug/L
51541	51541-3-HAL-F04	outside 313	Flush180	28-APR-21	1.280	ug/L
51541	51541-3-HAL-	outside 313	Flush180	28-APR-21	1.300	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51541	51541-3-HAL-F04	outside 313	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F04	outside 313	Initial	28-APR-21	1.920	ug/L
51541	51541-3-HAL-F05	outside 317	Flush180	28-APR-21	1.410	ug/L
51541	51541-3-HAL-F05	outside 317	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F05	outside 317	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F05	outside 317	Flush180	28-APR-21	1.000	ug/L
51541	51541-3-HAL-F06	outside 317	Flush180	28-APR-21	2.630	ug/L
51541	51541-3-HAL-F06	outside 317	Flush180	28-APR-21	1.680	ug/L
51541	51541-3-HAL-F06	outside 317	Flush180	28-APR-21	1.270	ug/L
51541	51541-3-HAL-F06	outside 317	Flush180	28-APR-21	1.190	ug/L
51541	51541-3-HAL-F05	outside 317	Initial	28-APR-21	1.460	ug/L
51541	51541-3-HAL-F06	outside 317	Initial	28-APR-21	3.290	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	28-APR-21	5.060	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	28-APR-21	2.780	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	28-APR-21	2.100	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	28-APR-21	2.150	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	21-JUL-23	1.000	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	21-JUL-23	1.000	ug/L
51541	51541-4-HAL-F02	outside 419	Flush180	21-JUL-23	1.000	ug/L
51541	51541-4-HAL-F02	outside 419	Initial	28-APR-21	4.050	ug/L
51541	51541-4-HAL-F02	outside 419	Initial	21-JUL-23	1.000	ug/L
51541	51541-2-HAL-F07	outside RM 215	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F07	outside RM 215	Flush180	28-APR-21	4.090	ug/L
51541	51541-2-HAL-F07	outside RM 215	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F07	outside RM 215	Flush180	28-APR-21	2.470	ug/L
51541	51541-2-HAL-F08	outside RM 215	Flush180	28-APR-21	2.470	ug/L
51541	51541-2-HAL-F08	outside RM 215	Flush180	28-APR-21	2.090	ug/L
51541	51541-2-HAL-F08	outside RM 215	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F08	outside RM 215	Flush180	28-APR-21	1.000	ug/L
51541	51541-2-HAL-F07	outside RM 215	Initial	28-APR-21	1.380	ug/L
51541	51541-2-HAL-F08	outside RM 215	Initial	28-APR-21	4.000	ug/L
51541	51541-4-HAL-F01	outside room 413	Flush180	28-APR-21	3.250	ug/L
51541	51541-4-HAL-F01	outside room 413	Flush180	28-APR-21	2.150	ug/L
51541	51541-4-HAL-F01	outside room 413	Flush180	28-APR-21	1.760	ug/L
51541	51541-4-HAL-F01	outside room 413	Flush180	28-APR-21	2.010	ug/L
51541	51541-4-HAL-F01	outside room 413	Initial	28-APR-21	3.040	ug/L

