



Sep 10, 2024

WASHINGTON H ES

9130 S UNIVERSITY AVE, Chicago IL 60619.

Dear **WASHINGTON H ES** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WASHINGTON H ES

9130 S UNIVERSITY AVE, Chicago IL 60619.

Estimadas familias de **WASHINGTON H ES**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51476	51476-1-HAL-F06	Main Building- 1st Floor Adjacent to Lunch Room Ce	Flush180	14-SEP-16	0.461	ppb
51476	51476-1-HAL-F06	Main Building- 1st Floor Adjacent to Lunch Room Ce	Flush180	14-SEP-16	0.406	ppb
51476	51476-1-HAL-F06	Main Building- 1st Floor Adjacent to Lunch Room Ce	Flush180	14-SEP-16	0.409	ppb
51476	51476-1-HAL-F06	Main Building- 1st Floor Adjacent to Lunch Room Ce	Flush180	14-SEP-16	0.349	ppb
51476	51476-1-HAL-F06	Main Building- 1st Floor Adjacent to Lunch Room Ce	Initial	14-SEP-16	0.572	ppb
51476	51476-1-HAL-F05	Main Building- 1st Floor Adjacent to Lunch Room Ri	Flush180	14-SEP-16	0.359	ppb
51476	51476-1-HAL-F05	Main Building- 1st Floor Adjacent to Lunch Room Ri	Flush180	14-SEP-16	0.443	ppb
51476	51476-1-HAL-F05	Main Building- 1st Floor Adjacent to Lunch Room Ri	Flush180	14-SEP-16	0.388	ppb
51476	51476-1-HAL-F05	Main Building- 1st Floor Adjacent to Lunch Room Ri	Flush180	14-SEP-16	0.492	ppb
51476	51476-1-HAL-F05	Main Building- 1st Floor Adjacent to Lunch Room Ri	Initial	14-SEP-16	0.623	ppb
51476	51476-1-KIT-KS08	Main Building- 1st Floor Kitchen Left, Sink	Flush180	14-SEP-16	0.476	ppb
51476	51476-1-KIT-KS08	Main Building- 1st Floor Kitchen Left, Sink	Flush180	14-SEP-16	0.320	ppb
51476	51476-1-KIT-KS08	Main Building- 1st Floor Kitchen Left, Sink	Flush180	14-SEP-16	0.313	ppb
51476	51476-1-KIT-KS08	Main Building- 1st Floor Kitchen Left, Sink	Flush180	14-SEP-16	0.827	ppb
51476	51476-1-KIT-KS08	Main Building- 1st Floor Kitchen Left, Sink	Initial	14-SEP-16	1.730	ppb
51476	51476-1-KIT-KS09	Main Building- 1st Floor Kitchen Right, Sink	Flush180	14-SEP-16	1.200	ppb
51476	51476-1-KIT-KS09	Main Building- 1st Floor Kitchen Right, Sink	Flush180	14-SEP-16	1.330	ppb
51476	51476-1-KIT-KS09	Main Building- 1st Floor Kitchen Right, Sink	Flush180	14-SEP-16	0.637	ppb
51476	51476-1-KIT-KS09	Main Building- 1st Floor Kitchen Right, Sink	Flush180	14-SEP-16	1.010	ppb
51476	51476-1-KIT-KS09	Main Building- 1st Floor Kitchen Right, Sink	Initial	14-SEP-16	1.200	ppb
51476	51476-1-111-F03	Main Building- 1st floor Inside Room 111, Fountain	Flush180	14-SEP-16	0.955	ppb
51476	51476-1-111-F03	Main Building- 1st floor Inside Room 111, Fountain	Flush180	14-SEP-16	0.837	ppb
51476	51476-1-111-F03	Main Building- 1st floor Inside Room 111, Fountain	Flush180	14-SEP-16	0.815	ppb
51476	51476-1-111-F03	Main Building- 1st floor Inside Room 111, Fountain	Flush180	14-SEP-16	0.634	ppb
51476	51476-1-111-F03	Main Building- 1st floor Inside Room 111, Fountain	Initial	14-SEP-16	0.572	ppb
51476	51476-1-111-S04	Main Building- 1st floor Inside Room 111, Sink	Flush180	14-SEP-16	0.703	ppb
51476	51476-1-111-S04	Main Building- 1st floor Inside Room 111, Sink	Flush180	14-SEP-16	0.544	ppb
51476	51476-1-111-S04	Main Building- 1st floor Inside Room 111, Sink	Flush180	14-SEP-16	0.601	ppb
51476	51476-1-111-S04	Main Building- 1st floor Inside Room 111, Sink	Flush180	14-SEP-16	0.683	ppb
51476	51476-1-111-S04	Main Building- 1st floor Inside Room 111, Sink	Initial	14-SEP-16	1.030	ppb
51476	51476-1-HAL-F02	Main Building- 1st floor Next to Room 105 Left, Fo	Flush180	14-SEP-16	0.406	ppb
51476	51476-1-HAL-F02	Main Building- 1st floor Next to Room 105 Left, Fo	Flush180	14-SEP-16	0.445	ppb
51476	51476-1-HAL-F02	Main Building- 1st floor Next to Room 105 Left, Fo	Flush180	14-SEP-16	0.426	ppb
51476	51476-1-HAL-F02	Main Building- 1st floor Next to Room 105 Left, Fo	Flush180	14-SEP-16	0.342	ppb
51476	51476-1-HAL-F02	Main Building- 1st floor Next to Room 105 Left, Fo	Initial	14-SEP-16	0.428	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51476	51476-1-HAL-F01	Main Building- 1st floor Next to Room 105 Right, F	Flush180	14-SEP-16	1.040	ppb
51476	51476-1-HAL-F01	Main Building- 1st floor Next to Room 105 Right, F	Flush180	14-SEP-16	0.945	ppb
51476	51476-1-HAL-F01	Main Building- 1st floor Next to Room 105 Right, F	Flush180	14-SEP-16	0.418	ppb
51476	51476-1-HAL-F01	Main Building- 1st floor Next to Room 105 Right, F	Flush180	14-SEP-16	0.383	ppb
51476	51476-1-HAL-F01	Main Building- 1st floor Next to Room 105 Right, F	Initial	14-SEP-16	4.060	ppb
51476	51476-3-HAL-F04	Main Building- 3rd floor Adjacent to Room 312 Left	Flush180	14-SEP-16	0.642	ppb
51476	51476-3-HAL-F04	Main Building- 3rd floor Adjacent to Room 312 Left	Flush180	14-SEP-16	0.805	ppb
51476	51476-3-HAL-F04	Main Building- 3rd floor Adjacent to Room 312 Left	Flush180	14-SEP-16	0.494	ppb
51476	51476-3-HAL-F04	Main Building- 3rd floor Adjacent to Room 312 Left	Flush180	14-SEP-16	1.080	ppb
51476	51476-3-HAL-F04	Main Building- 3rd floor Adjacent to Room 312 Left	Initial	14-SEP-16	2.100	ppb
51476	51476-3-HAL-F03	Main Building- 3rd floor Adjacent to Room 312 Righ	Flush180	14-SEP-16	1.390	ppb
51476	51476-3-HAL-F03	Main Building- 3rd floor Adjacent to Room 312 Righ	Flush180	14-SEP-16	1.000	ppb
51476	51476-3-HAL-F03	Main Building- 3rd floor Adjacent to Room 312 Righ	Flush180	14-SEP-16	1.600	ppb
51476	51476-3-HAL-F03	Main Building- 3rd floor Adjacent to Room 312 Righ	Flush180	14-SEP-16	1.100	ppb
51476	51476-3-HAL-F03	Main Building- 3rd floor Adjacent to Room 312 Righ	Initial	14-SEP-16	1.210	ppb
51476	51476-3-HAL-F01	Main Building- 3rd floor By Room 305 Right, Founta	Flush180	14-SEP-16	1.960	ppb
51476	51476-3-HAL-F01	Main Building- 3rd floor By Room 305 Right, Founta	Flush180	14-SEP-16	1.060	ppb
51476	51476-3-HAL-F01	Main Building- 3rd floor By Room 305 Right, Founta	Flush180	14-SEP-16	3.370	ppb
51476	51476-3-HAL-F01	Main Building- 3rd floor By Room 305 Right, Founta	Flush180	14-SEP-16	0.606	ppb
51476	51476-3-HAL-F01	Main Building- 3rd floor By Room 305 Right, Founta	Initial	14-SEP-16	2.330	ppb