



Sep 10, 2024

**WASHINGTON HS**

**3535 E 114TH ST, Chicago IL 60617.**

Dear **WASHINGTON HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**WASHINGTON HS**

**3535 E 114TH ST, Chicago IL 60617.**

Estimadas familias de **WASHINGTON HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que iguallen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51633	51633-1-HAL-RBF04	Main- Across From Main Office, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF04	Main- Across From Main Office, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF04	Main- Across From Main Office, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF04	Main- Across From Main Office, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F04	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	0.266	ppb
51633	51633-1-HAL-F04	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	0.269	ppb
51633	51633-1-HAL-F04	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	0.280	ppb
51633	51633-1-HAL-F04	Main- Across From Main Office, Left Fountain	Flush180	28-SEP-16	0.275	ppb
51633	51633-1-HAL-RBF04	Main- Across From Main Office, Left Fountain	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F04	Main- Across From Main Office, Left Fountain	Initial	28-SEP-16	0.314	ppb
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	0.774	ppb
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	0.669	ppb
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	0.555	ppb
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Flush180	28-SEP-16	0.419	ppb
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F03	Main- Across From Main Office, Right Fountain	Initial	28-SEP-16	0.600	ppb
51633	51633-1-HAL-RBF02	Main- Across From Room 123, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF02	Main- Across From Room 123, Left Fountain	Flush180	25-MAY-23	1.540	ug/L
51633	51633-1-HAL-RBF02	Main- Across From Room 123, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF02	Main- Across From Room 123, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F12	Main- Across From Room 123, Left Fountain	Flush180	28-SEP-16	1.350	ppb
51633	51633-1-HAL-F12	Main- Across From Room 123, Left Fountain	Flush180	28-SEP-16	1.670	ppb
51633	51633-1-HAL-F12	Main- Across From Room 123, Left Fountain	Flush180	28-SEP-16	1.230	ppb
51633	51633-1-HAL-F12	Main- Across From Room 123, Left Fountain	Flush180	28-SEP-16	1.220	ppb
51633	51633-1-HAL-RBF02	Main- Across From Room 123, Left Fountain	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F12	Main- Across From Room 123, Left Fountain	Initial	28-SEP-16	2.570	ppb
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	28-SEP-16	1.320	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	28-SEP-16	1.530	ppb
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	28-SEP-16	1.280	ppb
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Flush180	28-SEP-16	1.250	ppb
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Initial	25-MAY-23	1.210	ug/L
51633	51633-1-HAL-F11	Main- Across From Room 123, Right Fountain	Initial	28-SEP-16	2.280	ppb
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	25-MAY-23	1.840	ug/L
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	25-MAY-23	1.740	ug/L
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	25-MAY-23	1.280	ug/L
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	28-SEP-16	2.450	ppb
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	28-SEP-16	0.658	ppb
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	28-SEP-16	2.400	ppb
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Flush180	28-SEP-16	1.340	ppb
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Initial	25-MAY-23	2.360	ug/L
51633	51633-1-HAL-F09	Main- Across From Room 127, Right Fountain	Initial	28-SEP-16	3.180	ppb
51633	51633-1-HAL-F02	Main- Across From Room 135, Left Fountain	Flush180	28-SEP-16	0.657	ppb
51633	51633-1-HAL-F02	Main- Across From Room 135, Left Fountain	Flush180	28-SEP-16	0.691	ppb
51633	51633-1-HAL-F02	Main- Across From Room 135, Left Fountain	Flush180	28-SEP-16	0.506	ppb
51633	51633-1-HAL-F02	Main- Across From Room 135, Left Fountain	Flush180	28-SEP-16	0.540	ppb
51633	51633-1-HAL-F02	Main- Across From Room 135, Left Fountain	Initial	28-SEP-16	1.780	ppb
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	28-SEP-16	0.577	ppb
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	28-SEP-16	0.715	ppb
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	28-SEP-16	1.820	ppb
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Flush180	28-SEP-16	0.601	ppb
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F01	Main- Across From Room 135, Right Fountain	Initial	28-SEP-16	1.970	ppb
51633	51633-1-HAL-RBF03	Main- Across From Room 135, Right Retrofitted BF	Flush180	25-MAY-23	1.660	ug/L
51633	51633-1-HAL-RBF03	Main- Across From Room 135, Right Retrofitted BF	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF03	Main- Across From Room 135, Right Retrofitted BF	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF03	Main- Across From Room 135, Right Retrofitted BF	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF03	Main- Across From Room 135, Right Retrofitted BF	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	25-MAY-23	4.880	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	25-MAY-23	6.340	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	25-MAY-23	6.080	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	25-MAY-23	5.380	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	18-JUL-23	3.740	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	18-JUL-23	3.510	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	18-JUL-23	3.760	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	18-JUL-23	3.430	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	28-SEP-16	4.660	ppb
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	28-SEP-16	5.200	ppb
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	28-SEP-16	5.050	ppb
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	28-SEP-16	4.880	ppb
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	15-DEC-20	2.550	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	26-APR-23	3.690	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	26-APR-23	3.420	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	26-APR-23	3.560	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Flush180	26-APR-23	3.080	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Initial	25-MAY-23	4.470	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Initial	18-JUL-23	4.720	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Initial	28-SEP-16	4.560	ppb
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Initial	15-DEC-20	2.770	ug/L
51633	51633-1-HAL-F20	Main- Across From Room 138, Fountain	Initial	26-APR-23	4.190	ug/L
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	25-MAY-23	1.530	ug/L
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	25-MAY-23	1.940	ug/L
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	28-SEP-16	1.290	ppb
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	28-SEP-16	3.160	ppb
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	28-SEP-16	1.830	ppb
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Flush180	28-SEP-16	0.978	ppb
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Initial	25-MAY-23	1.850	ug/L
51633	51633-2-HAL-F01	Main- Across From Room 200, Left Fountain	Initial	28-SEP-16	3.790	ppb
51633	51633-2-HAL-F02	Main- Across From Room 200, Right Fountain	Flush180	28-SEP-16	2.830	ppb
51633	51633-2-HAL-F02	Main- Across From Room 200, Right Fountain	Flush180	28-SEP-16	2.210	ppb
51633	51633-2-HAL-F02	Main- Across From Room 200, Right Fountain	Flush180	28-SEP-16	2.840	ppb
51633	51633-2-HAL-F02	Main- Across From Room 200, Right Fountain	Flush180	28-SEP-16	1.820	ppb
51633	51633-2-HAL-F02	Main- Across From Room 200, Right Fountain	Initial	28-SEP-16	0.839	ppb
51633	51633-2-HAL-F03	Main- Across From Room 219, Right Fountain	Flush180	28-SEP-16	1.230	ppb
51633	51633-2-HAL-F03	Main- Across From Room 219, Right Fountain	Flush180	28-SEP-16	1.280	ppb
51633	51633-2-HAL-	Main- Across From Room 219,	Flush180	28-SEP-16	1.440	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Right Fountain				
51633	51633-2-HAL-F03	Main- Across From Room 219, Right Fountain	Flush180	28-SEP-16	1.140	ppb
51633	51633-2-HAL-F03	Main- Across From Room 219, Right Fountain	Initial	28-SEP-16	2.220	ppb
51633	51633-2-HAL-RBF01	Main- Across From Room 219, Right Retrofitted Bottle Filler	Flush180	25-MAY-23	2.040	ug/L
51633	51633-2-HAL-RBF01	Main- Across From Room 219, Right Retrofitted Bottle Filler	Flush180	25-MAY-23	2.320	ug/L
51633	51633-2-HAL-RBF01	Main- Across From Room 219, Right Retrofitted Bottle Filler	Flush180	25-MAY-23	2.130	ug/L
51633	51633-2-HAL-RBF01	Main- Across From Room 219, Right Retrofitted Bottle Filler	Flush180	25-MAY-23	2.250	ug/L
51633	51633-2-HAL-RBF01	Main- Across From Room 219, Right Retrofitted Bottle Filler	Initial	25-MAY-23	1.320	ug/L
51633	51633-1-HAL-RBF05	Main- Adjacent to Girls Washroom, Retrofitted Bottle Filler	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF05	Main- Adjacent to Girls Washroom, Retrofitted Bottle Filler	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF05	Main- Adjacent to Girls Washroom, Retrofitted Bottle Filler	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF05	Main- Adjacent to Girls Washroom, Retrofitted Bottle Filler	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	25-MAY-23	1.210	ug/L
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	28-SEP-16	1.510	ppb
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	28-SEP-16	0.843	ppb
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	28-SEP-16	0.373	ppb
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Flush180	28-SEP-16	1.550	ppb
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Initial	25-MAY-23	1.140	ug/L
51633	51633-1-HAL-F17	Main- Adjacent to Girls Washroom, Right Fountain	Initial	28-SEP-16	1.150	ppb
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	25-MAY-23	2.400	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	25-MAY-23	2.870	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	25-MAY-23	2.400	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	25-MAY-23	2.900	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	28-SEP-16	5.030	ppb
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	28-SEP-16	4.410	ppb
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	28-SEP-16	4.370	ppb
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	28-SEP-16	4.240	ppb
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	26-APR-23	2.520	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	26-APR-23	2.390	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	26-APR-23	2.370	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Flush180	26-APR-23	2.350	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Initial	25-MAY-23	2.720	ug/L
51633	51633-1-GYM-F15	Main- Boys Gym, Fountain	Initial	28-SEP-16	5.730	ppb
51633	51633-1-	Main- Boys Gym, Fountain	Initial	26-APR-23	2.540	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	GYM-F15					
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	28-SEP-16	30.400	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	28-SEP-16	8.210	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	28-SEP-16	8.130	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	28-SEP-16	15.300	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	17-NOV-16	2.000	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Flush180	26-APR-23	1.010	ug/L
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Initial	28-SEP-16	108.000	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Initial	17-NOV-16	2.100	ppb
51633	51633-1-KIT-KS27	Main- Kitchen, Center Meat Cleaning Sink	Initial	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	28-SEP-16	1.130	ppb
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	28-SEP-16	1.230	ppb
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	28-SEP-16	1.360	ppb
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Flush180	28-SEP-16	1.070	ppb
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Initial	25-MAY-23	1.050	ug/L
51633	51633-1-KIT-KS28	Main- Kitchen, Center North Sink	Initial	28-SEP-16	2.340	ppb
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	28-SEP-16	1.210	ppb
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	28-SEP-16	0.941	ppb
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	28-SEP-16	1.390	ppb
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Flush180	28-SEP-16	1.260	ppb
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS29	Main- Kitchen, Center Sink	Initial	28-SEP-16	1.120	ppb
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	1.070	ug/L
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	1.440	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	3.470	ug/L
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	2.050	ug/L
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	0.975	ppb
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	1.010	ppb
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	0.940	ppb
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS25	Main- Kitchen, East Wall 3-Basin, Center Faucet	Initial	28-SEP-16	1.700	ppb
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.100	ug/L
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	2.440	ppb
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	1.440	ppb
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	3.690	ppb
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	0.941	ppb
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Initial	25-MAY-23	2.770	ug/L
51633	51633-1-KIT-KS24	Main- Kitchen, East Wall 3-Basin, Left Faucet	Initial	28-SEP-16	1.860	ppb
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.209	ppb
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.316	ppb
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.574	ppb
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.176	ppb
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Initial	25-MAY-23	1.940	ug/L
51633	51633-1-KIT-KS26	Main- Kitchen, East Wall 3-Basin, Right Faucet	Initial	28-SEP-16	1.950	ppb
51633	51633-1-KIT-KS25-051633-1-KIT-KS25	Main- Kitchen, North Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	1.030	ppb
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	1.700	ug/L
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	1.860	ug/L
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	1.700	ug/L
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	25-MAY-23	1.350	ug/L
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	0.305	ppb
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	0.922	ppb
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	1.240	ppb
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Flush180	28-SEP-16	0.506	ppb
51633	51633-1-KIT-	Main- Kitchen, South Wall 3-Basin,	Initial	25-MAY-23	2.440	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS22	Center Faucet				
51633	51633-1-KIT-KS22	Main- Kitchen, South Wall 3-Basin, Center Faucet	Initial	28-SEP-16	1.600	ppb
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.890	ug/L
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	25-MAY-23	1.140	ug/L
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	0.397	ppb
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	1.040	ppb
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	0.935	ppb
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Flush180	28-SEP-16	0.629	ppb
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS21	Main- Kitchen, South Wall 3-Basin, Left Faucet	Initial	28-SEP-16	1.490	ppb
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	08-AUG-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	08-AUG-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	08-AUG-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	08-AUG-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	18-JUL-23	1.460	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	1.400	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	8.310	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	3.130	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.433	ppb
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.656	ppb
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	0.920	ppb
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	28-SEP-16	1.850	ppb
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Initial	08-AUG-23	1.000	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Initial	18-JUL-23	5.060	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Initial	25-MAY-23	5.140	ug/L
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Initial	28-SEP-16	5.210	ppb
51633	51633-1-KIT-KS23	Main- Kitchen, South Wall 3-Basin, Right Faucet	Initial	26-APR-23	1.000	ug/L
51633	51633-1-HAL-RBF07	Main- Next to Room 103, Right Fountain	Flush180	25-MAY-23	1.930	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Flush180	26-APR-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-HAL-RBF01	Main- Next to Room 114, Right Retrofit BF	Initial	26-APR-23	1.000	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	25-MAY-23	7.870	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	25-MAY-23	6.010	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	25-MAY-23	6.890	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	18-JUL-23	1.670	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	18-JUL-23	1.150	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	25-MAY-23	5.810	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	28-SEP-16	3.420	ppb
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	28-SEP-16	2.510	ppb
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	28-SEP-16	2.440	ppb
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Flush180	28-SEP-16	2.330	ppb
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Initial	25-MAY-23	4.430	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Initial	18-JUL-23	2.010	ug/L
51633	51633-1-GYM-F19	Main- North End Girls Gym, Fountain	Initial	28-SEP-16	4.920	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	28-SEP-16	6.210	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	28-SEP-16	6.700	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	28-SEP-16	5.310	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	28-SEP-16	7.170	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Flush180	17-NOV-16	1.000	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Initial	28-SEP-16	17.800	ppb
51633	51633-1-POOL-F13	Main- Pool Area, Fountain	Initial	17-NOV-16	1.000	ppb
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	25-MAY-23	3.720	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	25-MAY-23	3.020	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	25-MAY-23	3.510	ug/L
51633	51633-1-	Main- Upper Pool Area, Fountain	Flush180	25-MAY-23	5.670	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	POOL-F14					
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	18-JUL-23	1.330	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	18-JUL-23	1.000	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	28-SEP-16	1.030	ppb
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	28-SEP-16	0.961	ppb
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	28-SEP-16	1.060	ppb
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Flush180	28-SEP-16	0.996	ppb
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Initial	25-MAY-23	5.300	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Initial	18-JUL-23	2.250	ug/L
51633	51633-1-POOL-F14	Main- Upper Pool Area, Fountain	Initial	28-SEP-16	2.190	ppb
51633	51633-1-MODU-RBF01	Modular- Across From Room 01, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-RBF01	Modular- Across From Room 01, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-RBF01	Modular- Across From Room 01, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-RBF01	Modular- Across From Room 01, Left Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F02	Modular- Across From Room 01, Left Fountain	Flush180	28-SEP-16	0.159	ppb
51633	51633-1-MODU-F02	Modular- Across From Room 01, Left Fountain	Flush180	28-SEP-16	0.203	ppb
51633	51633-1-MODU-F02	Modular- Across From Room 01, Left Fountain	Flush180	28-SEP-16	0.172	ppb
51633	51633-1-MODU-F02	Modular- Across From Room 01, Left Fountain	Flush180	28-SEP-16	0.174	ppb
51633	51633-1-MODU-RBF01	Modular- Across From Room 01, Left Fountain	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F02	Modular- Across From Room 01, Left Fountain	Initial	28-SEP-16	0.417	ppb
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	28-SEP-16	0.195	ppb
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	28-SEP-16	0.259	ppb
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	28-SEP-16	0.152	ppb
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Flush180	28-SEP-16	0.184	ppb
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Initial	25-MAY-23	1.000	ug/L
51633	51633-1-MODU-F01	Modular- Across From Room 01, Right Fountain	Initial	28-SEP-16	0.361	ppb