



Sep 10, 2024

WATERS

4540 N CAMPBELL AVE, Chicago IL 60625.

Dear **WATERS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WATERS

4540 N CAMPBELL AVE, Chicago IL 60625.

Estimadas familias de **WATERS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51077	51077-1-KIT-KS01	Addition- Kitchen, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-KIT-KS01	Addition- Kitchen, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-KIT-KS01	Addition- Kitchen, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-KIT-KS01	Addition- Kitchen, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-KIT-KS01	Addition- Kitchen, Sink	Initial	16-SEP-16	1.280	ppb
51077	51077-2-HAL-F02	Main- Across From Room 210, North Fountain	Flush180	16-SEP-16	0.295	ppb
51077	51077-2-HAL-F02	Main- Across From Room 210, North Fountain	Flush180	16-SEP-16	0.541	ppb
51077	51077-2-HAL-F02	Main- Across From Room 210, North Fountain	Flush180	16-SEP-16	0.197	ppb
51077	51077-2-HAL-F02	Main- Across From Room 210, North Fountain	Flush180	16-SEP-16	0.225	ppb
51077	51077-2-HAL-F02	Main- Across From Room 210, North Fountain	Initial	16-SEP-16	0.695	ppb
51077	51077-2-HAL-F01	Main- Across From Room 210, South Fountain	Flush180	16-SEP-16	0.144	ppb
51077	51077-2-HAL-F01	Main- Across From Room 210, South Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F01	Main- Across From Room 210, South Fountain	Flush180	16-SEP-16	0.178	ppb
51077	51077-2-HAL-F01	Main- Across From Room 210, South Fountain	Flush180	16-SEP-16	0.228	ppb
51077	51077-2-HAL-F01	Main- Across From Room 210, South Fountain	Initial	16-SEP-16	1.010	ppb
51077	51077-3-HAL-F02	Main- Across From Room 310, North Fountain	Flush180	16-SEP-16	1.350	ppb
51077	51077-3-HAL-F02	Main- Across From Room 310, North Fountain	Flush180	16-SEP-16	1.520	ppb
51077	51077-3-HAL-F02	Main- Across From Room 310, North Fountain	Flush180	16-SEP-16	1.610	ppb
51077	51077-3-HAL-F02	Main- Across From Room 310, North Fountain	Flush180	16-SEP-16	1.560	ppb
51077	51077-3-HAL-F02	Main- Across From Room 310, North Fountain	Initial	16-SEP-16	1.550	ppb
51077	51077-3-HAL-F01	Main- Across From Room 310, South Fountain	Flush180	16-SEP-16	1.780	ppb
51077	51077-3-HAL-F01	Main- Across From Room 310, South Fountain	Flush180	16-SEP-16	1.200	ppb
51077	51077-3-HAL-F01	Main- Across From Room 310, South Fountain	Flush180	16-SEP-16	1.390	ppb
51077	51077-3-HAL-F01	Main- Across From Room 310, South Fountain	Flush180	16-SEP-16	1.080	ppb
51077	51077-3-HAL-F01	Main- Across From Room 310, South Fountain	Initial	16-SEP-16	2.220	ppb
51077	51077-1-HAL-F05	Main- Across From Teacher's Lounge in Old Lunchroom, Left Fountain	Flush180	23-SEP-20	1.000	ug/L
51077	51077-1-HAL-F05	Main- Across From Teacher's Lounge in Old Lunchroom, Left Fountain	Initial	23-SEP-20	1.000	ug/L
51077	51077-1-HAL-F03	Main- Across From Room 108, North Center Fountain	Flush180	16-SEP-16	0.135	ppb
51077	51077-1-HAL-F03	Main- Across From Room 108, North Center Fountain	Flush180	16-SEP-16	0.141	ppb
51077	51077-1-HAL-F03	Main- Across From Room 108, North Center Fountain	Flush180	16-SEP-16	0.153	ppb
51077	51077-1-HAL-F03	Main- Across From Room 108, North Center Fountain	Flush180	16-SEP-16	0.179	ppb
51077	51077-1-HAL-F03	Main- Across From Room 108, North Center Fountain	Initial	16-SEP-16	0.425	ppb
51077	51077-1-HAL-F04	Main- Across From Room 108, North Fountain	Flush180	16-SEP-16	0.279	ppb
51077	51077-1-HAL-F04	Main- Across From Room 108, North Fountain	Flush180	16-SEP-16	0.265	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51077	51077-1-HAL-F04	Main- Across Froom Room 108, North Fountain	Flush180	16-SEP-16	0.249	ppb
51077	51077-1-HAL-F04	Main- Across Froom Room 108, North Fountain	Flush180	16-SEP-16	0.279	ppb
51077	51077-1-HAL-F04	Main- Across Froom Room 108, North Fountain	Initial	16-SEP-16	0.339	ppb
51077	51077-1-HAL-F02	Main- Across Froom Room 108, South Center Fountain	Flush180	16-SEP-16	0.251	ppb
51077	51077-1-HAL-F02	Main- Across Froom Room 108, South Center Fountain	Flush180	16-SEP-16	0.450	ppb
51077	51077-1-HAL-F02	Main- Across Froom Room 108, South Center Fountain	Flush180	16-SEP-16	0.254	ppb
51077	51077-1-HAL-F02	Main- Across Froom Room 108, South Center Fountain	Flush180	16-SEP-16	0.266	ppb
51077	51077-1-HAL-F02	Main- Across Froom Room 108, South Center Fountain	Initial	16-SEP-16	0.328	ppb
51077	51077-1-HAL-F01	Main- Across Froom Room 108, South Fountain	Flush180	16-SEP-16	0.386	ppb
51077	51077-1-HAL-F01	Main- Across Froom Room 108, South Fountain	Flush180	16-SEP-16	0.323	ppb
51077	51077-1-HAL-F01	Main- Across Froom Room 108, South Fountain	Flush180	16-SEP-16	0.415	ppb
51077	51077-1-HAL-F01	Main- Across Froom Room 108, South Fountain	Flush180	16-SEP-16	0.433	ppb
51077	51077-1-HAL-F01	Main- Across Froom Room 108, South Fountain	Initial	16-SEP-16	1.250	ppb
51077	51077-2-HAL-F04	Main- Outside Room 205, North Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F04	Main- Outside Room 205, North Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F04	Main- Outside Room 205, North Fountain	Flush180	16-SEP-16	0.327	ppb
51077	51077-2-HAL-F04	Main- Outside Room 205, North Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F04	Main- Outside Room 205, North Fountain	Initial	16-SEP-16	0.766	ppb
51077	51077-2-HAL-F03	Main- Outside Room 205, South Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F03	Main- Outside Room 205, South Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F03	Main- Outside Room 205, South Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F03	Main- Outside Room 205, South Fountain	Flush180	16-SEP-16	0.120	ppb
51077	51077-2-HAL-F03	Main- Outside Room 205, South Fountain	Initial	16-SEP-16	0.168	ppb
51077	51077-3-HAL-F04	Main- Outside Room 304, North Fountain	Flush180	16-SEP-16	0.321	ppb
51077	51077-3-HAL-F04	Main- Outside Room 304, North Fountain	Flush180	16-SEP-16	0.234	ppb
51077	51077-3-HAL-F04	Main- Outside Room 304, North Fountain	Flush180	16-SEP-16	0.212	ppb
51077	51077-3-HAL-F04	Main- Outside Room 304, North Fountain	Flush180	16-SEP-16	0.145	ppb
51077	51077-3-HAL-F04	Main- Outside Room 304, North Fountain	Initial	16-SEP-16	0.822	ppb
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Flush180	16-SEP-16	0.185	ppb
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Flush180	16-SEP-16	0.122	ppb
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Flush180	16-SEP-16	0.246	ppb
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Flush180	16-SEP-16	0.336	ppb
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Flush180	23-SEP-20	1.000	ug/L
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Initial	16-SEP-16	0.397	ppb
51077	51077-3-HAL-F03	Main- Outside Room 304, South Fountain	Initial	23-SEP-20	1.250	ug/L
51077	51077-1-TL-S05	Main- Taechers Lounge, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-TL-S05	Main- Taechers Lounge, Sink	Flush180	16-SEP-16	0.120	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51077	51077-1-TL-S05	Main- Taechers Lounge, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-TL-S05	Main- Taechers Lounge, Sink	Flush180	16-SEP-16	0.120	ppb
51077	51077-1-TL-S05	Main- Taechers Lounge, Sink	Initial	16-SEP-16	0.120	ppb
57701	57701-1-TL-S01	Addition, Teachers Lounge	Flush180	17-NOV-20	1.000	ug/L
57701	57701-1-TL-S01	Addition, Teachers Lounge	Flush180	17-NOV-20	1.000	ug/L
57701	57701-1-TL-S01	Addition, Teachers Lounge	Flush180	17-NOV-20	1.000	ug/L
57701	57701-1-TL-S01	Addition, Teachers Lounge	Flush180	17-NOV-20	1.000	ug/L
57701	57701-1-TL-S01	Addition, Teachers Lounge	Initial	17-NOV-20	1.000	ug/L
57701	57701-1-HAL-F01	Addition- 1st Fl. Hallway, Near Rm 116, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F01	Addition- 1st Fl. Hallway, Near Rm 116, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F01	Addition- 1st Fl. Hallway, Near Rm 116, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F01	Addition- 1st Fl. Hallway, Near Rm 116, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F01	Addition- 1st Fl. Hallway, Near Rm 116, Left Fountain	Initial	25-SEP-20	2.970	ug/L
57701	57701-1-HAL-F02	Addition- 1st Fl. Hallway, Near Rm 116, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F02	Addition- 1st Fl. Hallway, Near Rm 116, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F02	Addition- 1st Fl. Hallway, Near Rm 116, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F02	Addition- 1st Fl. Hallway, Near Rm 116, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F02	Addition- 1st Fl. Hallway, Near Rm 116, Middle Fountain	Initial	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F03	Addition- 1st Fl. Hallway, Near Rm 116, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F03	Addition- 1st Fl. Hallway, Near Rm 116, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F03	Addition- 1st Fl. Hallway, Near Rm 116, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-F03	Addition- 1st Fl. Hallway, Near Rm 116, Right Fountain	Initial	25-SEP-20	1.000	ug/L
57701	57701-1-HAL-BF01	Addition- 1st Floor Hallway, Right Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-HAL-BF01	Addition- 1st Floor Hallway, Right Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-HAL-BF01	Addition- 1st Floor Hallway, Right Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-HAL-BF01	Addition- 1st Floor Hallway, Right Fountain Bottle Filler	Initial	23-SEP-20	1.430	ug/L
57701	57701-2-HAL-BF01	Addition- 2nd Fl. West Hall, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-BF01	Addition- 2nd Fl. West Hall, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-BF01	Addition- 2nd Fl. West Hall, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-BF01	Addition- 2nd Fl. West Hall, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-BF01	Addition- 2nd Fl. West Hall, Right Fountain Bottle Filler	Initial	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F01	Addition- 2nd Fl. West Hallway, By Elevator, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F01	Addition- 2nd Fl. West Hallway, By Elevator, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F01	Addition- 2nd Fl. West Hallway, By Elevator, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F01	Addition- 2nd Fl. West Hallway, By Elevator, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F01	Addition- 2nd Fl. West Hallway, By Elevator, Left Fountain	Initial	25-SEP-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01	Elevator, Left Fountain				
57701	57701-2-HAL-F02	Addition- 2nd Fl. West Hallway, By Elevator, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F02	Addition- 2nd Fl. West Hallway, By Elevator, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F02	Addition- 2nd Fl. West Hallway, By Elevator, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F02	Addition- 2nd Fl. West Hallway, By Elevator, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F02	Addition- 2nd Fl. West Hallway, By Elevator, Middle Fountain	Initial	25-SEP-20	1.380	ug/L
57701	57701-2-HAL-F03	Addition- 2nd Fl. West Hallway, By Elevator, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F03	Addition- 2nd Fl. West Hallway, By Elevator, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F03	Addition- 2nd Fl. West Hallway, By Elevator, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-2-HAL-F03	Addition- 2nd Fl. West Hallway, By Elevator, Right Fountain	Initial	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F01	Addition- 3rd Fl. Hallway, Near Rm 322, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F01	Addition- 3rd Fl. Hallway, Near Rm 322, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F01	Addition- 3rd Fl. Hallway, Near Rm 322, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F01	Addition- 3rd Fl. Hallway, Near Rm 322, Left Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F01	Addition- 3rd Fl. Hallway, Near Rm 322, Left Fountain	Initial	25-SEP-20	2.380	ug/L
57701	57701-3-HAL-F02	Addition- 3rd Fl. Hallway, Near Rm 322, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F02	Addition- 3rd Fl. Hallway, Near Rm 322, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F02	Addition- 3rd Fl. Hallway, Near Rm 322, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F02	Addition- 3rd Fl. Hallway, Near Rm 322, Middle Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F02	Addition- 3rd Fl. Hallway, Near Rm 322, Middle Fountain	Initial	25-SEP-20	1.980	ug/L
57701	57701-3-HAL-F03	Addition- 3rd Fl. Hallway, Near Rm 322, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F03	Addition- 3rd Fl. Hallway, Near Rm 322, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F03	Addition- 3rd Fl. Hallway, Near Rm 322, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F03	Addition- 3rd Fl. Hallway, Near Rm 322, Right Fountain	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F03	Addition- 3rd Fl. Hallway, Near Rm 322, Right Fountain	Initial	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-F03	Addition- 3rd Fl. Hallway, Near Rm 322, Right Fountain	Initial	23-SEP-20	3.570	ug/L
57701	57701-3-HAL-BF01	Addition- 3rd Fl. Hallway, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-BF01	Addition- 3rd Fl. Hallway, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-BF01	Addition- 3rd Fl. Hallway, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-BF01	Addition- 3rd Fl. Hallway, Right Fountain Bottle Filler	Flush180	25-SEP-20	1.000	ug/L
57701	57701-3-HAL-BF01	Addition- 3rd Fl. Hallway, Right Fountain Bottle Filler	Initial	25-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-	Addition- Cafeteria, East Fountain	Flush180	23-SEP-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC03					
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Initial	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC03	Addition- Cafeteria, East Fountain	Initial	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-BF01	Addition- Cafeteria, East Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-BF01	Addition- Cafeteria, East Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-BF01	Addition- Cafeteria, East Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-BF01	Addition- Cafeteria, East Fountain Bottle Filler	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-BF01	Addition- Cafeteria, East Fountain Bottle Filler	Initial	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Initial	16-SEP-16	0.120	ppb
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Initial	23-SEP-20	1.000	ug/L
57701	57701-1-CAF-WC02	Addition- Cafeteria, West Fountain	Initial	23-SEP-20	2.360	ug/L
57701	57701-1-KIT-S05	Kitchen Room 114A, East Wall Sink, Left Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S05	Kitchen Room 114A, East Wall Sink, Left Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S05	Kitchen Room 114A, East Wall Sink, Left Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S05	Kitchen Room 114A, East Wall Sink, Left Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S05	Kitchen Room 114A, East Wall Sink, Left Side	Initial	23-SEP-20	3.700	ug/L
57701	57701-1-KIT-S03	Kitchen Room 114A, Free Standing Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S03	Kitchen Room 114A, Free Standing Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S03	Kitchen Room 114A, Free Standing Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S03	Kitchen Room 114A, Free Standing Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S03	Kitchen Room 114A, Free Standing Sink	Initial	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S01	Kitchen Room 114A, Left of Entrance Door, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S01	Kitchen Room 114A, Left of Entrance Door, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S01	Kitchen Room 114A, Left of Entrance Door, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S01	Kitchen Room 114A, Left of Entrance Door, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S01	Kitchen Room 114A, Left of Entrance Door, South Wall Sink	Initial	23-SEP-20	2.590	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	20-OCT-20	1.000	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	20-OCT-20	1.000	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	20-OCT-20	1.000	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	20-OCT-20	1.000	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	23-SEP-20	19.800	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	23-SEP-20	4.150	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	23-SEP-20	2.880	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Flush180	23-SEP-20	2.460	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Initial	20-OCT-20	1.000	ug/L
57701	57701-1-KIT-S04	Kitchen Room 114A, North Wall Sink	Initial	23-SEP-20	11.800	ug/L
57701	57701-1-KIT-S02	Kitchen Room 114A, Right of Entrance, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S02	Kitchen Room 114A, Right of Entrance, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S02	Kitchen Room 114A, Right of Entrance, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S02	Kitchen Room 114A, Right of Entrance, South Wall Sink	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S02	Kitchen Room 114A, Right of Entrance, South Wall Sink	Initial	23-SEP-20	3.280	ug/L
57701	57701-1-KIT-S06	Kitchen Room 11A, East Wall Sink, Right Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S06	Kitchen Room 11A, East Wall Sink, Right Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S06	Kitchen Room 11A, East Wall Sink, Right Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S06	Kitchen Room 11A, East Wall Sink, Right Side	Flush180	23-SEP-20	1.000	ug/L
57701	57701-1-KIT-S06	Kitchen Room 11A, East Wall Sink, Right Side	Initial	23-SEP-20	1.900	ug/L