



Sep 10, 2024

WEBSTER

4055 W ARTHINGTON ST, Chicago IL 60624.

Dear **WEBSTER** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WEBSTER

4055 W ARTHINGTON ST, Chicago IL 60624.

Estimadas familias de **WEBSTER**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.220	ug/L
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.060	ug/L
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.060	ug/L
51215	51215-2-HAL-RBF01	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-RBF01	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-RBF01	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-RBF01	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.000	ug/L
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Flush180	12-JAN-22	1.300	ug/L
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Initial	13-SEP-16	2.000	ppb
51215	51215-2-HAL-RBF01	Main- 1st Floor Across From Library Left, Fountain	Initial	12-JAN-22	2.170	ug/L
51215	51215-1-HAL-WC15	Main- 1st Floor Across From Library Left, Fountain	Initial	12-JAN-22	1.390	ug/L
51215	51215-1-HAL-WC14	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC14	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC14	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC14	Main- 1st Floor Across From Library Right, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC14	Main- 1st Floor Across From Library Right, Fountai	Initial	13-SEP-16	2.000	ppb
51215	51215-1-HAL-RBF01	Main- 1st Floor Across From Library Right, Fountain	Flush180	12-JAN-22	2.240	ug/L
51215	51215-1-HAL-RBF01	Main- 1st Floor Across From Library Right, Fountain	Flush180	12-JAN-22	2.050	ug/L
51215	51215-1-HAL-RBF01	Main- 1st Floor Across From Library Right, Fountain	Flush180	12-JAN-22	1.080	ug/L
51215	51215-1-HAL-RBF01	Main- 1st Floor Across From Library Right, Fountain	Flush180	12-JAN-22	1.000	ug/L
51215	51215-1-HAL-RBF01	Main- 1st Floor Across From Library Right, Fountain	Initial	12-JAN-22	1.680	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	20-AUG-20	1.600	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	12-JAN-22	1.500	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	12-JAN-22	1.240	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	12-JAN-22	1.210	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Flush180	12-JAN-22	2.920	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Initial	13-SEP-16	2.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Initial	20-AUG-20	1.200	ug/L
51215	51215-1-HAL-WC16	Main- 1st Floor By Boiler Room, Fountain	Initial	12-JAN-22	1.010	ug/L
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	13-SEP-16	2.200	ppb
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	12-JAN-22	1.740	ug/L
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	12-JAN-22	2.250	ug/L
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	12-JAN-22	2.430	ug/L
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Flush180	12-JAN-22	3.090	ug/L
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Initial	13-SEP-16	2.000	ppb
51215	51215-1-101-S09	Main- 1st Floor Inside Room 101 Center, Sink	Initial	12-JAN-22	1.760	ug/L
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	12-JAN-22	1.190	ug/L
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	12-JAN-22	1.100	ug/L
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	12-JAN-22	1.100	ug/L
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Flush180	12-JAN-22	1.130	ug/L
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Initial	13-SEP-16	2.000	ppb
51215	51215-1-101-S07	Main- 1st Floor Inside Room 101 Left, Sink	Initial	12-JAN-22	2.650	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	31-JAN-23	2.010	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	31-JAN-23	2.030	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	31-JAN-23	2.630	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	31-JAN-23	2.060	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	12-JAN-22	11.700	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	12-JAN-22	36.100	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	12-JAN-22	25.900	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	12-JAN-22	10.500	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	19-AUG-22	2.600	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	19-AUG-22	3.640	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	19-AUG-22	4.290	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	19-AUG-22	5.070	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	09-SEP-22	6.150	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	09-SEP-22	4.460	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	09-SEP-22	4.390	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	09-SEP-22	3.770	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-JUL-22	2.500	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-JUL-22	5.410	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-JUL-22	3.740	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	26-JUL-22	4.470	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	29-DEC-22	7.990	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	29-DEC-22	8.710	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	29-DEC-22	6.190	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Flush180	29-DEC-22	9.670	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	31-JAN-23	1.750	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	13-SEP-16	2.000	ppb
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	12-JAN-22	55.600	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	19-AUG-22	2.690	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	09-SEP-22	4.590	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	26-JUL-22	2.700	ug/L
51215	51215-1-101-F08	Main- 1st Floor Inside Room 101, Fountain	Initial	29-DEC-22	6.050	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	13-SEP-16	2.800	ppb
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	13-SEP-16	2.200	ppb
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	13-SEP-16	2.600	ppb
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	13-SEP-16	2.300	ppb
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	12-JAN-22	14.500	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	12-JAN-22	7.640	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	12-JAN-22	5.260	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	12-JAN-22	4.480	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	26-JUL-22	1.870	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	26-JUL-22	1.670	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Flush180	26-JUL-22	1.640	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Initial	13-SEP-16	3.800	ppb
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Initial	12-JAN-22	26.200	ug/L
51215	51215-1-102-F05	Main- 1st Floor Inside Room 102, Fountain	Initial	26-JUL-22	1.200	ug/L
51215	51215-1-102-S10	Main- 1st Floor Inside Room 102, Outside Restroom	Flush180	12-JAN-22	1.300	ug/L
51215	51215-1-102-S10	Main- 1st Floor Inside Room 102, Outside Restroom	Flush180	12-JAN-22	1.000	ug/L
51215	51215-1-102-S10	Main- 1st Floor Inside Room 102, Outside Restroom	Flush180	12-JAN-22	1.000	ug/L
51215	51215-1-102-	Main- 1st Floor Inside Room 102,	Flush180	12-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S10	Outside Restroom				
51215	51215-1-102-S10	Main- 1st Floor Inside Room 102, Outside Restroom	Initial	12-JAN-22	1.500	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	12-JAN-22	8.780	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	12-JAN-22	7.420	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	12-JAN-22	3.970	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	12-JAN-22	2.660	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	26-JUL-22	1.420	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	26-JUL-22	1.050	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	26-JUL-22	1.000	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Flush180	26-JUL-22	1.000	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Initial	13-SEP-16	2.000	ppb
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Initial	12-JAN-22	6.770	ug/L
51215	51215-1-102-S06	Main- 1st Floor Inside Room 102, Sink	Initial	26-JUL-22	1.410	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	12-JAN-22	3.800	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	12-JAN-22	2.790	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	12-JAN-22	2.580	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	12-JAN-22	2.330	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	26-JUL-22	3.410	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	26-JUL-22	2.680	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	26-JUL-22	3.510	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Flush180	26-JUL-22	2.210	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Initial	13-SEP-16	2.900	ppb
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Initial	12-JAN-22	5.160	ug/L
51215	51215-1-105-S11	Main- 1st Floor Inside Room 105, Sink	Initial	26-JUL-22	4.450	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	12-JAN-22	117.000	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	12-JAN-22	59.500	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	S12	Sink				
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	12-JAN-22	35.100	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	12-JAN-22	22.400	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	19-AUG-22	2.000	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	19-AUG-22	2.490	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	19-AUG-22	2.110	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	19-AUG-22	1.830	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	26-JUL-22	14.900	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	26-JUL-22	26.500	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	26-JUL-22	25.300	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Flush180	26-JUL-22	26.500	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Initial	13-SEP-16	2.000	ppb
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Initial	12-JAN-22	701.000	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Initial	19-AUG-22	2.720	ug/L
51215	51215-1-107-S12	Main- 1st Floor Inside Room 107, Sink	Initial	26-JUL-22	69.000	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	29-DEC-22	2.450	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	29-DEC-22	3.110	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	29-DEC-22	3.200	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	29-DEC-22	3.730	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	31-JAN-23	1.400	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	31-JAN-23	1.280	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	31-JAN-23	1.370	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	31-JAN-23	1.720	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	13-SEP-16	5.900	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	13-SEP-16	10.000	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	13-SEP-16	4.100	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	13-SEP-16	23.000	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	6.100	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	2.600	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	4.300	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	3.100	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	2.600	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	4.300	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	3.100	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	28-OCT-16	6.100	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	12-JAN-22	94.100	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	12-JAN-22	26.800	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	12-JAN-22	37.500	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	12-JAN-22	40.800	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	19-AUG-22	4.610	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	19-AUG-22	9.060	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	19-AUG-22	3.580	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	19-AUG-22	8.390	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	09-SEP-22	3.570	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	09-SEP-22	6.290	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	09-SEP-22	7.270	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	09-SEP-22	10.100	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	26-JUL-22	44.900	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	26-JUL-22	34.400	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	26-JUL-22	29.400	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Flush180	26-JUL-22	25.300	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	29-DEC-22	5.180	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	31-JAN-23	10.900	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	13-SEP-16	39.000	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	28-OCT-16	2.500	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	28-OCT-16	2.500	ppb
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	12-JAN-22	52.200	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	19-AUG-22	2.850	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	09-SEP-22	1.900	ug/L
51215	51215-1-109-S13	Main- 1st Floor Inside Room 109, Sink	Initial	26-JUL-22	47.300	ug/L
51215	51215-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS03	Main- 1st Floor Kitchen Center Faucet, Sink	Initial	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS02	Main- 1st Floor Kitchen Left Faucet, Sink	Initial	13-SEP-16	2.400	ppb
51215	51215-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS04	Main- 1st Floor Kitchen Right Faucet, Sink	Initial	13-SEP-16	2.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51215	51215-1-KIT-KS01	Main- 1st Floor Kitchen, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS01	Main- 1st Floor Kitchen, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS01	Main- 1st Floor Kitchen, Sink	Flush180	13-SEP-16	4.000	ppb
51215	51215-1-KIT-KS01	Main- 1st Floor Kitchen, Sink	Flush180	13-SEP-16	2.000	ppb
51215	51215-1-KIT-KS01	Main- 1st Floor Kitchen, Sink	Initial	13-SEP-16	2.200	ppb
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	12-JAN-22	2.130	ug/L
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	12-JAN-22	2.170	ug/L
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	12-JAN-22	2.160	ug/L
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Flush180	12-JAN-22	2.200	ug/L
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Initial	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC03	Main- 2nd Floor Across From Room 213 Left, Fountai	Initial	12-JAN-22	1.280	ug/L
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Flush180	20-AUG-20	4.320	ug/L
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Initial	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC04	Main- 2nd Floor Across From Room 213 Right, Founta	Initial	20-AUG-20	2.890	ug/L
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	12-JAN-22	1.010	ug/L
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Initial	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC01	Main- 2nd Floor Across From Room 223 Left, Fountai	Initial	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	12-JAN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02	Room 223 Right, Founta				
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Flush180	12-JAN-22	1.000	ug/L
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Initial	13-SEP-16	2.000	ppb
51215	51215-2-HAL-WC02	Main- 2nd Floor Across From Room 223 Right, Founta	Initial	12-JAN-22	1.000	ug/L