



Sep 10, 2024

WELLS HS

936 N ASHLAND AVE, Chicago IL 60622.

Dear **WELLS HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WELLS HS

936 N ASHLAND AVE, Chicago IL 60622.

Estimadas familias de **WELLS HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-1-KIT-KS07	Main- Kitchen East Sink	Flush180	04-OCT-16	1.260	ppb
51555	51555-1-KIT-KS07	Main- Kitchen East Sink	Flush180	04-OCT-16	1.100	ppb
51555	51555-1-KIT-KS07	Main- Kitchen East Sink	Flush180	04-OCT-16	1.060	ppb
51555	51555-1-KIT-KS07	Main- Kitchen East Sink	Flush180	04-OCT-16	0.407	ppb
51555	51555-1-KIT-KS07	Main- Kitchen East Sink	Initial	04-OCT-16	0.804	ppb
51555	51555-KIT-KS05	Main- Kitchen North, Center Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-KIT-KS05	Main- Kitchen North, Center Sink	Flush180	04-OCT-16	0.128	ppb
51555	51555-KIT-KS05	Main- Kitchen North, Center Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-KIT-KS05	Main- Kitchen North, Center Sink	Flush180	04-OCT-16	0.714	ppb
51555	51555-KIT-KS05	Main- Kitchen North, Center Sink	Initial	04-OCT-16	0.509	ppb
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush180	04-OCT-16	0.181	ppb
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush180	04-OCT-16	0.124	ppb
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Flush180	04-OCT-16	0.169	ppb
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Initial	04-OCT-16	0.241	ppb
51555	51555-1-KIT-KS04	Main- Kitchen North, Left Sink	Initial	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS06	Main- Kitchen North, Right Sink	Flush180	04-OCT-16	0.123	ppb
51555	51555-1-KIT-KS06	Main- Kitchen North, Right Sink	Flush180	04-OCT-16	0.158	ppb
51555	51555-1-KIT-KS06	Main- Kitchen North, Right Sink	Flush180	04-OCT-16	0.172	ppb
51555	51555-1-KIT-KS06	Main- Kitchen North, Right Sink	Flush180	04-OCT-16	0.164	ppb
51555	51555-1-KIT-KS06	Main- Kitchen North, Right Sink	Initial	04-OCT-16	0.316	ppb
51555	51555-1-KIT-KS02	Main- Kitchen South, Center Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS02	Main- Kitchen South, Center Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS02	Main- Kitchen South, Center Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS02	Main- Kitchen South, Center Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS02	Main- Kitchen South, Center Sink	Initial	04-OCT-16	0.141	ppb
51555	51555-1-KIT-KS01	Main- Kitchen South, Left Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS01	Main- Kitchen South, Left Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS01	Main- Kitchen South, Left Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS01	Main- Kitchen South, Left Sink	Flush180	04-OCT-16	0.163	ppb
51555	51555-1-KIT-KS01	Main- Kitchen South, Left Sink	Initial	04-OCT-16	0.375	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-1-KIT-KS03	Main- Kitchen South, Right Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS03	Main- Kitchen South, Right Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS03	Main- Kitchen South, Right Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS03	Main- Kitchen South, Right Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS03	Main- Kitchen South, Right Sink	Initial	04-OCT-16	0.242	ppb
51555	51555-1-KIT-KS08	Main- Kitchen West Sink	Flush180	04-OCT-16	0.147	ppb
51555	51555-1-KIT-KS08	Main- Kitchen West Sink	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-KIT-KS08	Main- Kitchen West Sink	Flush180	04-OCT-16	1.890	ppb
51555	51555-1-KIT-KS08	Main- Kitchen West Sink	Flush180	04-OCT-16	0.364	ppb
51555	51555-1-KIT-KS08	Main- Kitchen West Sink	Initial	04-OCT-16	0.912	ppb
51555	51555-1-KIT-KS08	Main- Kitchen West Wall Left 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS08	Main- Kitchen West Wall Left 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS08	Main- Kitchen West Wall Left 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS08	Main- Kitchen West Wall Left 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS08	Main- Kitchen West Wall Left 3-Basin Left Sink	Initial	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS10	Main- Kitchen West Wall Left 3-Basin Right Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS10	Main- Kitchen West Wall Left 3-Basin Right Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS10	Main- Kitchen West Wall Left 3-Basin Right Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS10	Main- Kitchen West Wall Left 3-Basin Right Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS10	Main- Kitchen West Wall Left 3-Basin Right Sink	Initial	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS09	Main- Kitchen West Wall Left 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS09	Main- Kitchen West Wall Left 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS09	Main- Kitchen West Wall Left 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS09	Main- Kitchen West Wall Left 3-Basin Middle Sink	Initial	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS13	Main- Kitchen West Wall R. 3-Basin Right Sink	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-KIT-KS13	Main- Kitchen West Wall R. 3-Basin Right Sink	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-KIT-KS13	Main- Kitchen West Wall R. 3-Basin Right Sink	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-KIT-KS13	Main- Kitchen West Wall R. 3-Basin Right Sink	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-KIT-KS13	Main- Kitchen West Wall R. 3-Basin Right Sink	Initial	03-JAN-2024	1.000	ug/L
51555	51555-1-KIT-KS11	Main- Kitchen West Wall Right 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS11	Main- Kitchen West Wall Right 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS11	Main- Kitchen West Wall Right 3-Basin Left Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS11	Main- Kitchen West Wall Right 3-Basin Left Sink	Initial	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS12	Main- Kitchen West Wall Right 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS12	Main- Kitchen West Wall Right 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-1-KIT-KS12	Main- Kitchen West Wall Right 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS12	Main- Kitchen West Wall Right 3-Basin Middle Sink	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-KIT-KS12	Main- Kitchen West Wall Right 3-Basin Middle Sink	Initial	08-NOV-2023	1.100	ug/L
51555	51555-2-HAL-BF01	Main- Outside 211 Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-BF01	Main- Outside 211 Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-BF01	Main- Outside 211 Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-BF01	Main- Outside 211 Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-BF01	Main- Outside 211 Bottle Filler	Initial	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	11-NOV-16	37.000	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	11-NOV-16	44.000	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	04-OCT-16	7.680	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	11-NOV-16	24.000	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	11-NOV-16	26.000	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	27-OCT-17	1.420	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	27-OCT-17	1.150	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	27-OCT-17	0.822	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	27-OCT-17	0.711	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	04-OCT-16	8.640	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	04-OCT-16	7.610	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Flush180	04-OCT-16	4.070	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Initial	04-OCT-16	43.400	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Initial	11-NOV-16	61.000	ppb
51555	51555-1-HAL-F09	Main- Outside Room 116, Left Fountain	Initial	27-OCT-17	2.840	ppb
51555	51555-1-HAL-F10	Main- Outside Room 116, Right Fountain	Flush180	04-OCT-16	2.060	ppb
51555	51555-1-HAL-F10	Main- Outside Room 116, Right Fountain	Flush180	04-OCT-16	1.890	ppb
51555	51555-1-HAL-F10	Main- Outside Room 116, Right Fountain	Flush180	04-OCT-16	1.990	ppb
51555	51555-1-HAL-F10	Main- Outside Room 116, Right Fountain	Flush180	04-OCT-16	1.790	ppb
51555	51555-1-HAL-F10	Main- Outside Room 116, Right Fountain	Initial	04-OCT-16	1.830	ppb
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush	08-NOV-2023	1.650	ug/L
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush	08-NOV-2023	1.200	ug/L
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush	08-NOV-2023	1.110	ug/L
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush	08-NOV-2023	1.060	ug/L
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush180	04-OCT-16	1.900	ppb
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush180	04-OCT-16	1.970	ppb
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush180	04-OCT-16	2.010	ppb
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Flush180	04-OCT-16	2.000	ppb
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Initial	04-OCT-16	2.290	ppb
51555	51555-1-HAL-F13	Main-Across Room 104, Left Fountain	Initial	08-NOV-2023	2.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F13	Fountain				
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush	08-NOV-2023	1.310	ug/L
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush	08-NOV-2023	1.260	ug/L
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush	08-NOV-2023	1.110	ug/L
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush	08-NOV-2023	1.060	ug/L
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush180	04-OCT-16	4.800	ppb
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush180	04-OCT-16	6.400	ppb
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush180	04-OCT-16	7.160	ppb
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Flush180	04-OCT-16	4.720	ppb
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Initial	04-OCT-16	6.280	ppb
51555	51555-1-HAL-F14	Main-Across Room 104, Right Fountain	Initial	08-NOV-2023	2.430	ug/L
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush	08-NOV-2023	1.210	ug/L
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush180	04-OCT-16	0.883	ppb
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush180	04-OCT-16	0.607	ppb
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush180	04-OCT-16	0.389	ppb
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Flush180	04-OCT-16	0.475	ppb
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Initial	04-OCT-16	1.880	ppb
51555	51555-1-HAL-F17	Main-Across Room 115, Left Fountain	Initial	08-NOV-2023	1.350	ug/L
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush180	04-OCT-16	0.379	ppb
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush180	04-OCT-16	0.282	ppb
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush180	04-OCT-16	0.267	ppb
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Flush180	04-OCT-16	0.293	ppb
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Initial	04-OCT-16	1.520	ppb
51555	51555-1-HAL-F18	Main-Across Room 115, Right Fountain	Initial	08-NOV-2023	1.730	ug/L
51555	51555-2-HAL-F05	Main-Across Room 206, Left Fountain	Flush180	04-OCT-16	2.070	ppb
51555	51555-2-HAL-F05	Main-Across Room 206, Left Fountain	Flush180	04-OCT-16	1.410	ppb
51555	51555-2-HAL-F05	Main-Across Room 206, Left Fountain	Flush180	04-OCT-16	1.390	ppb
51555	51555-2-HAL-F05	Main-Across Room 206, Left Fountain	Flush180	04-OCT-16	1.960	ppb
51555	51555-2-HAL-F05	Main-Across Room 206, Left Fountain	Initial	04-OCT-16	3.350	ppb
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush	08-NOV-2023	1.850	ug/L
51555	51555-2-HAL-	Main-Across Room 206, Right Fountain	Flush	08-NOV-2023	1.520	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	Fountain				
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush	08-NOV-2023	1.400	ug/L
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush	08-NOV-2023	1.270	ug/L
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush180	04-OCT-16	1.320	ppb
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush180	04-OCT-16	2.040	ppb
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush180	04-OCT-16	1.810	ppb
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Flush180	04-OCT-16	2.090	ppb
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Initial	04-OCT-16	3.110	ppb
51555	51555-2-HAL-F06	Main-Across Room 206, Right Fountain	Initial	08-NOV-2023	2.130	ug/L
51555	51555-3-HAL-F05	Main-Across Room 304, Left Fountain	Flush180	04-OCT-16	6.470	ppb
51555	51555-3-HAL-F05	Main-Across Room 304, Left Fountain	Flush180	04-OCT-16	5.270	ppb
51555	51555-3-HAL-F05	Main-Across Room 304, Left Fountain	Flush180	04-OCT-16	3.280	ppb
51555	51555-3-HAL-F05	Main-Across Room 304, Left Fountain	Flush180	04-OCT-16	2.460	ppb
51555	51555-3-HAL-F05	Main-Across Room 304, Left Fountain	Initial	04-OCT-16	2.920	ppb
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush	08-NOV-2023	1.250	ug/L
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush	08-NOV-2023	1.010	ug/L
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush180	04-OCT-16	3.260	ppb
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush180	04-OCT-16	2.270	ppb
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush180	04-OCT-16	5.130	ppb
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Flush180	04-OCT-16	3.650	ppb
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Initial	04-OCT-16	2.370	ppb
51555	51555-3-HAL-F06	Main-Across Room 304, Right Fountain	Initial	08-NOV-2023	1.030	ug/L
51555	51555-3-HAL-BF02	Main-Across Room 307, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-BF02	Main-Across Room 307, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-BF02	Main-Across Room 307, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-BF02	Main-Across Room 307, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-BF02	Main-Across Room 307, Bottle Filler	Initial	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-WC08	Main-Across Room 307, Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC08	Main-Across Room 307, Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC08	Main-Across Room 307, Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC08	Main-Across Room 307, Fountain	Initial	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Initial	04-OCT-16	1.000	ppb
51555	51555-3-HAL-WC07	Main-Across Room 307, Fountain/Bottle Filler	Initial	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush	08-NOV-2023	1.480	ug/L
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush	08-NOV-2023	1.320	ug/L
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush	08-NOV-2023	1.040	ug/L
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush180	04-OCT-16	1.210	ppb
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush180	04-OCT-16	0.999	ppb
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush180	04-OCT-16	1.170	ppb
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Flush180	04-OCT-16	0.616	ppb
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Initial	04-OCT-16	1.160	ppb
51555	51555-4-HAL-F05	Main-Across Room 404, Left Fountain	Initial	08-NOV-2023	2.010	ug/L
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush	08-NOV-2023	1.950	ug/L
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush	08-NOV-2023	2.680	ug/L
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush	08-NOV-2023	2.090	ug/L
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush	08-NOV-2023	1.940	ug/L
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush180	04-OCT-16	0.897	ppb
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush180	04-OCT-16	0.755	ppb
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush180	04-OCT-16	0.605	ppb
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Flush180	04-OCT-16	0.589	ppb
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Initial	04-OCT-16	1.360	ppb
51555	51555-4-HAL-F06	Main-Across Room 404, Right Fountain	Initial	08-NOV-2023	3.080	ug/L
51555	51555-4-HAL-BF01	Main-Across Room 407, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-BF01	Main-Across Room 407, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-BF01	Main-Across Room 407, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-BF01	Main-Across Room 407, Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-BF01	Main-Across Room 407, Bottle Filler	Initial	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-f08	Main-Across Room 407, Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-f08	Main-Across Room 407, Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-f08	Main-Across Room 407, Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-f08	Main-Across Room 407, Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-f08	Main-Across Room 407, Fountain	Initial	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F08	Main-Across Room 407, Left Fountain	Flush180	04-OCT-16	2.550	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-4-HAL-F08	Main-Across Room 407, Left Fountain	Flush180	04-OCT-16	4.100	ppb
51555	51555-4-HAL-F08	Main-Across Room 407, Left Fountain	Flush180	04-OCT-16	3.130	ppb
51555	51555-4-HAL-F08	Main-Across Room 407, Left Fountain	Flush180	04-OCT-16	2.590	ppb
51555	51555-4-HAL-F08	Main-Across Room 407, Left Fountain	Initial	04-OCT-16	2.910	ppb
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	08-NOV-2023	5.520	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	08-NOV-2023	6.550	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	08-NOV-2023	8.040	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	08-NOV-2023	6.410	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	12-MAR-2024	3.570	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	12-MAR-2024	3.930	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	12-MAR-2024	2.790	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	12-MAR-2024	3.430	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	26-JAN-2024	4.510	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	26-JAN-2024	4.040	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	26-JAN-2024	4.610	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	26-JAN-2024	5.210	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	03-JAN-2024	7.750	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	03-JAN-2024	16.300	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	03-JAN-2024	7.320	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush	03-JAN-2024	4.700	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush180	04-OCT-16	2.780	ppb
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush180	04-OCT-16	2.180	ppb
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush180	04-OCT-16	2.590	ppb
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Flush180	04-OCT-16	2.240	ppb
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Initial	04-OCT-16	3.380	ppb
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Initial	08-NOV-2023	9.050	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Initial	12-MAR-2024	3.500	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Initial	26-JAN-2024	17.400	ug/L
51555	51555-4-HAL-F07	Main-Across Room 407, Right Fountain	Initial	03-JAN-2024	9.280	ug/L
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush180	04-OCT-16	1.600	ppb
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush180	04-OCT-16	1.650	ppb
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush180	04-OCT-16	1.490	ppb
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Flush180	04-OCT-16	1.350	ppb
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Initial	04-OCT-16	1.640	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F09	Fountain				
51555	51555-4-HAL-F09	Main-Across Room 417, Left Fountain	Initial	08-NOV-2023	1.000	ug/L
51555	51555-3-GYM-F11	Main-Boys Gym Third Floor	Flush180	04-OCT-16	6.880	ppb
51555	51555-3-GYM-F11	Main-Boys Gym Third Floor	Flush180	04-OCT-16	3.470	ppb
51555	51555-3-GYM-F11	Main-Boys Gym Third Floor	Flush180	04-OCT-16	2.360	ppb
51555	51555-3-GYM-F11	Main-Boys Gym Third Floor	Flush180	04-OCT-16	2.550	ppb
51555	51555-3-GYM-F11	Main-Boys Gym Third Floor	Initial	04-OCT-16	2.310	ppb
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	08-NOV-2023	16.100	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	08-NOV-2023	9.940	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	08-NOV-2023	8.440	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	08-NOV-2023	7.040	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush	03-JAN-2024	1.000	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush180	04-OCT-16	0.669	ppb
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush180	04-OCT-16	0.721	ppb
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush180	04-OCT-16	1.270	ppb
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Flush180	04-OCT-16	1.930	ppb
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Initial	04-OCT-16	1.830	ppb
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Initial	08-NOV-2023	10.900	ug/L
51555	51555-1-HAL-F11	Main-Outside Room 110, Left Fountain	Initial	03-JAN-2024	1.800	ug/L
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush	08-NOV-2023	2.690	ug/L
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush	08-NOV-2023	2.790	ug/L
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush	08-NOV-2023	2.830	ug/L
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush	08-NOV-2023	3.180	ug/L
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush180	04-OCT-16	0.783	ppb
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush180	04-OCT-16	0.896	ppb
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush180	04-OCT-16	0.804	ppb
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Flush180	04-OCT-16	0.765	ppb
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Initial	04-OCT-16	1.570	ppb
51555	51555-1-HAL-F12	Main-Outside Room 110, Right Fountain	Initial	08-NOV-2023	3.710	ug/L
51555	51555-1-HAL-F15	Main-Outside Room 127, Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F15	Main-Outside Room 127, Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F15	Main-Outside Room 127, Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F15	Main-Outside Room 127, Fountain	Initial	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F15	Main-Outside Room 127,	Flush	08-NOV-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	Fountain/Bottle Filler				
51555	51555-1-HAL-BF01	Main-Outside Room 127, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-BF01	Main-Outside Room 127, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-BF01	Main-Outside Room 127, Fountain/Bottle Filler	Flush	08-NOV-2023	1.000	ug/L
51555	51555-1-HAL-F16	Main-Outside Room 127, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F16	Main-Outside Room 127, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F16	Main-Outside Room 127, Fountain/Bottle Filler	Flush180	04-OCT-16	1.000	ppb
51555	51555-1-HAL-F16	Main-Outside Room 127, Fountain/Bottle Filler	Initial	04-OCT-16	1.000	ppb
51555	51555-1-HAL-BF01	Main-Outside Room 127, Fountain/Bottle Filler	Initial	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	04-OCT-16	59.400	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	04-OCT-16	58.800	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	04-OCT-16	67.900	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	11-NOV-16	6.100	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	11-NOV-16	11.000	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	11-NOV-16	10.000	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	11-NOV-16	8.800	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	04-OCT-16	65.200	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Initial	11-NOV-16	18.000	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Initial	27-OCT-17	0.500	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Initial	04-OCT-16	40.700	ppb
51555	51555-2-HAL-F07	Main-Outside Room 211, Right Fountain	Initial	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	08-NOV-2023	7.630	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	08-NOV-2023	22.400	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	08-NOV-2023	26.600	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	08-NOV-2023	26.300	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	12-MAR-2024	11.300	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	12-MAR-2024	13.300	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	12-MAR-2024	12.500	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	12-MAR-2024	10.500	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	26-JAN-2024	7.330	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	26-JAN-2024	8.550	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	26-JAN-2024	6.770	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	26-JAN-2024	6.040	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	03-JAN-2024	6.940	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	03-JAN-2024	5.860	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	03-JAN-2024	6.570	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush	03-JAN-2024	8.030	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush180	04-OCT-16	1.420	ppb
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush180	04-OCT-16	1.440	ppb
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush180	04-OCT-16	2.800	ppb
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Flush180	04-OCT-16	1.230	ppb
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Initial	04-OCT-16	1.580	ppb
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Initial	08-NOV-2023	4.620	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Initial	12-MAR-2024	9.050	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Initial	26-JAN-2024	8.570	ug/L
51555	51555-2-HAL-F03	Main-Outside Room 212, Left Fountain	Initial	03-JAN-2024	9.010	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	08-NOV-2023	16.800	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	08-NOV-2023	13.300	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	08-NOV-2023	9.860	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	08-NOV-2023	7.570	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	26-JAN-2024	1.210	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	26-JAN-2024	1.750	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	26-JAN-2024	1.000	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	03-JAN-2024	2.890	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	03-JAN-2024	2.580	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	03-JAN-2024	1.780	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush	03-JAN-2024	1.760	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush180	04-OCT-16	0.610	ppb
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush180	04-OCT-16	0.636	ppb
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush180	04-OCT-16	0.564	ppb
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Flush180	04-OCT-16	0.599	ppb
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Initial	04-OCT-16	1.190	ppb
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Initial	08-NOV-2023	14.700	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Initial	26-JAN-2024	1.740	ug/L
51555	51555-2-HAL-F04	Main-Outside Room 212, Right Fountain	Initial	03-JAN-2024	6.070	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-2-HAL-F08	Main-Outside Room 215, Left Fountain	Flush180	04-OCT-16	0.125	ppb
51555	51555-2-HAL-F08	Main-Outside Room 215, Left Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-2-HAL-F08	Main-Outside Room 215, Left Fountain	Flush180	04-OCT-16	1.000	ppb
51555	51555-2-HAL-F08	Main-Outside Room 215, Left Fountain	Flush180	04-OCT-16	0.141	ppb
51555	51555-2-HAL-F08	Main-Outside Room 215, Left Fountain	Initial	04-OCT-16	0.247	ppb
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush	08-NOV-2023	2.020	ug/L
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush	08-NOV-2023	1.150	ug/L
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush180	04-OCT-16	0.874	ppb
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush180	04-OCT-16	0.704	ppb
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush180	04-OCT-16	0.791	ppb
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Flush180	04-OCT-16	1.310	ppb
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Initial	04-OCT-16	0.464	ppb
51555	51555-2-HAL-F09	Main-Outside Room 215, Right Fountain	Initial	08-NOV-2023	1.000	ug/L
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush	08-NOV-2023	1.800	ug/L
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush	08-NOV-2023	1.800	ug/L
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush	08-NOV-2023	1.750	ug/L
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush	08-NOV-2023	1.750	ug/L
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush180	04-OCT-16	1.660	ppb
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush180	04-OCT-16	1.810	ppb
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush180	04-OCT-16	1.680	ppb
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Flush180	04-OCT-16	1.610	ppb
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Initial	04-OCT-16	1.920	ppb
51555	51555-2-HAL-F01	Main-Outside Room 220, Left Fountain	Initial	08-NOV-2023	2.610	ug/L
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush	08-NOV-2023	2.060	ug/L
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush	08-NOV-2023	2.280	ug/L
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush	08-NOV-2023	2.110	ug/L
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush	08-NOV-2023	2.020	ug/L
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush180	04-OCT-16	2.230	ppb
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush180	04-OCT-16	2.640	ppb
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush180	04-OCT-16	2.290	ppb
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Flush180	04-OCT-16	2.050	ppb
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Initial	04-OCT-16	2.100	ppb
51555	51555-2-HAL-F02	Main-Outside Room 220, Right Fountain	Initial	08-NOV-2023	2.620	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	08-NOV-2023	5.710	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	08-NOV-2023	6.500	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	08-NOV-2023	6.630	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03	Fountain				
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	08-NOV-2023	8.730	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	12-MAR-2024	4.300	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	12-MAR-2024	1.820	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	12-MAR-2024	2.010	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	12-MAR-2024	1.580	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	26-JAN-2024	10.200	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	26-JAN-2024	8.500	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	26-JAN-2024	5.030	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	26-JAN-2024	4.760	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	03-JAN-2024	4.380	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	03-JAN-2024	6.850	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	03-JAN-2024	4.360	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush	03-JAN-2024	2.610	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush180	04-OCT-16	2.360	ppb
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush180	04-OCT-16	2.450	ppb
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush180	04-OCT-16	3.350	ppb
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Flush180	04-OCT-16	4.020	ppb
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Initial	04-OCT-16	2.590	ppb
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Initial	08-NOV-2023	6.640	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Initial	12-MAR-2024	55.000	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Initial	26-JAN-2024	1.070	ug/L
51555	51555-3-HAL-F03	Main-Outside Room 310, Left Fountain	Initial	03-JAN-2024	1.520	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	08-NOV-2023	6.010	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	08-NOV-2023	5.050	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	08-NOV-2023	4.380	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	08-NOV-2023	4.040	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	12-MAR-2024	1.320	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	12-MAR-2024	1.130	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	12-MAR-2024	1.120	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	12-MAR-2024	1.060	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	26-JAN-2024	3.330	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	26-JAN-2024	3.080	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	26-JAN-2024	3.130	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	26-JAN-2024	4.210	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	03-JAN-2024	5.420	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	03-JAN-2024	6.000	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	03-JAN-2024	4.760	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04	Fountain				
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush	03-JAN-2024	3.020	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush180	04-OCT-16	1.880	ppb
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush180	04-OCT-16	1.590	ppb
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush180	04-OCT-16	1.150	ppb
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Flush180	04-OCT-16	1.800	ppb
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Initial	04-OCT-16	2.450	ppb
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Initial	08-NOV-2023	8.500	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Initial	12-MAR-2024	1.080	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Initial	26-JAN-2024	26.600	ug/L
51555	51555-3-HAL-F04	Main-Outside Room 310, Right Fountain	Initial	03-JAN-2024	23.300	ug/L
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush	08-NOV-2023	3.150	ug/L
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush	08-NOV-2023	2.290	ug/L
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush	08-NOV-2023	2.130	ug/L
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush	08-NOV-2023	1.980	ug/L
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush180	04-OCT-16	2.530	ppb
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush180	04-OCT-16	3.580	ppb
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush180	04-OCT-16	2.470	ppb
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Flush180	04-OCT-16	2.510	ppb
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Initial	04-OCT-16	4.450	ppb
51555	51555-3-HAL-F01	Main-Outside Room 314, Left Fountain	Initial	08-NOV-2023	4.760	ug/L
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush180	04-OCT-16	0.335	ppb
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush180	04-OCT-16	0.353	ppb
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush180	04-OCT-16	0.333	ppb
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Flush180	04-OCT-16	0.394	ppb
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Initial	04-OCT-16	0.375	ppb
51555	51555-3-HAL-F09	Main-Outside Room 315, Left Fountain	Initial	08-NOV-2023	1.000	ug/L
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush	08-NOV-2023	1.700	ug/L
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush	08-NOV-2023	3.440	ug/L
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush	08-NOV-2023	3.320	ug/L
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush	08-NOV-2023	2.130	ug/L
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush180	04-OCT-16	0.926	ppb
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush180	04-OCT-16	0.736	ppb
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush180	04-OCT-16	0.785	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Flush180	04-OCT-16	0.876	ppb
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Initial	04-OCT-16	1.070	ppb
51555	51555-3-HAL-F10	Main-Outside Room 315, Right Fountain	Initial	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush	08-NOV-2023	1.490	ug/L
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush	08-NOV-2023	1.620	ug/L
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush	08-NOV-2023	1.750	ug/L
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush	08-NOV-2023	1.790	ug/L
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	04-OCT-16	3.440	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	04-OCT-16	3.260	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	04-OCT-16	2.300	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	04-OCT-16	2.730	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Flush180	27-OCT-17	0.500	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Initial	27-OCT-17	0.500	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Initial	04-OCT-16	1.320	ppb
51555	51555-4-HAL-F03	Main-Outside Room 410, Left Fountain	Initial	08-NOV-2023	2.640	ug/L
51555	51555-4-HAL-F04	Main-Outside Room 410, Right Fountain	Flush180	04-OCT-16	2.060	ppb
51555	51555-4-HAL-F04	Main-Outside Room 410, Right Fountain	Flush180	04-OCT-16	2.990	ppb
51555	51555-4-HAL-F04	Main-Outside Room 410, Right Fountain	Flush180	04-OCT-16	1.510	ppb
51555	51555-4-HAL-F04	Main-Outside Room 410, Right Fountain	Flush180	04-OCT-16	3.540	ppb
51555	51555-4-HAL-F04	Main-Outside Room 410, Right Fountain	Initial	04-OCT-16	1.780	ppb
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	08-NOV-2023	3.740	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	08-NOV-2023	2.540	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	08-NOV-2023	2.470	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	08-NOV-2023	2.490	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	03-JAN-2024	3.690	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	03-JAN-2024	3.290	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	03-JAN-2024	3.100	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush	03-JAN-2024	3.210	ug/L
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush180	04-OCT-16	2.630	ppb
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush180	04-OCT-16	4.250	ppb
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush180	04-OCT-16	9.580	ppb
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Flush180	04-OCT-16	3.040	ppb
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Initial	04-OCT-16	5.360	ppb
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Initial	08-NOV-2023	6.120	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51555	51555-4-HAL-F01	Main-Outside Room 416, Left Fountain	Initial	03-JAN-2024	3.660	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	08-NOV-2023	3.380	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	08-NOV-2023	2.970	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	08-NOV-2023	2.890	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	08-NOV-2023	2.890	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	12-MAR-2024	4.880	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	12-MAR-2024	4.190	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	12-MAR-2024	4.490	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	12-MAR-2024	4.850	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	26-JAN-2024	4.070	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	26-JAN-2024	5.700	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	26-JAN-2024	4.350	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	26-JAN-2024	3.180	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	03-JAN-2024	3.950	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	03-JAN-2024	4.200	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	03-JAN-2024	3.680	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush	03-JAN-2024	3.890	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush180	04-OCT-16	2.540	ppb
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush180	04-OCT-16	2.330	ppb
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush180	04-OCT-16	3.110	ppb
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Flush180	04-OCT-16	2.780	ppb
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Initial	04-OCT-16	2.890	ppb
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Initial	08-NOV-2023	6.540	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Initial	12-MAR-2024	3.580	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Initial	26-JAN-2024	1.990	ug/L
51555	51555-4-HAL-F02	Main-Outside Room 416, Right Fountain	Initial	03-JAN-2024	11.000	ug/L
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush	08-NOV-2023	1.000	ug/L
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush180	04-OCT-16	0.737	ppb
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush180	04-OCT-16	0.632	ppb
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush180	04-OCT-16	0.672	ppb
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Flush180	04-OCT-16	0.982	ppb
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Initial	04-OCT-16	2.110	ppb
51555	51555-4-HAL-F10	Main-Outside Room 417, Right Fountain	Initial	08-NOV-2023	1.120	ug/L

