



Sep 10, 2024

WENTWORTH

7007 S LOOMIS BLVD, Chicago IL 60636.

Dear **WENTWORTH** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WENTWORTH

7007 S LOOMIS BLVD, Chicago IL 60636.

Estimadas familias de **WENTWORTH**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51371	51371-B-S-KIT-KS03		Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS03		Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS03		Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS03		Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS03		Initial	08-MAY-19	1.000	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	25-MAY-16	1.870	ppb
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	25-MAY-16	1.730	ppb
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	25-MAY-16	1.900	ppb
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	25-MAY-16	1.540	ppb
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	08-MAY-19	2.530	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	08-MAY-19	2.170	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	08-MAY-19	1.500	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	08-MAY-19	1.280	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Flush180	21-AUG-20	1.000	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Initial	25-MAY-16	0.817	ppb
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Initial	08-MAY-19	1.930	ug/L
51371	51371-1-S-HAL-F01	1st Floor Fountain #1	Initial	21-AUG-20	4.700	ug/L
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	25-MAY-16	2.380	ppb
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	25-MAY-16	2.290	ppb
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	25-MAY-16	2.040	ppb
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	25-MAY-16	2.100	ppb
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	08-MAY-19	3.030	ug/L
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	08-MAY-19	2.420	ug/L
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	08-MAY-19	2.320	ug/L
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Flush180	08-MAY-19	2.040	ug/L
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Initial	25-MAY-16	1.780	ppb
51371	51371-2-S-HAL-F01	2nd Floor Fountain #1	Initial	08-MAY-19	2.630	ug/L
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	25-MAY-16	20.100	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	25-MAY-16	35.500	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	25-MAY-16	8.540	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	18-AUG-16	4.500	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	18-AUG-16	3.400	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	18-AUG-16	3.000	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	18-AUG-16	2.700	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Flush180	25-MAY-16	11.400	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Initial	25-MAY-16	15.300	ppb
51371	51371-2-HAL-F02	2nd Floor Fountain #2	Initial	18-AUG-16	4.900	ppb
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	25-MAY-16	2.450	ppb
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	25-MAY-16	2.380	ppb
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	25-MAY-16	2.170	ppb
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	25-MAY-16	3.000	ppb
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	08-MAY-19	2.160	ug/L
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	08-MAY-19	3.310	ug/L
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	08-MAY-19	2.970	ug/L
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	08-MAY-19	2.710	ug/L
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Flush180	21-AUG-20	1.000	ug/L
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Initial	25-MAY-16	3.630	ppb
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Initial	08-MAY-19	1.900	ug/L
51371	51371-3-S-HAL-F01	3rd Floor Fountain #1	Initial	21-AUG-20	1.000	ug/L
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	18-AUG-16	3.200	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	18-AUG-16	4.600	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	25-MAY-16	2.630	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	25-MAY-16	2.950	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	25-MAY-16	3.830	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	25-MAY-16	21.000	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	18-AUG-16	3.700	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Flush180	18-AUG-16	2.700	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Initial	25-MAY-16	6.270	ppb
51371	51371-3-HAL-F02	3rd Floor Fountain #2	Initial	18-AUG-16	3.400	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	25-MAY-16	35.900	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	25-MAY-16	47.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	25-MAY-16	93.200	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	25-MAY-16	110.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	18-AUG-16	14.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	18-AUG-16	24.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	18-AUG-16	4.100	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	18-AUG-16	3.600	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	01-SEP-16	1.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	01-SEP-16	1.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	01-SEP-16	1.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Flush180	01-SEP-16	1.000	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Initial	25-MAY-16	28.200	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51371	51371-B-HAL-F02	Basement Fountain 1 East	Initial	18-AUG-16	4.900	ppb
51371	51371-B-HAL-F02	Basement Fountain 1 East	Initial	01-SEP-16	1.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	18-AUG-16	3.400	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	25-MAY-16	132.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	25-MAY-16	108.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	18-AUG-16	7.200	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	18-AUG-16	12.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	25-MAY-16	28.400	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	25-MAY-16	31.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Flush180	18-AUG-16	14.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Initial	25-MAY-16	170.000	ppb
51371	51371-B-HAL-F03	Basement Fountain 2 East	Initial	18-AUG-16	9.900	ppb
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	25-MAY-16	0.342	ppb
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	25-MAY-16	0.325	ppb
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	25-MAY-16	0.295	ppb
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	25-MAY-16	0.383	ppb
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Initial	25-MAY-16	0.371	ppb
51371	51371-B-S-KIT-KS01	Basement Kitchen Sink east	Initial	08-MAY-19	1.000	ug/L
51371	51371-B-CAF-BF01	Bottle Filler in Cafeteria	Flush180	06-DEC-22	6.780	ug/L
51371	51371-B-CAF-BF01	Bottle Filler in Cafeteria	Flush180	06-DEC-22	6.560	ug/L
51371	51371-B-CAF-BF01	Bottle Filler in Cafeteria	Flush180	06-DEC-22	6.680	ug/L
51371	51371-B-CAF-BF01	Bottle Filler in Cafeteria	Flush180	06-DEC-22	7.560	ug/L
51371	51371-B-CAF-BF01	Bottle Filler in Cafeteria	Initial	06-DEC-22	4.560	ug/L
51371	51371-B-S-KIT-KS02	Center dishwashing slnk	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS02	Center dishwashing slnk	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS02	Center dishwashing slnk	Flush180	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS02	Center dishwashing slnk	Initial	08-MAY-19	1.000	ug/L
51371	51371-B-S-KIT-KS02	Center dishwashing slnk	Initial	08-MAY-19	1.000	ug/L
51371	51371-B-CAF-F01	Fountain in Cafeteria	Flush180	06-DEC-22	1.800	ug/L
51371	51371-B-CAF-F01	Fountain in Cafeteria	Flush180	06-DEC-22	1.490	ug/L
51371	51371-B-CAF-F01	Fountain in Cafeteria	Flush180	06-DEC-22	1.940	ug/L
51371	51371-B-CAF-F01	Fountain in Cafeteria	Flush180	06-DEC-22	3.850	ug/L
51371	51371-B-CAF-F01	Fountain in Cafeteria	Initial	06-DEC-22	1.350	ug/L
51371	51371-1-120-	Inside Room 120, Fountain	Flush180	01-DEC-21	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51371	51371-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	1.000	ug/L
51371	51371-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	1.000	ug/L
51371	51371-1-120-F01	Inside Room 120, Fountain	Flush180	01-DEC-21	1.000	ug/L
51371	51371-1-120-F01	Inside Room 120, Fountain	Initial	01-DEC-21	1.000	ug/L
51371	51371-1-124-F01	Inside Room 124, Fountain	Flush180	01-DEC-21	1.490	ug/L
51371	51371-1-124-F01	Inside Room 124, Fountain	Flush180	01-DEC-21	1.350	ug/L
51371	51371-1-124-F01	Inside Room 124, Fountain	Flush180	01-DEC-21	1.000	ug/L
51371	51371-1-124-F01	Inside Room 124, Fountain	Flush180	01-DEC-21	1.000	ug/L
51371	51371-1-124-F01	Inside Room 124, Fountain	Initial	01-DEC-21	2.680	ug/L
51371	51371-1-HAL-BF01	Outside room 100, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-BF01	Outside room 100, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-BF01	Outside room 100, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-BF01	Outside room 100, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-BF01	Outside room 100, Bottle Filler	Initial	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-F02	Outside room 100, Fountain	Flush180	06-DEC-22	3.270	ug/L
51371	51371-1-HAL-F02	Outside room 100, Fountain	Flush180	06-DEC-22	1.110	ug/L
51371	51371-1-HAL-F02	Outside room 100, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-F02	Outside room 100, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-1-HAL-F02	Outside room 100, Fountain	Initial	06-DEC-22	1.980	ug/L
51371	51371-2-HAL-BF01	Outside room 205, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-BF01	Outside room 205, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-BF01	Outside room 205, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-BF01	Outside room 205, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-BF01	Outside room 205, Bottle Filler	Initial	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-F03	Outside room 205, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-F03	Outside room 205, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-F03	Outside room 205, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-F03	Outside room 205, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-2-HAL-F03	Outside room 205, Fountain	Initial	06-DEC-22	1.200	ug/L
51371	51371-3-HAL-BF01	Outside room 305, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-BF01	Outside room 305, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-BF01	Outside room 305, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-BF01	Outside room 305, Bottle Filler	Flush180	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-BF01	Outside room 305, Bottle Filler	Initial	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-F03	Outside room 305, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-F03	Outside room 305, Fountain	Flush180	06-DEC-22	1.360	ug/L
51371	51371-3-HAL-F03	Outside room 305, Fountain	Flush180	06-DEC-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51371	51371-3-HAL-F03	Outside room 305, Fountain	Flush180	06-DEC-22	1.000	ug/L
51371	51371-3-HAL-F03	Outside room 305, Fountain	Initial	06-DEC-22	2.140	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	25-MAY-16	0.221	ppb
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	25-MAY-16	0.233	ppb
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	25-MAY-16	0.356	ppb
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	25-MAY-16	0.221	ppb
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Flush180	21-AUG-20	1.000	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Initial	25-MAY-16	0.522	ppb
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Initial	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F01	Annex 1st Floor Fountain #1	Initial	21-AUG-20	1.000	ug/L
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	25-MAY-16	0.237	ppb
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	25-MAY-16	0.154	ppb
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	25-MAY-16	0.211	ppb
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	25-MAY-16	0.163	ppb
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Initial	25-MAY-16	0.718	ppb
52384	52384-1-S-HAL-F02	Annex 1st Floor Fountain #2	Initial	08-MAY-19	1.000	ug/L
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	25-MAY-16	0.726	ppb
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	25-MAY-16	0.550	ppb
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	25-MAY-16	0.834	ppb
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	25-MAY-16	0.753	ppb
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Initial	25-MAY-16	0.740	ppb
52384	52384-1-W-KIT-KS01	Annex 1st Floor Kitch Sink	Initial	08-MAY-19	1.150	ug/L
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	25-MAY-16	2.590	ppb
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	25-MAY-16	1.070	ppb
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	25-MAY-16	1.330	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	25-MAY-16	1.020	ppb
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	08-MAY-19	1.110	ug/L
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	08-MAY-19	1.380	ug/L
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Initial	25-MAY-16	2.740	ppb
52384	52384-1-N-120-S01	Annex 1st Floor Room 120 Sink	Initial	08-MAY-19	1.860	ug/L
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	25-MAY-16	0.761	ppb
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	25-MAY-16	0.250	ppb
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	25-MAY-16	0.742	ppb
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	25-MAY-16	0.720	ppb
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Flush180	08-MAY-19	1.000	ug/L
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Initial	25-MAY-16	0.631	ppb
52384	52384-1-S-125-S01	Annex 1st Floor Sink Room 125	Initial	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	25-MAY-16	0.174	ppb
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	25-MAY-16	0.233	ppb
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	25-MAY-16	0.678	ppb
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	25-MAY-16	0.174	ppb
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Flush180	21-AUG-20	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Initial	25-MAY-16	0.722	ppb
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Initial	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F01	Annex 2nd Floor Fountain #1	Initial	21-AUG-20	1.630	ug/L
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	25-MAY-16	0.168	ppb
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	25-MAY-16	0.173	ppb
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	25-MAY-16	0.183	ppb
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	25-MAY-16	0.162	ppb
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Flush180	08-MAY-19	1.000	ug/L

Water Quality Assessment
Daniel S Wentworth Elementary School

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Initial	25-MAY-16	0.411	ppb
52384	52384-2-S-HAL-F02	Annex 2nd Floor Fountain #2	Initial	08-MAY-19	1.000	ug/L