



Sep 10, 2024

WESTINGHOUSE HS

3223 W FRANKLIN BLVD, Chicago IL 60624.

Dear **WESTINGHOUSE HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WESTINGHOUSE HS

3223 W FRANKLIN BLVD, Chicago IL 60624.

Estimadas familias de **WESTINGHOUSE HS:**

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarle y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC01	Main- Across From Room 200, Left Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC02	Main- Across From Room 200, Right Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC03	Main- Across From Room 230, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC03	Main- Across From Room 230, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC03	Main- Across From Room 230, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC03	Main- Across From Room 230, Left Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC04	Main- Across From Room 230, Right Fountain	Initial	03-JUN-22	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54663	54663-2-HAL-WC06	Main- By Room 251, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-WC06	Main- By Room 251, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-2-HAL-WC06	Main- By Room 251, Right Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	02-NOV-16	0.209	ppb
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	02-NOV-16	0.248	ppb
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	02-NOV-16	0.812	ppb
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	02-NOV-16	0.282	ppb
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Initial	02-NOV-16	0.587	ppb
54663	54663-1-KIT-KS07	Main- East Prep Room Sink	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Initial	02-NOV-16	1.000	ppb
54663	54663-1-GYM-F20	Main- Inside Gym, Fountain on North End	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-POOL-F22	Main- Inside Pool Area, Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	02-NOV-16	1.460	ppb
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	02-NOV-16	1.140	ppb
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	02-NOV-16	1.270	ppb
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	02-NOV-16	2.680	ppb
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	03-JUN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS05	North Faucet				
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Initial	02-NOV-16	3.240	ppb
54663	54663-1-KIT-KS05	Main- Kitchen Kettle, West Wall, North Faucet	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	02-NOV-16	2.010	ppb
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	02-NOV-16	2.200	ppb
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	02-NOV-16	1.310	ppb
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	02-NOV-16	1.090	ppb
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Initial	02-NOV-16	23.600	ppb
54663	54663-1-KIT-KS04	Main- Kitchen Kettle, West Wall, South Faucet	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	02-NOV-16	0.459	ppb
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	02-NOV-16	0.196	ppb
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	02-NOV-16	0.580	ppb
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Initial	02-NOV-16	0.224	ppb
54663	54663-1-KIT-KS03	Main- Kitchen, Center Sink	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	02-NOV-16	0.507	ppb
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	02-NOV-16	0.650	ppb
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	02-NOV-16	0.872	ppb
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	02-NOV-16	2.090	ppb
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Initial	02-NOV-16	1.960	ppb
54663	54663-1-KIT-KS06	Main- Kitchen, East Wall, Pot Filler Stove Faucet	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-KIT-	Main- Kitchen, North Wall, East	Flush180	02-NOV-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	KS02	Faucet				
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	02-NOV-16	0.144	ppb
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Initial	02-NOV-16	0.690	ppb
54663	54663-1-KIT-KS02	Main- Kitchen, North Wall, East Faucet	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	02-NOV-16	0.203	ppb
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Initial	02-NOV-16	0.394	ppb
54663	54663-1-KIT-KS01	Main- Kitchen, North Wall, West Faucet	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC12	Main- Next to Janitors Closet 105D, Left Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC13	Main- Next to Janitors Closet 105D, Right Fountain	Initial	02-NOV-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
54663	54663-1-HAL-WC15	Main- Next to Janitors Closet 165D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC15	Main- Next to Janitors Closet 165D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC15	Main- Next to Janitors Closet 165D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC15	Main- Next to Janitors Closet 165D, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC15	Main- Next to Janitors Closet 165D, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC15	Main- Next to Janitors Closet 165D, Right Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC11	Main- Next to Main Office, Left Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC10	Main- Next to Main Office, Right Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	10-DEC-20	1.000	ug/L
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Initial	10-DEC-20	1.000	ug/L
54663	54663-1-HAL-WC17	Main- Next to Pump Room 150F, Left Fountain	Initial	03-JUN-22	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC17	Left Fountain				
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC16	Main- Next to Pump Room 150F, Right Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC18	Main- Next to Staff Room 143B, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC18	Main- Next to Staff Room 143B, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC18	Main- Next to Staff Room 143B, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC18	Main- Next to Staff Room 143B, Left Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC18	Main- Next to Staff Room 143B, Left Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-BF01	Main- Next to Staff Room 143B, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-BF01	Main- Next to Staff Room 143B, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-BF01	Main- Next to Staff Room 143B, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-BF01	Main- Next to Staff Room 143B, Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-BF01	Main- Next to Staff Room 143B, Left Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Initial	02-NOV-16	1.000	ppb
54663	54663-1-HAL-WC19	Main- Next to Staff Room 143B, Right Fountain	Initial	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-BF01	Next to Janitors closet 221D Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-BF01	Next to Janitors closet 221D Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-BF01	Next to Janitors closet 221D Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-BF01	Next to Janitors closet 221D Left Fountain	Flush180	03-JUN-22	1.000	ug/L
54663	54663-2-HAL-BF01	Next to Janitors closet 221D Left Fountain	Initial	03-JUN-22	1.000	ug/L

