



Sep 10, 2024

WHITNEY

2815 S KOMENSKY AVE, Chicago IL 60623.

Dear **WHITNEY** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

WHITNEY

2815 S KOMENSKY AVE, Chicago IL 60623.

Estimadas familias de **WHITNEY**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
50002	50002-1-W-M1-S02	Modular 2	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-W-M1-S02	Modular 2	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-W-M1-S02	Modular 2	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-W-M1-S02	Modular 2	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-W-M1-S02	Modular 2	Initial	05-MAR-20	1.000	ug/L
50002	50002-1-M2-S02	Modular 2- Eastwall Inside M2 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-M2-S02	Modular 2- Eastwall Inside M2 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-M2-S02	Modular 2- Eastwall Inside M2 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-M2-S02	Modular 2- Eastwall Inside M2 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-M2-S02	Modular 2- Eastwall Inside M2 Classroom, Sink	Initial	04-JUN-16	1.000	ppb
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	04-JUN-16	0.177	ppb
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	04-JUN-16	1.000	ppb
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Flush180	05-MAR-20	1.000	ug/L
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Initial	04-JUN-16	1.000	ppb
50002	50002-1-E-M1-S01	Modular 2- Westwall Inside M1 Classroom, Sink	Initial	05-MAR-20	1.000	ug/L
51282	51282-B-S-KIT-KS02	Basement Kitchen, Right Sink	Flush180	05-MAR-20	1.510	ug/L
51282	51282-B-S-KIT-KS02	Basement Kitchen, Right Sink	Flush180	05-MAR-20	1.410	ug/L
51282	51282-B-S-KIT-KS02	Basement Kitchen, Right Sink	Flush180	05-MAR-20	1.270	ug/L
51282	51282-B-S-KIT-KS02	Basement Kitchen, Right Sink	Flush180	05-MAR-20	4.400	ug/L
51282	51282-B-S-KIT-KS02	Basement Kitchen, Right Sink	Initial	05-MAR-20	1.420	ug/L
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	04-JUN-16	0.455	ppb
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	04-JUN-16	0.340	ppb
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	04-JUN-16	0.920	ppb
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	04-JUN-16	0.481	ppb
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Initial	04-JUN-16	0.269	ppb
51282	51282-2-W-HAL-F01	Main- 2nd FI North Corridor Next to Room 204, Foun	Initial	05-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	04-JUN-16	1.760	ppb
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	04-JUN-16	1.540	ppb
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	04-JUN-16	1.710	ppb
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	04-JUN-16	1.640	ppb
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Flush180	05-MAR-20	1.000	ug/L
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Initial	04-JUN-16	2.080	ppb
51282	51282-2-N-HAL-F02	Main- 2nd Fl. South Corridor Outside Room 208, Fou	Initial	05-MAR-20	1.000	ug/L
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	04-JUN-16	2.920	ppb
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	04-JUN-16	2.180	ppb
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	04-JUN-16	2.310	ppb
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	04-JUN-16	1.820	ppb
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	05-MAR-20	1.010	ug/L
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	05-MAR-20	1.190	ug/L
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	05-MAR-20	1.120	ug/L
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Flush180	05-MAR-20	1.000	ug/L
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Initial	04-JUN-16	0.871	ppb
51282	51282-3-N-HAL-F02	Main- 3rd Fl. South Corridor Outside Room 308, Fou	Initial	05-MAR-20	1.000	ug/L
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	04-JUN-16	0.580	ppb
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	04-JUN-16	0.328	ppb
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	04-JUN-16	0.902	ppb
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	04-JUN-16	0.386	ppb
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	05-MAR-20	1.010	ug/L
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Initial	04-JUN-16	0.733	ppb
51282	51282-B-S-KIT-KS01	Main- Basement Kitchen Southwall, Left Sink	Initial	05-MAR-20	1.090	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	04-JUN-16	2.550	ppb
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	04-JUN-16	2.460	ppb
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	04-JUN-16	2.940	ppb
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	04-JUN-16	2.610	ppb
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	24-JUL-20	10.700	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	28-OCT-20	1.000	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	28-OCT-20	1.050	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	28-OCT-20	1.030	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	28-OCT-20	1.200	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	05-MAR-20	1.040	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	05-MAR-20	1.040	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Flush180	05-MAR-20	1.050	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Initial	04-JUN-16	2.360	ppb
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Initial	24-JUL-20	9.000	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Initial	28-OCT-20	1.000	ug/L
51282	51282-B-S-HAL-F05	Main- Basement Next to Room 001, Fountain	Initial	05-MAR-20	1.160	ug/L
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	04-JUN-16	1.630	ppb
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	04-JUN-16	1.550	ppb
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	04-JUN-16	1.540	ppb
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	04-JUN-16	1.440	ppb
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	05-MAR-20	1.090	ug/L
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Initial	04-JUN-16	1.560	ppb
51282	51282-B-S-HAL-F02	Main- Basement Next to Room 009, Left Fountain	Initial	05-MAR-20	1.100	ug/L
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	04-JUN-16	1.340	ppb
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	04-JUN-16	1.550	ppb
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	04-JUN-16	1.690	ppb
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	04-JUN-16	1.240	ppb
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	05-MAR-20	1.080	ug/L
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	05-MAR-20	1.070	ug/L
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	05-MAR-20	1.170	ug/L
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Flush180	05-MAR-20	1.100	ug/L
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Initial	04-JUN-16	3.160	ppb
51282	51282-B-S-HAL-F03	Main- Basement Outside Room 009, Right Fountain	Initial	05-MAR-20	1.000	ug/L
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	04-JUN-16	0.873	ppb
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	04-JUN-16	0.208	ppb
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	04-JUN-16	0.796	ppb
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	04-JUN-16	0.677	ppb
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	05-MAR-20	1.120	ug/L
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	05-MAR-20	1.130	ug/L
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Flush180	05-MAR-20	1.250	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Corridor, Fountain				
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Initial	04-JUN-16	0.262	ppb
51282	51282-1-N-HAL-F02	Main- Next to Room 108 South Corridor, Fountain	Initial	05-MAR-20	1.260	ug/L
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	04-JUN-16	0.940	ppb
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	04-JUN-16	0.964	ppb
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	04-JUN-16	0.849	ppb
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	04-JUN-16	0.411	ppb
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	24-JUL-20	3.660	ug/L
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Flush180	05-MAR-20	1.000	ug/L
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Initial	04-JUN-16	0.593	ppb
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Initial	24-JUL-20	1.870	ug/L
51282	51282-3-W-HAL-F01	Main- North Corridor Outside Room 304, Fountain	Initial	05-MAR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	04-JUN-16	0.230	ppb
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	04-JUN-16	0.252	ppb
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	04-JUN-16	1.000	ppb
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	04-JUN-16	0.179	ppb
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	23-APR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	23-APR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	24-JUL-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	23-APR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	23-APR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	05-MAR-20	7.990	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	05-MAR-20	8.590	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	05-MAR-20	3.620	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Flush180	05-MAR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Initial	04-JUN-16	1.000	ppb
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Initial	23-APR-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Initial	24-JUL-20	1.000	ug/L
53890	53890-1-N-HAL-F01	Modular 1- South Entry Door, Fountain	Initial	05-MAR-20	5.430	ug/L
59845	59845-2-E-HAL-F03	Annex, Across from Room 222	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F03	Annex, Across from Room 222	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F03	Annex, Across from Room 222	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F03	Annex, Across from Room 222	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F03	Annex, Across from Room 222	Initial	05-MAR-20	1.000	ug/L
59845	59845-2-E-	Annex- Across Room 213,	Flush180	04-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	HAL-F02	Fountain				
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	04-JUN-16	1.000	ppb
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	04-JUN-16	1.000	ppb
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	04-JUN-16	1.000	ppb
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	24-JUL-20	1.000	ug/L
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Initial	04-JUN-16	1.000	ppb
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Initial	24-JUL-20	1.000	ug/L
59845	59845-2-E-HAL-F02	Annex- Across Room 213, Fountain	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Initial	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F06	Annex- Across from Room 114, Fountain 1	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Initial	04-JUN-16	1.000	ppb
59845	59845-1-E-HAL-F07	Annex- Across from Room 114, Fountain 2	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-113-F11	Annex- Inside Room 113, Fountain	Flush180	04-JUN-16	0.781	ppb
59845	59845-1-113-F11	Annex- Inside Room 113, Fountain	Flush180	04-JUN-16	5.410	ppb
59845	59845-1-113-F11	Annex- Inside Room 113, Fountain	Flush180	04-JUN-16	1.720	ppb
59845	59845-1-113-F11	Annex- Inside Room 113, Fountain	Flush180	04-JUN-16	0.936	ppb
59845	59845-1-113-F11	Annex- Inside Room 113, Fountain	Initial	04-JUN-16	1.240	ppb
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	04-JUN-16	0.163	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	04-JUN-16	0.137	ppb
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	04-JUN-16	0.564	ppb
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	04-JUN-16	0.192	ppb
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Initial	04-JUN-16	0.155	ppb
59845	59845-1-E-113-S10	Annex- Inside Room 113, Sink	Initial	05-MAR-20	4.820	ug/L
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	04-JUN-16	0.231	ppb
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	04-JUN-16	0.129	ppb
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	04-JUN-16	0.555	ppb
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	04-JUN-16	0.225	ppb
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Initial	04-JUN-16	0.144	ppb
59845	59845-1-E-114-F09	Annex- Inside Room 114 Eastwall, Fountain	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	04-JUN-16	0.125	ppb
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	04-JUN-16	0.153	ppb
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	04-JUN-16	0.314	ppb
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	04-JUN-16	2.220	ppb
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	05-MAR-20	1.110	ug/L
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Initial	04-JUN-16	0.131	ppb
59845	59845-1-E-114-S08	Annex- Inside Room 114 Kindergarden, Sink	Initial	05-MAR-20	1.800	ug/L
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	04-JUN-16	1.820	ppb
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	04-JUN-16	0.544	ppb
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	04-JUN-16	0.528	ppb
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	04-JUN-16	0.371	ppb
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Flush180	05-MAR-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Initial	04-JUN-16	0.429	ppb
59845	59845-1-S-KIT-KS03	Annex- Kitchen Center, Sink	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	04-JUN-16	0.200	ppb
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	04-JUN-16	0.134	ppb
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	04-JUN-16	0.151	ppb
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	04-JUN-16	0.153	ppb
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Initial	04-JUN-16	0.134	ppb
59845	59845-1-N-KIT-KS02	Annex- Kitchen Northwall, Fountain	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Initial	04-JUN-16	0.382	ppb
59845	59845-1-N-KIT-KS01	Annex- Kitchen Northwall, Sink	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Initial	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F04	Annex- Outside Kitchen/ LunchRoom, Fountain 1	Initial	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	24-JUL-20	1.000	ug/L
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	05-MAR-20	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	CAF-F05	LunchRoom, Fountain 2				
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Flush180	05-MAR-20	1.000	ug/L
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Initial	04-JUN-16	1.000	ppb
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Initial	24-JUL-20	1.000	ug/L
59845	59845-1-W-CAF-F05	Annex- Outside Kitchen/ LunchRoom, Fountain 2	Initial	05-MAR-20	1.000	ug/L