



Sep 10, 2024

**WOODLAWN**

**6657 S KIMBARK AVE, Chicago IL 60637.**

Dear **WOODLAWN** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



**Sep 10, 2024**

**WOODLAWN**

**6657 S KIMBARK AVE, Chicago IL 60637.**

Estimadas familias de **WOODLAWN**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer  
Director de Salud y Seguridad Ambientales  
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	18-NOV-21	1.930	ug/L
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	18-NOV-21	2.160	ug/L
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	18-NOV-21	2.450	ug/L
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Flush180	18-NOV-21	2.430	ug/L
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Initial	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F02	Across From Room 201, Fountain	Initial	18-NOV-21	1.510	ug/L
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Flush180	18-NOV-21	1.040	ug/L
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Initial	03-JUN-16	1.000	ppb
51403	51403-1-100-S07	Inside Room 100A East, Sink 2	Initial	18-NOV-21	1.000	ug/L
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	03-JUN-16	8.300	ppb
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	18-NOV-21	1.810	ug/L
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	18-NOV-21	2.220	ug/L
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	18-NOV-21	1.260	ug/L
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Flush180	18-NOV-21	3.450	ug/L
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Initial	03-JUN-16	12.400	ppb
51403	51403-1-100-S06	Inside Room 100A South, Sink 1	Initial	18-NOV-21	3.910	ug/L
51403	51403-1-101-BF01	Inside Room 101, Bottle Filler	Flush180	01-SEP-22	1.180	ug/L
51403	51403-1-101-BF01	Inside Room 101, Bottle Filler	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-BF01	Inside Room 101, Bottle Filler	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-BF01	Inside Room 101, Bottle Filler	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-BF01	Inside Room 101, Bottle Filler	Initial	01-SEP-22	4.740	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51403	51403-1-101-F01	Inside Room 101, Fountain	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-F01	Inside Room 101, Fountain	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-F01	Inside Room 101, Fountain	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-F01	Inside Room 101, Fountain	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-F01	Inside Room 101, Fountain	Initial	01-SEP-22	1.000	ug/L
51403	51403-1-101-S01	Inside Room 101, Sink, Left	Flush180	01-SEP-22	1.600	ug/L
51403	51403-1-101-S01	Inside Room 101, Sink, Left	Flush180	01-SEP-22	1.610	ug/L
51403	51403-1-101-S01	Inside Room 101, Sink, Left	Flush180	01-SEP-22	1.220	ug/L
51403	51403-1-101-S01	Inside Room 101, Sink, Left	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-S01	Inside Room 101, Sink, Left	Initial	01-SEP-22	1.230	ug/L
51403	51403-1-101-S02	Inside Room 101, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-S02	Inside Room 101, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-S02	Inside Room 101, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-S02	Inside Room 101, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-101-S02	Inside Room 101, Sink, Right	Initial	01-SEP-22	1.000	ug/L
51403	51403-1-106-S02	Inside Room 106 North, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-106-S02	Inside Room 106 North, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-106-S02	Inside Room 106 North, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-106-S02	Inside Room 106 North, Sink 1	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-106-S02	Inside Room 106 North, Sink 1	Initial	03-JUN-16	1.000	ppb
51403	51403-1-106-S03	Inside Room 106 South, Sink 2	Flush180	03-JUN-16	21.500	ppb
51403	51403-1-106-S03	Inside Room 106 South, Sink 2	Flush180	03-JUN-16	39.500	ppb
51403	51403-1-106-S03	Inside Room 106 South, Sink 2	Flush180	03-JUN-16	26.600	ppb
51403	51403-1-106-S03	Inside Room 106 South, Sink 2	Flush180	03-JUN-16	11.200	ppb
51403	51403-1-106-S03	Inside Room 106 South, Sink 2	Initial	03-JUN-16	24.400	ppb
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush	14-MAY-2024	3.490	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush	14-MAY-2024	2.160	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush	14-MAY-2024	1.000	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush	14-MAY-2024	1.000	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	01-SEP-22	91.400	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	01-SEP-22	25.700	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	01-SEP-22	18.500	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Flush180	01-SEP-22	19.000	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Initial	01-SEP-22	178.000	ug/L
51403	51403-1-110-BF01	Inside Room 110, Bottle Filler	Initial	14-MAY-2024	12.200	ug/L
51403	51403-1-110-F01	Inside Room 110, Fountain	Flush180	01-SEP-22	2.070	ug/L
51403	51403-1-110-F01	Inside Room 110, Fountain	Flush180	01-SEP-22	1.320	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51403	51403-1-110-F01	Inside Room 110, Fountain	Flush180	01-SEP-22	1.120	ug/L
51403	51403-1-110-F01	Inside Room 110, Fountain	Flush180	01-SEP-22	1.030	ug/L
51403	51403-1-110-F01	Inside Room 110, Fountain	Initial	01-SEP-22	1.000	ug/L
51403	51403-1-110-S02	Inside Room 110, Sink, Left	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S02	Inside Room 110, Sink, Left	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S02	Inside Room 110, Sink, Left	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S02	Inside Room 110, Sink, Left	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S02	Inside Room 110, Sink, Left	Initial	01-SEP-22	1.000	ug/L
51403	51403-1-110-S03	Inside Room 110, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S03	Inside Room 110, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S03	Inside Room 110, Sink, Right	Flush180	01-SEP-22	1.690	ug/L
51403	51403-1-110-S03	Inside Room 110, Sink, Right	Flush180	01-SEP-22	1.000	ug/L
51403	51403-1-110-S03	Inside Room 110, Sink, Right	Initial	01-SEP-22	1.000	ug/L
51403	51403-1-110-S01	Inside Room 110	Flush180	18-NOV-21	1.600	ug/L
51403	51403-1-110-S01	Inside Room 110	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-110-S01	Inside Room 110	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-110-S01	Inside Room 110	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-110-S01	Inside Room 110	Initial	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Initial	03-JUN-16	1.000	ppb
51403	51403-1-KIT-KS05	Left, Kitchen Sink	Initial	18-NOV-21	1.000	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	29-AUG-23	2.370	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	29-AUG-23	1.140	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	29-AUG-23	1.340	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	19-SEP-23	1.000	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	19-SEP-23	1.070	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	19-SEP-23	1.000	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Flush180	19-SEP-23	1.000	ug/L
51403	51403-1-HAL-BF01	Near main entrance stairs, left bottle filler	Initial	29-AUG-23	9.830	ug/L
51403	51403-1-HAL-	Near main entrance stairs, left	Initial	19-SEP-23	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	BF01	bottle filler				
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	29-AUG-23	29.000	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	29-AUG-23	11.300	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	29-AUG-23	12.500	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	29-AUG-23	8.060	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	19-SEP-23	2.150	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	19-SEP-23	2.400	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	19-SEP-23	2.350	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Flush180	19-SEP-23	2.730	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Initial	29-AUG-23	11.100	ug/L
51403	51403-1-HAL-F02	Near main entrance stairs, left fountain	Initial	19-SEP-23	1.940	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	29-AUG-23	17.700	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	29-AUG-23	24.000	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	29-AUG-23	12.000	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	29-AUG-23	13.400	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	19-SEP-23	2.170	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	19-SEP-23	2.290	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	19-SEP-23	2.670	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Flush180	19-SEP-23	1.260	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Initial	29-AUG-23	18.800	ug/L
51403	51403-1-HAL-F03	Near main entrance stairs, right fountain	Initial	19-SEP-23	1.990	ug/L
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	29-AUG-23	1.070	ug/L
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Initial	29-AUG-23	2.380	ug/L
51403	51403-1-HAL-F04	Outside Main Office, Fountain	Initial	03-JUN-16	1.000	ppb
51403	51403-1-HAL-RBF01	Outside Main Office, Retrofitted Bottle Filler	Flush180	18-NOV-21	3.350	ug/L
51403	51403-1-HAL-RBF01	Outside Main Office, Retrofitted Bottle Filler	Flush180	18-NOV-21	3.300	ug/L
51403	51403-1-HAL-RBF01	Outside Main Office, Retrofitted Bottle Filler	Flush180	18-NOV-21	3.380	ug/L
51403	51403-1-HAL-RBF01	Outside Main Office, Retrofitted Bottle Filler	Flush180	18-NOV-21	3.510	ug/L
51403	51403-1-HAL-RBF01	Outside Main Office, Retrofitted Bottle Filler	Initial	18-NOV-21	3.130	ug/L
51403	51403-1-HAL-F01	Outside Room 109, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-	Outside Room 109, Fountain	Flush180	03-JUN-16	1.000	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F01					
51403	51403-1-HAL-F01	Outside Room 109, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-F01	Outside Room 109, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-1-HAL-F01	Outside Room 109, Fountain	Initial	03-JUN-16	1.000	ppb
51403	51403-1-HAL-RBF02	Outside Room 109, Retrofitted Bottle Filler	Flush180	18-NOV-21	2.310	ug/L
51403	51403-1-HAL-RBF02	Outside Room 109, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.780	ug/L
51403	51403-1-HAL-RBF02	Outside Room 109, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.750	ug/L
51403	51403-1-HAL-RBF02	Outside Room 109, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.700	ug/L
51403	51403-1-HAL-RBF02	Outside Room 109, Retrofitted Bottle Filler	Initial	18-NOV-21	2.330	ug/L
51403	51403-1-HAL-BF02	Outside Room 109, bottle filler	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-BF02	Outside Room 109, bottle filler	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-BF02	Outside Room 109, bottle filler	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-BF02	Outside Room 109, bottle filler	Flush180	29-AUG-23	1.000	ug/L
51403	51403-1-HAL-BF02	Outside Room 109, bottle filler	Initial	29-AUG-23	1.000	ug/L
51403	51403-2-HAL-F01	Outside Room 209, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F01	Outside Room 209, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F01	Outside Room 209, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F01	Outside Room 209, Fountain	Flush180	03-JUN-16	1.000	ppb
51403	51403-2-HAL-F01	Outside Room 209, Fountain	Initial	03-JUN-16	1.000	ppb
51403	51403-2-HAL-RBF01	Outside Room 209, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.230	ug/L
51403	51403-2-HAL-RBF01	Outside Room 209, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.150	ug/L
51403	51403-2-HAL-RBF01	Outside Room 209, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.100	ug/L
51403	51403-2-HAL-RBF01	Outside Room 209, Retrofitted Bottle Filler	Flush180	18-NOV-21	1.110	ug/L
51403	51403-2-HAL-RBF01	Outside Room 209, Retrofitted Bottle Filler	Initial	18-NOV-21	1.300	ug/L
51403	51403-1-KIT-KS06	Right, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS06	Right, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS06	Right, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS06	Right, Kitchen Sink	Flush180	18-NOV-21	1.000	ug/L
51403	51403-1-KIT-KS06	Right, Kitchen Sink	Initial	18-NOV-21	1.660	ug/L