



Sep 10, 2024

YOUNG HS

211 S LAFLIN ST, Chicago IL 60607.

Dear **YOUNG HS** families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

YOUNG HS

211 S LAFLIN ST, Chicago IL 60607.

Estimadas familias de **YOUNG HS**:

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51568	51568-B-KIT-KS02	3 Basin S. Wall Left Sink	Flush	19-DEC-2023	3.280	ug/L
51568	51568-B-KIT-KS02	3 Basin S. Wall Left Sink	Flush	19-DEC-2023	1.740	ug/L
51568	51568-B-KIT-KS02	3 Basin S. Wall Left Sink	Flush	19-DEC-2023	1.360	ug/L
51568	51568-B-KIT-KS02	3 Basin S. Wall Left Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS02	3 Basin S. Wall Left Sink	Initial	19-DEC-2023	2.320	ug/L
51568	51568-B-KIT-KS03	3 Basin S. Wall Right Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS03	3 Basin S. Wall Right Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS03	3 Basin S. Wall Right Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS03	3 Basin S. Wall Right Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS03	3 Basin S. Wall Right Sink	Initial	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-BF01	Bottle Filler by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-BF01	Bottle Filler by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-BF01	Bottle Filler by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-BF01	Bottle Filler by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-BF01	Bottle Filler by Door 9	Initial	19-DEC-2023	1.000	ug/L
51568	52376-2-BLR-F01	Boys Locker RM Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52376-2-BLR-F01	Boys Locker RM Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52376-2-BLR-F01	Boys Locker RM Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52376-2-BLR-F01	Boys Locker RM Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52376-2-BLR-F01	Boys Locker RM Fountain	Initial	19-DEC-2023	2.460	ug/L
51568	51568-2-210A-F01	By Room 210A Storage Left Fountain	Flush	19-DEC-2023	1.030	ug/L
51568	51568-2-210A-F01	By Room 210A Storage Left Fountain	Flush	19-DEC-2023	1.120	ug/L
51568	51568-2-210A-F01	By Room 210A Storage Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-F01	By Room 210A Storage Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-F01	By Room 210A Storage Left Fountain	Initial	19-DEC-2023	2.700	ug/L
51568	51568-2-210A-F02	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-F02	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-F02	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-F02	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-BF01	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-BF01	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-BF01	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-BF01	By Room 210A Storage Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-F02	By Room 210A Storage Right Fountain	Initial	19-DEC-2023	1.000	ug/L
51568	51568-2-210A-BF01	By Room 210A Storage Right Fountain	Initial	19-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51568	52379-3-HAL-F01	East end Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52379-3-HAL-F01	East end Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52379-3-HAL-F01	East end Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52379-3-HAL-F01	East end Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52379-3-HAL-F01	East end Hall Left Fountain	Initial	19-DEC-2023	1.940	ug/L
51568	52379-3-HAL-F02	East end Hall Right Fountain	Flush	19-DEC-2023	1.270	ug/L
51568	52379-3-HAL-F02	East end Hall Right Fountain	Flush	19-DEC-2023	1.270	ug/L
51568	52379-3-HAL-F02	East end Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52379-3-HAL-F02	East end Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	52379-3-HAL-F02	East end Hall Right Fountain	Initial	19-DEC-2023	1.460	ug/L
51568	51568-1-HAL-F05	Entrance 3	Flush	19-DEC-2023	2.630	ug/L
51568	51568-1-HAL-F05	Entrance 3	Flush	19-DEC-2023	2.270	ug/L
51568	51568-1-HAL-F05	Entrance 3	Flush	19-DEC-2023	3.650	ug/L
51568	51568-1-HAL-F05	Entrance 3	Flush	19-DEC-2023	1.520	ug/L
51568	51568-1-HAL-F05	Entrance 3	Flush180	14-OCT-16	1.700	ppb
51568	51568-1-HAL-F05	Entrance 3	Flush180	14-OCT-16	1.400	ppb
51568	51568-1-HAL-F05	Entrance 3	Flush180	14-OCT-16	1.200	ppb
51568	51568-1-HAL-F05	Entrance 3	Flush180	14-OCT-16	1.300	ppb
51568	51568-1-HAL-F05	Entrance 3	Initial	14-OCT-16	2.100	ppb
51568	51568-1-HAL-F05	Entrance 3	Initial	19-DEC-2023	3.800	ug/L
51568	51568-1-HAL-F06	Fountain by Door 8	Flush	19-DEC-2023	1.210	ug/L
51568	51568-1-HAL-F06	Fountain by Door 8	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F06	Fountain by Door 8	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F06	Fountain by Door 8	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F06	Fountain by Door 8	Initial	19-DEC-2023	2.140	ug/L
51568	51568-1-HAL-F07	Fountain by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F07	Fountain by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F07	Fountain by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F07	Fountain by Door 9	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F07	Fountain by Door 9	Initial	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-BF01	Hall East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-BF01	Hall East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-BF01	Hall East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-BF01	Hall East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-BF01	Hall East Dining Area Right	Initial	19-DEC-2023	1.000	ug/L
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush	19-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush180	14-OCT-16	0.320	ppb
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush180	14-OCT-16	0.340	ppb
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush180	14-OCT-16	0.310	ppb
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Flush180	14-OCT-16	0.280	ppb
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Initial	14-OCT-16	0.290	ppb
51568	51568-B-HAL-F01	Hall Outside Engineer Office	Initial	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-WC01	Hall in East Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC01	Hall in East Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC01	Hall in East Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC01	Hall in East Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC01	Hall in East Dining Area	Initial	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush	19-DEC-2023	1.010	ug/L
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush	19-DEC-2023	1.010	ug/L
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Initial	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F01	Hall in East Dining Area Left	Initial	19-DEC-2023	2.080	ug/L
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Initial	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F02	Hall in East Dining Area Right	Initial	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	14-OCT-16	0.640	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	14-OCT-16	0.640	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	14-OCT-16	74.000	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	14-OCT-16	0.600	ppb
51568	51568-2-HAL-	Hall outside Storage RM Left	Flush180	19-JAN-17	0.730	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F07					
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	19-JAN-17	0.860	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	19-JAN-17	0.530	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Flush180	19-JAN-17	0.760	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Initial	14-OCT-16	0.960	ppb
51568	51568-2-HAL-F07	Hall outside Storage RM Left	Initial	19-JAN-17	0.840	ppb
51568	51568-2-HAL-F08	Hall outside Storage RM Right	Flush180	14-OCT-16	0.570	ppb
51568	51568-2-HAL-F08	Hall outside Storage RM Right	Flush180	14-OCT-16	0.470	ppb
51568	51568-2-HAL-F08	Hall outside Storage RM Right	Flush180	14-OCT-16	0.370	ppb
51568	51568-2-HAL-F08	Hall outside Storage RM Right	Flush180	14-OCT-16	0.640	ppb
51568	51568-2-HAL-F08	Hall outside Storage RM Right	Initial	14-OCT-16	0.610	ppb
51568	51568-2-HAL-WC02	Hall outside West Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC02	Hall outside West Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC02	Hall outside West Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC02	Hall outside West Dining Area	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-WC02	Hall outside West Dining Area	Initial	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush	19-DEC-2023	2.080	ug/L
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush	19-DEC-2023	2.350	ug/L
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush	19-DEC-2023	2.960	ug/L
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush	19-DEC-2023	3.020	ug/L
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Initial	14-OCT-16	1.000	ppb
51568	51568-2-HAL-F06	Hall outside West Dining Area Right Fountain	Initial	19-DEC-2023	1.960	ug/L
51568	51568-B-KIT-KS01	Kitchen	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS01	Kitchen	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS01	Kitchen	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS01	Kitchen	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS01	Kitchen	Flush180	14-OCT-16	0.270	ppb
51568	51568-B-KIT-KS01	Kitchen	Flush180	14-OCT-16	0.230	ppb
51568	51568-B-KIT-KS01	Kitchen	Flush180	14-OCT-16	0.360	ppb
51568	51568-B-KIT-KS01	Kitchen	Flush180	14-OCT-16	0.920	ppb
51568	51568-B-KIT-KS01	Kitchen	Initial	14-OCT-16	1.100	ppb
51568	51568-B-KIT-KS01	Kitchen	Initial	19-DEC-2023	1.000	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	24-JAN-2024	1.770	ug/L
51568	51568-2-HAL-	Left Fountain East end of FL	Flush	24-JAN-2024	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F03					
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	24-JAN-2024	1.000	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	24-JAN-2024	1.020	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	19-DEC-2023	3.220	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	19-DEC-2023	5.070	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	19-DEC-2023	2.390	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush	19-DEC-2023	1.740	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	14-OCT-16	15.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	14-OCT-16	24.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	19-JAN-17	10.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	19-JAN-17	17.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	19-JAN-17	13.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	19-JAN-17	24.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	08-SEP-17	2.190	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	08-SEP-17	1.780	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	08-SEP-17	1.820	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	08-SEP-17	2.400	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	14-OCT-16	22.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Flush180	14-OCT-16	13.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Initial	19-JAN-17	5.600	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Initial	08-SEP-17	3.140	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Initial	14-OCT-16	17.000	ppb
51568	51568-2-HAL-F03	Left Fountain East end of FL	Initial	24-JAN-2024	2.990	ug/L
51568	51568-2-HAL-F03	Left Fountain East end of FL	Initial	19-DEC-2023	5.820	ug/L
51568	51568-1-HAL-F01	Main Entrance Left Fountain	Flush180	14-OCT-16	0.600	ppb
51568	51568-1-HAL-F01	Main Entrance Left Fountain	Flush180	14-OCT-16	0.640	ppb
51568	51568-1-HAL-F01	Main Entrance Left Fountain	Flush180	14-OCT-16	0.270	ppb
51568	51568-1-HAL-F01	Main Entrance Left Fountain	Flush180	14-OCT-16	0.200	ppb
51568	51568-1-HAL-F01	Main Entrance Left Fountain	Initial	14-OCT-16	0.710	ppb
51568	51568-1-HAL-F02	Main Entrance Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-1-HAL-F02	Main Entrance Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-1-HAL-F02	Main Entrance Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-1-HAL-F02	Main Entrance Right Fountain	Initial	14-OCT-16	1.000	ppb
51568	51568-1-HAL-WC01	Main Entrance Water Cooler	Flush180	14-OCT-16	1.000	ppb
51568	51568-1-HAL-WC01	Main Entrance Water Cooler	Flush180	14-OCT-16	1.000	ppb
51568	51568-1-HAL-WC01	Main Entrance Water Cooler	Flush180	14-OCT-16	1.000	ppb
51568	51568-1-HAL-WC01	Main Entrance Water Cooler	Flush180	14-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51568	51568-1-HAL-WC01	Main Entrance Water Cooler	Initial	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F06	North West End of Hall Right Fountain	Flush180	14-OCT-16	0.780	ppb
51568	51568-3-HAL-F06	North West End of Hall Right Fountain	Flush180	14-OCT-16	0.680	ppb
51568	51568-3-HAL-F06	North West End of Hall Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F06	North West End of Hall Right Fountain	Flush180	14-OCT-16	0.660	ppb
51568	51568-3-HAL-F06	North West End of Hall Right Fountain	Initial	14-OCT-16	2.300	ppb
51568	51568-3-HAL-F05	North West End of Hall left Fountain	Flush180	14-OCT-16	0.600	ppb
51568	51568-3-HAL-F05	North West End of Hall left Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F05	North West End of Hall left Fountain	Flush180	14-OCT-16	0.790	ppb
51568	51568-3-HAL-F05	North West End of Hall left Fountain	Flush180	14-OCT-16	1.300	ppb
51568	51568-3-HAL-F05	North West End of Hall left Fountain	Initial	14-OCT-16	1.600	ppb
51568	51568-3-HAL-BF01	North end of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-BF01	North end of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-BF01	North end of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-BF01	North end of Hall Right Fountain	Initial	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush	19-DEC-2023	1.010	ug/L
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush180	14-OCT-16	2.400	ppb
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush180	14-OCT-16	2.500	ppb
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush180	14-OCT-16	2.700	ppb
51568	51568-3-HAL-F07	Northeast End of Hall Left	Flush180	14-OCT-16	1.800	ppb
51568	51568-3-HAL-F07	Northeast End of Hall Left	Initial	14-OCT-16	2.100	ppb
51568	51568-3-HAL-F07	Northeast End of Hall Left	Initial	19-DEC-2023	2.730	ug/L
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush180	14-OCT-16	1.500	ppb
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush180	14-OCT-16	1.500	ppb
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush180	14-OCT-16	1.400	ppb
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush180	14-OCT-16	1.500	ppb
51568	51568-3-HAL-F08	Northeast End of Hall Right	Flush180	16-DEC-20	1.000	ug/L
51568	51568-3-HAL-F08	Northeast End of Hall Right	Initial	14-OCT-16	1.800	ppb
51568	51568-3-HAL-F08	Northeast End of Hall Right	Initial	16-DEC-20	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51568	51568-3-HAL-F08	Northeast End of Hall Right	Initial	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush	19-DEC-2023	2.410	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush	19-DEC-2023	1.260	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush	19-DEC-2023	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	14-OCT-16	0.670	ppb
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	14-OCT-16	0.700	ppb
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	14-OCT-16	0.750	ppb
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	14-OCT-16	0.540	ppb
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	12-FEB-21	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	12-FEB-21	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	12-FEB-21	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	12-FEB-21	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Flush180	16-DEC-20	11.900	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Initial	14-OCT-16	0.660	ppb
51568	51568-1-HAL-F04	Outside Counseling Department	Initial	12-FEB-21	1.000	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Initial	16-DEC-20	95.100	ug/L
51568	51568-1-HAL-F04	Outside Counseling Department	Initial	19-DEC-2023	4.050	ug/L
51568	51568-1-HAL-F03	Outside RM 128-Attendance office	Flush180	14-OCT-16	2.500	ppb
51568	51568-1-HAL-F03	Outside RM 128-Attendance office	Flush180	14-OCT-16	4.400	ppb
51568	51568-1-HAL-F03	Outside RM 128-Attendance office	Flush180	14-OCT-16	3.200	ppb
51568	51568-1-HAL-F03	Outside RM 128-Attendance office	Flush180	14-OCT-16	2.500	ppb
51568	51568-1-HAL-F03	Outside RM 128-Attendance office	Initial	14-OCT-16	4.100	ppb
51568	51568-2-218D-F01	Outside Storage room 218D Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F01	Outside Storage room 218D Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F01	Outside Storage room 218D Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F01	Outside Storage room 218D Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F01	Outside Storage room 218D Left Fountain	Initial	19-DEC-2023	1.070	ug/L
51568	51568-2-218D-F02	Outside Storage room 218D Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F02	Outside Storage room 218D Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F02	Outside Storage room 218D Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F02	Outside Storage room 218D Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-2-218D-F02	Outside Storage room 218D Right Fountain	Initial	19-DEC-2023	1.000	ug/L
51568	51568-2-210C-S02	RM 210C Storage	Flush180	14-OCT-16	10.000	ppb
51568	51568-2-210C-S02	RM 210C Storage	Flush180	14-OCT-16	4.500	ppb
51568	51568-2-210C-S02	RM 210C Storage	Flush180	14-OCT-16	26.000	ppb
51568	51568-2-210C-S02	RM 210C Storage	Flush180	14-OCT-16	7.700	ppb
51568	51568-2-	RM 210C Storage	Flush180	19-JAN-17	2.800	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	210C-S02					
51568	51568-2-210C-S02	RM 210C Storage	Flush180	19-JAN-17	0.190	ppb
51568	51568-2-210C-S02	RM 210C Storage	Flush180	19-JAN-17	3.400	ppb
51568	51568-2-210C-S02	RM 210C Storage	Flush180	19-JAN-17	1.200	ppb
51568	51568-2-210C-S02	RM 210C Storage	Initial	14-OCT-16	170.000	ppb
51568	51568-2-210C-S02	RM 210C Storage	Initial	19-JAN-17	1.400	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	19-JAN-17	7.200	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	19-JAN-17	5.900	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	19-JAN-17	1.400	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	14-OCT-16	16.000	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	14-OCT-16	1.500	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	14-OCT-16	0.470	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	14-OCT-16	8.400	ppb
51568	51568-2-251B-S01	RM 251B Storage	Flush180	19-JAN-17	2.800	ppb
51568	51568-2-251B-S01	RM 251B Storage	Initial	19-JAN-17	1.600	ppb
51568	51568-2-251B-S01	RM 251B Storage	Initial	14-OCT-16	0.730	ppb
51568	51568-1-HAL-RBF01	Retrofitted Bottle Filler by Door 9	Flush	19-DEC-2023	1.290	ug/L
51568	51568-1-HAL-RBF01	Retrofitted Bottle Filler by Door 9	Flush	19-DEC-2023	1.190	ug/L
51568	51568-1-HAL-RBF01	Retrofitted Bottle Filler by Door 9	Flush	19-DEC-2023	3.790	ug/L
51568	51568-1-HAL-RBF01	Retrofitted Bottle Filler by Door 9	Flush	19-DEC-2023	1.630	ug/L
51568	51568-1-HAL-RBF01	Retrofitted Bottle Filler by Door 9	Initial	19-DEC-2023	4.760	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	14-FEB-2024	1.070	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	14-FEB-2024	1.060	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	24-JAN-2024	1.170	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	24-JAN-2024	1.000	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	24-JAN-2024	1.000	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	24-JAN-2024	1.000	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	19-DEC-2023	33.600	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	19-DEC-2023	13.200	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	19-DEC-2023	7.540	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	19-DEC-2023	5.580	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	14-FEB-2024	1.000	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush	14-FEB-2024	1.000	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	14-OCT-16	12.000	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	14-OCT-16	12.000	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	19-JAN-17	5.100	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	19-JAN-17	5.900	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	19-JAN-17	5.500	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	19-JAN-17	5.200	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	14-OCT-16	9.100	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Flush180	14-OCT-16	8.200	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Initial	14-OCT-16	15.000	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Initial	19-JAN-17	8.600	ppb
51568	51568-2-HAL-F04	Right Fountain East End of FL	Initial	14-FEB-2024	1.150	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Initial	24-JAN-2024	5.910	ug/L
51568	51568-2-HAL-F04	Right Fountain East End of FL	Initial	19-DEC-2023	12.100	ug/L
51568	51568-B-KIT-KS04	S Wall Single Basin Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS04	S Wall Single Basin Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS04	S Wall Single Basin Sink	Flush	19-DEC-2023	1.000	ug/L
51568	51568-B-KIT-KS04	S Wall Single Basin Sink	Flush	19-DEC-2023	2.190	ug/L
51568	51568-B-KIT-KS04	S Wall Single Basin Sink	Initial	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush180	14-OCT-16	1.400	ppb
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush180	14-OCT-16	1.500	ppb
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush180	14-OCT-16	1.100	ppb
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Flush180	14-OCT-16	0.670	ppb
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Initial	14-OCT-16	2.100	ppb
51568	51568-3-HAL-F01	South East Corner of Hall Left Fountain	Initial	19-DEC-2023	1.370	ug/L
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush	19-DEC-2023	1.000	ug/L
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Initial	14-OCT-16	1.000	ppb
51568	51568-3-HAL-F02	Southeast Corner of Hall Right Fountain	Initial	19-DEC-2023	1.320	ug/L
51568	51568-3-HAL-WC01	Southeast Corner of Hall Water Cooler	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-WC01	Southeast Corner of Hall Water Cooler	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-WC01	Southeast Corner of Hall Water Cooler	Flush180	14-OCT-16	1.000	ppb
51568	51568-3-HAL-WC01	Southeast Corner of Hall Water Cooler	Flush180	14-OCT-16	1.000	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51568	51568-3-HAL-WC01	Southeast Corner of Hall Water Cooler	Initial	14-OCT-16	1.000	ppb
51568	52377-1-HAL-BF01	West end of hall Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
51568	52377-1-HAL-BF01	West end of hall Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
51568	52377-1-HAL-BF01	West end of hall Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
51568	52377-1-HAL-BF01	West end of hall Bottle Filler	Flush	19-DEC-2023	1.000	ug/L
51568	52377-1-HAL-BF01	West end of hall Bottle Filler	Initial	19-DEC-2023	1.000	ug/L
52376	52376-B-HAL-F01	Basement Hall	Flush180	14-OCT-16	0.900	ppb
52376	52376-B-HAL-F01	Basement Hall	Flush180	14-OCT-16	0.840	ppb
52376	52376-B-HAL-F01	Basement Hall	Flush180	14-OCT-16	0.840	ppb
52376	52376-B-HAL-F01	Basement Hall	Flush180	14-OCT-16	0.940	ppb
52376	52376-B-HAL-F01	Basement Hall	Initial	14-OCT-16	1.000	ppb
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush	19-DEC-2023	1.980	ug/L
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush	19-DEC-2023	2.920	ug/L
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush	19-DEC-2023	3.450	ug/L
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush	19-DEC-2023	3.680	ug/L
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush180	14-OCT-16	1.200	ppb
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush180	14-OCT-16	1.500	ppb
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush180	14-OCT-16	1.400	ppb
52376	52376-1-CGYM-F02	C Gym North Entrance	Flush180	14-OCT-16	1.600	ppb
52376	52376-1-CGYM-F02	C Gym North Entrance	Initial	14-OCT-16	1.600	ppb
52376	52376-1-CGYM-F02	C Gym North Entrance	Initial	19-DEC-2023	4.340	ug/L
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush	19-DEC-2023	1.480	ug/L
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush	19-DEC-2023	1.260	ug/L
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush	19-DEC-2023	1.300	ug/L
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush180	14-OCT-16	1.700	ppb
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush180	14-OCT-16	1.800	ppb
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush180	14-OCT-16	1.700	ppb
52376	52376-1-CGYM-F01	C Gym South Entrance	Flush180	14-OCT-16	1.600	ppb
52376	52376-1-CGYM-F01	C Gym South Entrance	Initial	14-OCT-16	2.500	ppb
52376	52376-1-CGYM-F01	C Gym South Entrance	Initial	19-DEC-2023	4.410	ug/L
52376	52376-2-HAL-F04	East End Hall Right Fountain	Flush180	14-OCT-16	1.800	ppb
52376	52376-2-HAL-F04	East End Hall Right Fountain	Flush180	14-OCT-16	1.300	ppb
52376	52376-2-HAL-F04	East End Hall Right Fountain	Flush180	14-OCT-16	1.200	ppb
52376	52376-2-HAL-F04	East End Hall Right Fountain	Flush180	14-OCT-16	1.200	ppb
52376	52376-2-HAL-F04	East End Hall Right Fountain	Initial	14-OCT-16	1.600	ppb
52376	52376-1-POL-F01	East Side pool area	Flush	19-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52376	52376-1-POL-F01	East Side pool area	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-POL-F01	East Side pool area	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-POL-F01	East Side pool area	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-POL-F01	East Side pool area	Flush180	14-OCT-16	0.720	ppb
52376	52376-1-POL-F01	East Side pool area	Flush180	14-OCT-16	0.680	ppb
52376	52376-1-POL-F01	East Side pool area	Flush180	14-OCT-16	0.570	ppb
52376	52376-1-POL-F01	East Side pool area	Flush180	14-OCT-16	0.610	ppb
52376	52376-1-POL-F01	East Side pool area	Initial	14-OCT-16	1.400	ppb
52376	52376-1-POL-F01	East Side pool area	Initial	19-DEC-2023	2.690	ug/L
52376	52376-2-GLR-F02	Girls Locker RM Right Fountain	Flush180	14-OCT-16	0.650	ppb
52376	52376-2-GLR-F02	Girls Locker RM Right Fountain	Flush180	14-OCT-16	0.700	ppb
52376	52376-2-GLR-F02	Girls Locker RM Right Fountain	Flush180	14-OCT-16	0.850	ppb
52376	52376-2-GLR-F02	Girls Locker RM Right Fountain	Flush180	14-OCT-16	1.100	ppb
52376	52376-2-GLR-F02	Girls Locker RM Right Fountain	Initial	14-OCT-16	2.500	ppb
52376	52376-1-HAL-F01	Gym Hall 1st Fountain	Flush	19-DEC-2023	1.480	ug/L
52376	52376-1-HAL-F01	Gym Hall 1st Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F01	Gym Hall 1st Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F01	Gym Hall 1st Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F01	Gym Hall 1st Fountain	Initial	19-DEC-2023	2.460	ug/L
52376	52376-1-HAL-F02	Gym Hall 2nd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F02	Gym Hall 2nd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F02	Gym Hall 2nd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F02	Gym Hall 2nd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F02	Gym Hall 2nd Fountain	Initial	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush180	14-OCT-16	0.510	ppb
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush180	14-OCT-16	0.470	ppb
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush180	14-OCT-16	0.390	ppb
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Flush180	14-OCT-16	0.420	ppb
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Initial	14-OCT-16	0.740	ppb
52376	52376-1-HAL-F03	Gym Hall 3rd Fountain	Initial	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush	19-DEC-2023	1.000	ug/L



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F04					
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush180	14-OCT-16	0.250	ppb
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush180	14-OCT-16	0.170	ppb
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush180	14-OCT-16	0.270	ppb
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Flush180	14-OCT-16	0.230	ppb
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Initial	14-OCT-16	0.340	ppb
52376	52376-1-HAL-F04	Gym Hall 4th Fountain	Initial	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Initial	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F05	Gym Hall 5th Fountain	Initial	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Initial	14-OCT-16	1.000	ppb
52376	52376-1-HAL-F06	Gym Hall 6th Fountain	Initial	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Initial	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC01	Gym Hall Left Water Cooler	Initial	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-	Gym Hall Right Water Cooler	Flush	19-DEC-2023	1.000	ug/L

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	WC02					
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush	19-DEC-2023	1.000	ug/L
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Flush180	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Initial	14-OCT-16	1.000	ppb
52376	52376-1-HAL-WC02	Gym Hall Right Water Cooler	Initial	19-DEC-2023	1.000	ug/L
52376	52376-2-HAL-F01	Wesr End of Hall Left Fountain	Flush180	14-OCT-16	0.510	ppb
52376	52376-2-HAL-F01	Wesr End of Hall Left Fountain	Flush180	14-OCT-16	0.370	ppb
52376	52376-2-HAL-F01	Wesr End of Hall Left Fountain	Flush180	14-OCT-16	0.320	ppb
52376	52376-2-HAL-F01	Wesr End of Hall Left Fountain	Flush180	14-OCT-16	0.370	ppb
52376	52376-2-HAL-F01	Wesr End of Hall Left Fountain	Initial	14-OCT-16	0.410	ppb
52376	52376-1-POL-F02	West End of Pool	Flush180	14-OCT-16	0.230	ppb
52376	52376-1-POL-F02	West End of Pool	Flush180	14-OCT-16	0.210	ppb
52376	52376-1-POL-F02	West End of Pool	Flush180	14-OCT-16	0.220	ppb
52376	52376-1-POL-F02	West End of Pool	Flush180	14-OCT-16	0.220	ppb
52376	52376-1-POL-F02	West End of Pool	Initial	14-OCT-16	0.210	ppb
52377	52377-2-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F02	East End of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.590	ppb
52377	52377-1-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.760	ppb
52377	52377-1-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.760	ppb
52377	52377-1-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.600	ppb
52377	52377-1-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.600	ppb
52377	52377-1-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.590	ppb
52377	52377-2-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.540	ppb
52377	52377-2-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.540	ppb
52377	52377-2-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.540	ppb
52377	52377-2-HAL-F02	East End of Hall	Flush180	14-OCT-16	0.480	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
52377	52377-2-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F01	West end of Hall	Flush	19-DEC-2023	1.000	ug/L
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Flush180	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Initial	14-OCT-16	1.000	ppb
52377	52377-1-HAL-F01	West end of Hall	Initial	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Initial	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Initial	14-OCT-16	1.000	ppb
52377	52377-2-HAL-F01	West end of Hall	Initial	19-DEC-2023	1.000	ug/L
52377	52377-1-HAL-F01	West end of Hall	Initial	19-DEC-2023	1.000	ug/L