



Sep 10, 2024

, .

Dear families,

In 2016, Chicago Public Schools (CPS) began sampling for lead in drinking water from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. For fixtures that have sample results equal to or above the Illinois Department of Public Health's standard of 5 ppb, these fixtures have been taken out of service until the issue is addressed and the fixture has been retested. No fixture will be returned to service until the Illinois Department of Public Health standard for lead in drinking water is met. Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why some fixtures return with elevated results. The issue is not system-wide, but it is specific to the fixtures or pipes that will be addressed through the remediation plan.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer

Director of Environmental Health and Safety

Chicago Public Schools



Sep 10, 2024

, .

Estimadas familias de :

En 2016, las Escuelas Públicas de Chicago (CPS) comenzaron a inspeccionar el agua potable de las escuelas del distrito en búsqueda de plomo. Nuestra primera prioridad es la salud y la seguridad de nuestros estudiantes y personal, y estas pruebas se iniciaron para ser precavidos y confirmar que el agua en nuestras escuelas estuviera segura.

Según las directrices de la Agencia de Protección Ambiental (EPA, según sus siglas en inglés) en cuanto al plomo en el agua potable la concentración de plomo en el agua potable no debe exceder 15 partes por mil millones (ppb, según sus siglas en inglés). Según las directrices del Departamento de Salud Pública de Illinois (IDPH, según sus siglas en inglés), las concentraciones de plomo en el agua potable no deben exceder 5 ppb.

Las instalaciones que al ser examinadas demostraron resultados que igualen o sobrepasaran el estándar del IDPH de 5 ppb han sido removidas de servicio hasta que el asunto sea resuelto y la instalación haya sido reexaminada. Ninguna instalación será regresada al servicio hasta que cumpla con los estándares de plomo en el agua del IDPH.

El agua de Chicago no contiene plomo al salir de la planta de tratamiento. Sin embargo, se puede encontrar plomo en algunas instalaciones y materiales de plomería interiores, y el plomo encontrado en el agua de pluma normalmente surge de la corrosión en estos artículos. Esto explica por qué algunas instalaciones regresan con resultados elevados. El asunto no está generalizado en el sistema, sino que es específico para instalaciones o tuberías que serán trabajadas por el plan de remediación.

Las directrices federales indican que los niños de menos de seis años sufren el mayor riesgo de exposición dañina al plomo, y pueden ser expuestos al plomo de una variedad de fuentes, que incluyen la pintura, el terreno y hasta algunos productos para el consumidor. Si está preocupado sobre los riesgos posibles de ser expuesto al plomo, el Departamento de Salud Pública de Chicago (CDPH) recomienda ir a su pediatra o uno de los proveedores de atención médica locales incluidos en el anexo para que sea examinado. Adicionalmente, la línea directa sobre el plomo del CDPH puede responder a cualquier pregunta de salud que tenga o ayudarlo y a decidir si hacerle una prueba a su niño; para preguntas o más información sobre el plomo y los niños, visite <https://www.cdc.gov/nceh/lead/>.

La seguridad de sus niños es nuestra primera prioridad, y estamos haciendo todo lo posible para responder a esta situación lo más rápida y rigurosamente posible. Continuaremos a mantenerlos a ustedes y sus familias informadas durante este proceso.

Sinceramente,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director de Salud y Seguridad Ambientales
Escuelas Públicas de Chicago

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51615	51615-1-HAL-F15	Main- 1st Floor Next to Stairwell #2, Fountain	Flush180	18-OCT-16	0.549	ppb
51615	51615-1-HAL-F15	Main- 1st Floor Next to Stairwell #2, Fountain	Flush180	18-OCT-16	0.254	ppb
51615	51615-1-HAL-F15	Main- 1st Floor Next to Stairwell #2, Fountain	Flush180	18-OCT-16	0.342	ppb
51615	51615-1-HAL-F15	Main- 1st Floor Next to Stairwell #2, Fountain	Flush180	18-OCT-16	0.739	ppb
51615	51615-1-HAL-F15	Main- 1st Floor Next to Stairwell #2, Fountain	Initial	18-OCT-16	0.795	ppb
51615	51615-1-HAL-F18	Main- 1st Floor Next to Stairwell #4, Right Founta	Flush180	18-OCT-16	3.710	ppb
51615	51615-1-HAL-F18	Main- 1st Floor Next to Stairwell #4, Right Founta	Flush180	18-OCT-16	3.150	ppb
51615	51615-1-HAL-F18	Main- 1st Floor Next to Stairwell #4, Right Founta	Flush180	18-OCT-16	3.000	ppb
51615	51615-1-HAL-F18	Main- 1st Floor Next to Stairwell #4, Right Founta	Flush180	18-OCT-16	3.920	ppb
51615	51615-1-HAL-F18	Main- 1st Floor Next to Stairwell #4, Right Founta	Initial	18-OCT-16	5.730	ppb
51615	51615-1-HAL-F14	Main- 1st Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	1.050	ppb
51615	51615-1-HAL-F14	Main- 1st Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	0.892	ppb
51615	51615-1-HAL-F14	Main- 1st Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	0.955	ppb
51615	51615-1-HAL-F14	Main- 1st Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	1.000	ppb
51615	51615-1-HAL-F14	Main- 1st Floor Next to Stairwell #5, Fountain	Initial	18-OCT-16	1.470	ppb
51615	51615-1-HAL-F10	Main- 1st Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	1.000	ppb
51615	51615-1-HAL-F10	Main- 1st Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	1.040	ppb
51615	51615-1-HAL-F10	Main- 1st Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	1.020	ppb
51615	51615-1-HAL-F10	Main- 1st Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	0.942	ppb
51615	51615-1-HAL-F10	Main- 1st Floor Next to Stairwell #6, Fountain	Initial	18-OCT-16	1.370	ppb
51615	51615-2-HAL-F04	Main- 2nd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	0.537	ppb
51615	51615-2-HAL-F04	Main- 2nd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	0.773	ppb
51615	51615-2-HAL-F04	Main- 2nd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	0.560	ppb
51615	51615-2-HAL-F04	Main- 2nd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	0.569	ppb
51615	51615-2-HAL-F04	Main- 2nd Floor Next to Stairwell #3, Fountain	Initial	18-OCT-16	0.616	ppb
51615	51615-2-HAL-F07	Main- 2nd Floor Next to Stairwell #4, Fountain	Flush180	18-OCT-16	1.020	ppb
51615	51615-2-HAL-F07	Main- 2nd Floor Next to Stairwell #4, Fountain	Flush180	18-OCT-16	1.300	ppb
51615	51615-2-HAL-F07	Main- 2nd Floor Next to Stairwell #4, Fountain	Flush180	18-OCT-16	1.180	ppb
51615	51615-2-HAL-F07	Main- 2nd Floor Next to Stairwell #4, Fountain	Flush180	18-OCT-16	0.988	ppb
51615	51615-2-HAL-F07	Main- 2nd Floor Next to Stairwell #4, Fountain	Initial	18-OCT-16	1.400	ppb
51615	51615-2-HAL-F06	Main- 2nd Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	0.993	ppb
51615	51615-2-HAL-F06	Main- 2nd Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	1.110	ppb
51615	51615-2-HAL-F06	Main- 2nd Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	1.150	ppb
51615	51615-2-HAL-F06	Main- 2nd Floor Next to Stairwell #5, Fountain	Flush180	18-OCT-16	1.060	ppb
51615	51615-2-HAL-F06	Main- 2nd Floor Next to Stairwell #5, Fountain	Initial	18-OCT-16	1.340	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51615	51615-2-HAL-F05	Main- 2nd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	0.986	ppb
51615	51615-2-HAL-F05	Main- 2nd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	0.933	ppb
51615	51615-2-HAL-F05	Main- 2nd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	0.826	ppb
51615	51615-2-HAL-F05	Main- 2nd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	0.809	ppb
51615	51615-2-HAL-F05	Main- 2nd Floor Next to Stairwell #6, Fountain	Initial	18-OCT-16	1.060	ppb
51615	51615-3-HAL-F04	Main- 3rd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	1.620	ppb
51615	51615-3-HAL-F04	Main- 3rd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	1.790	ppb
51615	51615-3-HAL-F04	Main- 3rd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	1.860	ppb
51615	51615-3-HAL-F04	Main- 3rd Floor Next to Stairwell #3, Fountain	Flush180	18-OCT-16	1.310	ppb
51615	51615-3-HAL-F04	Main- 3rd Floor Next to Stairwell #3, Fountain	Initial	18-OCT-16	2.070	ppb
51615	51615-3-HAL-F06	Main- 3rd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	1.730	ppb
51615	51615-3-HAL-F06	Main- 3rd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	2.080	ppb
51615	51615-3-HAL-F06	Main- 3rd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	2.260	ppb
51615	51615-3-HAL-F06	Main- 3rd Floor Next to Stairwell #6, Fountain	Flush180	18-OCT-16	1.350	ppb
51615	51615-3-HAL-F06	Main- 3rd Floor Next to Stairwell #6, Fountain	Initial	18-OCT-16	2.410	ppb
51615	51615-2-HAL-F02	Main- Across From Room 232, Fountain	Flush180	18-OCT-16	0.317	ppb
51615	51615-2-HAL-F02	Main- Across From Room 232, Fountain	Flush180	18-OCT-16	0.273	ppb
51615	51615-2-HAL-F02	Main- Across From Room 232, Fountain	Flush180	18-OCT-16	0.295	ppb
51615	51615-2-HAL-F02	Main- Across From Room 232, Fountain	Flush180	18-OCT-16	0.390	ppb
51615	51615-2-HAL-F02	Main- Across From Room 232, Fountain	Initial	18-OCT-16	0.444	ppb
51615	51615-3-HAL-F02	Main- Across From Room 310, Fountain	Flush180	18-OCT-16	1.250	ppb
51615	51615-3-HAL-F02	Main- Across From Room 310, Fountain	Flush180	18-OCT-16	1.270	ppb
51615	51615-3-HAL-F02	Main- Across From Room 310, Fountain	Flush180	18-OCT-16	1.490	ppb
51615	51615-3-HAL-F02	Main- Across From Room 310, Fountain	Flush180	18-OCT-16	1.400	ppb
51615	51615-3-HAL-F02	Main- Across From Room 310, Fountain	Initial	18-OCT-16	1.470	ppb
51615	51615-3-HAL-F07	Main- Across From Room 316, Fountain	Flush180	18-OCT-16	1.840	ppb
51615	51615-3-HAL-F07	Main- Across From Room 316, Fountain	Flush180	18-OCT-16	1.690	ppb
51615	51615-3-HAL-F07	Main- Across From Room 316, Fountain	Flush180	18-OCT-16	1.950	ppb
51615	51615-3-HAL-F07	Main- Across From Room 316, Fountain	Flush180	18-OCT-16	1.880	ppb
51615	51615-3-HAL-F07	Main- Across From Room 316, Fountain	Initial	18-OCT-16	2.190	ppb
51615	51615-3-HAL-F03	Main- Across From Room 341, Fountain	Flush180	18-OCT-16	4.590	ppb
51615	51615-3-HAL-F03	Main- Across From Room 341, Fountain	Flush180	18-OCT-16	4.210	ppb
51615	51615-3-HAL-F03	Main- Across From Room 341, Fountain	Flush180	18-OCT-16	3.500	ppb
51615	51615-3-HAL-F03	Main- Across From Room 341, Fountain	Flush180	18-OCT-16	3.210	ppb
51615	51615-3-HAL-F03	Main- Across From Room 341, Fountain	Initial	18-OCT-16	2.470	ppb
51615	51615-1-116-F26	Main- Boys Locker Room, Left Fountain	Flush180	18-OCT-16	2.790	ppb
51615	51615-1-116-F26	Main- Boys Locker Room, Left Fountain	Flush180	18-OCT-16	3.060	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51615	51615-1-116-F26	Main- Boys Locker Room, Left Fountain	Flush180	18-OCT-16	3.970	ppb
51615	51615-1-116-F26	Main- Boys Locker Room, Left Fountain	Flush180	18-OCT-16	4.000	ppb
51615	51615-1-116-F26	Main- Boys Locker Room, Left Fountain	Initial	18-OCT-16	3.330	ppb
51615	51615-1-116-F27	Main- Boys Locker Room, Right Fountain	Flush180	18-OCT-16	3.810	ppb
51615	51615-1-116-F27	Main- Boys Locker Room, Right Fountain	Flush180	18-OCT-16	4.450	ppb
51615	51615-1-116-F27	Main- Boys Locker Room, Right Fountain	Flush180	18-OCT-16	4.970	ppb
51615	51615-1-116-F27	Main- Boys Locker Room, Right Fountain	Flush180	18-OCT-16	5.730	ppb
51615	51615-1-116-F27	Main- Boys Locker Room, Right Fountain	Initial	18-OCT-16	6.170	ppb
51615	51615-1-118-F24	Main- Girls Locker Room 118, Left Fountain	Flush180	18-OCT-16	3.180	ppb
51615	51615-1-118-F24	Main- Girls Locker Room 118, Left Fountain	Flush180	18-OCT-16	3.730	ppb
51615	51615-1-118-F24	Main- Girls Locker Room 118, Left Fountain	Flush180	18-OCT-16	5.050	ppb
51615	51615-1-118-F24	Main- Girls Locker Room 118, Left Fountain	Flush180	18-OCT-16	1.590	ppb
51615	51615-1-118-F24	Main- Girls Locker Room 118, Left Fountain	Initial	18-OCT-16	2.020	ppb
51615	51615-1-GYM-F08	Main- Inside Gym, North Wall Fountain	Flush180	18-OCT-16	1.810	ppb
51615	51615-1-GYM-F08	Main- Inside Gym, North Wall Fountain	Flush180	18-OCT-16	2.120	ppb
51615	51615-1-GYM-F08	Main- Inside Gym, North Wall Fountain	Flush180	18-OCT-16	2.230	ppb
51615	51615-1-GYM-F08	Main- Inside Gym, North Wall Fountain	Flush180	18-OCT-16	1.960	ppb
51615	51615-1-GYM-F08	Main- Inside Gym, North Wall Fountain	Initial	18-OCT-16	2.050	ppb
51615	51615-1-GYM-F09	Main- Inside Gym, West Wall Fountain	Flush180	18-OCT-16	1.840	ppb
51615	51615-1-GYM-F09	Main- Inside Gym, West Wall Fountain	Flush180	18-OCT-16	1.990	ppb
51615	51615-1-GYM-F09	Main- Inside Gym, West Wall Fountain	Flush180	18-OCT-16	2.640	ppb
51615	51615-1-GYM-F09	Main- Inside Gym, West Wall Fountain	Flush180	18-OCT-16	2.170	ppb
51615	51615-1-GYM-F09	Main- Inside Gym, West Wall Fountain	Initial	18-OCT-16	2.280	ppb
51615	51615-1-HAL-F19	Main- Inside Lobby, West Wall, Left Fountain	Flush180	18-OCT-16	3.490	ppb
51615	51615-1-HAL-F19	Main- Inside Lobby, West Wall, Left Fountain	Flush180	18-OCT-16	3.000	ppb
51615	51615-1-HAL-F19	Main- Inside Lobby, West Wall, Left Fountain	Flush180	18-OCT-16	4.100	ppb
51615	51615-1-HAL-F19	Main- Inside Lobby, West Wall, Left Fountain	Flush180	18-OCT-16	3.860	ppb
51615	51615-1-HAL-F19	Main- Inside Lobby, West Wall, Left Fountain	Initial	18-OCT-16	5.010	ppb
51615	51615-1-115-F05	Main- Inside Room 115, Left Fountain	Flush180	18-OCT-16	3.360	ppb
51615	51615-1-115-F05	Main- Inside Room 115, Left Fountain	Flush180	18-OCT-16	3.460	ppb
51615	51615-1-115-F05	Main- Inside Room 115, Left Fountain	Flush180	18-OCT-16	3.170	ppb
51615	51615-1-115-F05	Main- Inside Room 115, Left Fountain	Flush180	18-OCT-16	3.410	ppb
51615	51615-1-115-F05	Main- Inside Room 115, Left Fountain	Initial	18-OCT-16	3.050	ppb
51615	51615-1-115-F06	Main- Inside Room 115, Right Fountain	Flush180	18-OCT-16	7.030	ppb
51615	51615-1-115-F06	Main- Inside Room 115, Right Fountain	Flush180	18-OCT-16	7.180	ppb
51615	51615-1-115-F06	Main- Inside Room 115, Right Fountain	Flush180	18-OCT-16	10.000	ppb
51615	51615-1-115-F06	Main- Inside Room 115, Right Fountain	Flush180	18-OCT-16	8.860	ppb
51615	51615-1-115-F06	Main- Inside Room 115, Right Fountain	Initial	18-OCT-16	7.360	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F06	Fountain				
51615	51615-1-125-S22	Main- Inside Room 125, Sink	Flush180	18-OCT-16	1.320	ppb
51615	51615-1-125-S22	Main- Inside Room 125, Sink	Flush180	18-OCT-16	1.520	ppb
51615	51615-1-125-S22	Main- Inside Room 125, Sink	Flush180	18-OCT-16	2.900	ppb
51615	51615-1-125-S22	Main- Inside Room 125, Sink	Flush180	18-OCT-16	2.030	ppb
51615	51615-1-125-S22	Main- Inside Room 125, Sink	Initial	18-OCT-16	6.190	ppb
51615	51615-1-125-F23	Main- Inside Room 134, Fountain	Flush180	18-OCT-16	0.584	ppb
51615	51615-1-125-F23	Main- Inside Room 134, Fountain	Flush180	18-OCT-16	0.955	ppb
51615	51615-1-125-F23	Main- Inside Room 134, Fountain	Flush180	18-OCT-16	1.030	ppb
51615	51615-1-125-F23	Main- Inside Room 134, Fountain	Flush180	18-OCT-16	1.230	ppb
51615	51615-1-125-F23	Main- Inside Room 134, Fountain	Initial	18-OCT-16	2.310	ppb
51615	51615-3-HAL-F05	Main- Inside Room 338, Fountain	Flush180	18-OCT-16	1.420	ppb
51615	51615-3-HAL-F05	Main- Inside Room 338, Fountain	Flush180	18-OCT-16	1.660	ppb
51615	51615-3-HAL-F05	Main- Inside Room 338, Fountain	Flush180	18-OCT-16	1.470	ppb
51615	51615-3-HAL-F05	Main- Inside Room 338, Fountain	Flush180	18-OCT-16	1.220	ppb
51615	51615-3-HAL-F05	Main- Inside Room 338, Fountain	Initial	18-OCT-16	3.050	ppb
51615	51615-1-KIT-KS02	Main- Kitchen, East Wall Left Sink	Flush180	18-OCT-16	0.367	ppb
51615	51615-1-KIT-KS02	Main- Kitchen, East Wall Left Sink	Flush180	18-OCT-16	0.381	ppb
51615	51615-1-KIT-KS02	Main- Kitchen, East Wall Left Sink	Flush180	18-OCT-16	0.377	ppb
51615	51615-1-KIT-KS02	Main- Kitchen, East Wall Left Sink	Flush180	18-OCT-16	0.291	ppb
51615	51615-1-KIT-KS02	Main- Kitchen, East Wall Left Sink	Initial	18-OCT-16	0.470	ppb
51615	51615-1-KIT-KS03	Main- Kitchen, East Wall Right Sink	Flush180	18-OCT-16	0.956	ppb
51615	51615-1-KIT-KS03	Main- Kitchen, East Wall Right Sink	Flush180	18-OCT-16	0.899	ppb
51615	51615-1-KIT-KS03	Main- Kitchen, East Wall Right Sink	Flush180	18-OCT-16	0.733	ppb
51615	51615-1-KIT-KS03	Main- Kitchen, East Wall Right Sink	Flush180	18-OCT-16	0.780	ppb
51615	51615-1-KIT-KS03	Main- Kitchen, East Wall Right Sink	Initial	18-OCT-16	1.150	ppb
51615	51615-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	18-OCT-16	1.110	ppb
51615	51615-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	18-OCT-16	1.200	ppb
51615	51615-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	18-OCT-16	1.020	ppb
51615	51615-1-KIT-KS01	Main- Kitchen, North Wall Sink	Flush180	18-OCT-16	1.330	ppb
51615	51615-1-KIT-KS01	Main- Kitchen, North Wall Sink	Initial	18-OCT-16	0.726	ppb
51615	51615-2-LIB-F03	Main- Library, Next to Copy Room, Fountain	Flush180	18-OCT-16	8.920	ppb
51615	51615-2-LIB-F03	Main- Library, Next to Copy Room, Fountain	Flush180	18-OCT-16	9.960	ppb
51615	51615-2-LIB-F03	Main- Library, Next to Copy Room, Fountain	Flush180	18-OCT-16	10.900	ppb
51615	51615-2-LIB-F03	Main- Library, Next to Copy Room, Fountain	Flush180	18-OCT-16	12.300	ppb
51615	51615-2-LIB-F03	Main- Library, Next to Copy Room, Fountain	Initial	18-OCT-16	12.400	ppb
51615	51615-1-123-F11	Main- Lunchroom, East Wall Fountain	Flush180	18-OCT-16	1.620	ppb
51615	51615-1-123-	Main- Lunchroom, East Wall	Flush180	18-OCT-16	2.930	ppb

Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
	F11	Fountain				
51615	51615-1-123-F11	Main- Lunchroom, East Wall Fountain	Flush180	18-OCT-16	1.250	ppb
51615	51615-1-123-F11	Main- Lunchroom, East Wall Fountain	Flush180	18-OCT-16	2.140	ppb
51615	51615-1-123-F11	Main- Lunchroom, East Wall Fountain	Initial	18-OCT-16	4.670	ppb
51615	51615-1-123-F12	Main- Lunchroom, West Wall Fountain	Flush180	18-OCT-16	4.470	ppb
51615	51615-1-123-F12	Main- Lunchroom, West Wall Fountain	Flush180	18-OCT-16	5.640	ppb
51615	51615-1-123-F12	Main- Lunchroom, West Wall Fountain	Flush180	18-OCT-16	5.310	ppb
51615	51615-1-123-F12	Main- Lunchroom, West Wall Fountain	Flush180	18-OCT-16	9.350	ppb
51615	51615-1-123-F12	Main- Lunchroom, West Wall Fountain	Initial	18-OCT-16	14.800	ppb
51615	51615-1-126-F20	Main- Main Office, Fountain	Flush180	18-OCT-16	1.490	ppb
51615	51615-1-126-F20	Main- Main Office, Fountain	Flush180	18-OCT-16	1.420	ppb
51615	51615-1-126-F20	Main- Main Office, Fountain	Flush180	18-OCT-16	1.670	ppb
51615	51615-1-126-F20	Main- Main Office, Fountain	Flush180	18-OCT-16	2.170	ppb
51615	51615-1-126-F20	Main- Main Office, Fountain	Initial	18-OCT-16	3.670	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	18-OCT-16	3.190	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	18-OCT-16	1.990	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	31-MAY-17	3.600	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	31-MAY-17	4.070	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	18-OCT-16	2.400	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	31-MAY-17	2.720	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	18-OCT-16	2.320	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Flush180	31-MAY-17	3.030	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Initial	18-OCT-16	25.100	ppb
51615	51615-1-126-S21	Main- Main Office, Sink	Initial	31-MAY-17	5.180	ppb
51615	51615-1-HAL-F04	Main- Outside Room 134, Fountain	Flush180	18-OCT-16	2.440	ppb
51615	51615-1-HAL-F04	Main- Outside Room 134, Fountain	Flush180	18-OCT-16	1.460	ppb
51615	51615-1-HAL-F04	Main- Outside Room 134, Fountain	Flush180	18-OCT-16	1.460	ppb
51615	51615-1-HAL-F04	Main- Outside Room 134, Fountain	Flush180	18-OCT-16	1.970	ppb
51615	51615-1-HAL-F04	Main- Outside Room 134, Fountain	Initial	18-OCT-16	2.950	ppb
51615	51615-2-HAL-F01	Main- Outside Room 288, Fountain	Flush180	18-OCT-16	2.380	ppb
51615	51615-2-HAL-F01	Main- Outside Room 288, Fountain	Flush180	18-OCT-16	2.230	ppb
51615	51615-2-HAL-F01	Main- Outside Room 288, Fountain	Flush180	18-OCT-16	2.320	ppb
51615	51615-2-HAL-F01	Main- Outside Room 288, Fountain	Flush180	18-OCT-16	2.120	ppb
51615	51615-2-HAL-F01	Main- Outside Room 288, Fountain	Initial	18-OCT-16	2.870	ppb
51615	51615-3-HAL-F08	Main- Outside Room 330, Fountain	Flush180	18-OCT-16	2.160	ppb
51615	51615-3-HAL-F08	Main- Outside Room 330, Fountain	Flush180	18-OCT-16	2.350	ppb
51615	51615-3-HAL-F08	Main- Outside Room 330, Fountain	Flush180	18-OCT-16	2.030	ppb
51615	51615-3-HAL-F08	Main- Outside Room 330, Fountain	Flush180	18-OCT-16	1.820	ppb



Facility ID	Fixture Code	Fixture Location	Draw Type	Collected On	Result	UOM
51615	51615-3-HAL-F08	Main- Outside Room 330, Fountain	Initial	18-OCT-16	2.420	ppb
51615	51615-3-HAL-F01	Main- Outside Room 331, Fountain	Flush180	18-OCT-16	6.550	ppb
51615	51615-3-HAL-F01	Main- Outside Room 331, Fountain	Flush180	18-OCT-16	6.560	ppb
51615	51615-3-HAL-F01	Main- Outside Room 331, Fountain	Flush180	18-OCT-16	5.950	ppb
51615	51615-3-HAL-F01	Main- Outside Room 331, Fountain	Flush180	18-OCT-16	5.850	ppb
51615	51615-3-HAL-F01	Main- Outside Room 331, Fountain	Initial	18-OCT-16	6.990	ppb
51615	51615-1-124-S13	Main- Teachers Lounge, Sink	Flush180	18-OCT-16	1.590	ppb
51615	51615-1-124-S13	Main- Teachers Lounge, Sink	Flush180	18-OCT-16	1.170	ppb
51615	51615-1-124-S13	Main- Teachers Lounge, Sink	Flush180	18-OCT-16	0.798	ppb
51615	51615-1-124-S13	Main- Teachers Lounge, Sink	Flush180	18-OCT-16	0.552	ppb
51615	51615-1-124-S13	Main- Teachers Lounge, Sink	Initial	18-OCT-16	0.562	ppb